## 100MM RYANSPAN RYANFIRE MASTIC RYANFIRE HP-X TO JOINT

All errors and omissions excepted. The information contained within this drawing is believed to be correct on the date of publication, and is based upon tested and certified solutions. The policy of Ryanfire Products Ltd is one of constant improvement. Installers must ensure that they are following the latest published drawings, test evidence and instructions. Whilst Ryanfire Products Ltd will endeavour to keep its publications up to date, the accuracy of the information contained within this drawing may be affected by pertinent changes in the law or regulatory requirements and alterations or amondments to the specification of the manufactured products. Tors and conditions of raise analysis.

INSTALLATION INSTRUCTIONS

3. SELECT THE 100MM RYANSPAN.

AND DEBRIS.

1. ENSURE THE APERTURE IS CLEAN AND FREE OF DUST

4. COMPRESS THE RYANSPAN AND FIT IT WITHIN THE GAP TO SIT FLUSH WITH ONE SIDE THE WALL.

5. TO JOIN TWO PIECES OF RYANSPAN, APPLY RYANFIRE HP-X TO EACH END AND BUTT THEM UP AGAINST

EACH OTHER. ENSURE A TIGHT FITTING SEAL.

2. APPLY A BEAD OF RYANFIRE MASTIC TO THE INTERNAL EDGES OF THE APERTURE.

Ryanfire Products Ltd owns and has copyright to these drawings. They are to be used only for the purpose for which they were intended and supplied and are not to be sold, transferred or made available for use by a third party. Any misuse of these drawings will result in legal proceedings.

Products: RYANSPAN

RYANFIRE MASTIC

RYANFIRE HP-X AS 1530.4/AS 4072.1

BK: 222

Approvals:

FR PLASTERBOARD

Ref: 22SFR00048

ID: A

Scenario: Horizontal linear gap seal

Construction: 166mm FR Plasterboard /

Masonry wall

Void Size: 100mm wide

Fire Integrity: 60 minutes
Fire Insulation: 60 minutes

Web based drawings are for example only. Fire performance of any system is dependant on, but not limited to size of opening, substrate, if penetrations are passing through, type, size and number. Please refer to Ryanfire technical department for detailed and specific fire performance information.



RYANFIRE Technical Support: info@ryanfire.co.nz - Tel 09 443 0362

Drawing Titl

## Ryanspan horizontal linear gap seal 166mm plasterboard wall

Scale

NTS

Date

August 2023

Drawing Number

Rev

V67.9

1.0