



Register of Hand Operated Fire Fighting Equipment

ISSUE 1 | REVISION 1



Contents

1. Introduction.....	2
2. Legislative and Standards Background	2
3. Operation of the Register.....	3
4. Subscriptions and Updates.....	3
5. Charges	3
6. Annual Review	4
7. Copyright	4
8. Responsibility	4
9. Disclaimer	4
10. Listing procedures and administration of the Register.....	4
) 10.1 Procedures for a manufacturer to obtain “listing” in the register.....	4
) 10.2 Criteria for obtaining product listing in this Register.....	5
11. Clearance Certificate.....	5

Section A: Listed Fire Extinguishers

) FIREWATCH NEW ZEALAND LTD.....	6
) PSL FIRE & SAFETY	7

1. Introduction

This Register of Certified Product (“Register”) lists hand operated fire-fighting Products and associated equipment that has been formally issued with a Cylinder Importation Compliance Certificate as complying with the requirements of NZS 4503 Hand Operated Fire Fighting Equipment and/or a standard directly cited by NZS 4503.

Listings are also included for items which have been certified/listed by the relevant overseas listing agencies as compliant with standard(s) cited in NZS 4503 as acceptable for that product type.

Listings are also included for items which have been formally certified as above at the time of first listing, then manufacturer/importer self certified by formal declaration for either ongoing up grades or changes necessitated by amendments to governing standards.

Each listing details the basis on which that listing has been accepted.

This Register is published by the Fire Protection Association (New Zealand) Incorporated (FPANZ), under a memorandum of understanding an FPANZ approved inspectorate body have responsibility for independent technical control of this Register.

This Register has been produced for reference by:

-) Territorial Authorities
-) Fire & Emergency NZ
-) Architects
-) Consultants

-) Designers
-) Installation, Maintenance and Testing Contractors
-) Building owners
-) Importers
-) Manufacturers
-) Accredited Inspection Bodies
-) Standards New Zealand

The Register is intended to be used for both new installations to the latest standards, and for the upgrade and extension of historic installations.

2. Legislative and Standards Background

All fire extinguishers must meet the requirements of the Hazardous Substances and New Organisms Act (HSNO) and other relevant regulations.

NZS 4503:2005 clause 2.2 requires Hand operated fire-fighting equipment to comply with the following manufacturing standards:

-) S/NZS 1221 – Fire hose reels
-) AS/NZS 1841 – Parts 1-8 Portable fire extinguishers (General & Specific requirements)
-) AS/NZS 3504 – Fire blankets
-) AS/NZS 4353 – Portable fire extinguishers – Aerosol type
-) AS 4265 – Wheeled fire extinguishers

CONTINUED OVERLEAF...

For specialist circumstances the FPANZ recognise that the above standards may not cover the required products and other internationally recognised standards may be accepted as design standards and be listed in this register.

Equipment may also be included that has been approved & listed for fire protection purposes by a recognised test and approval body and which conforms with the requirements of recognised standards.

3. Operation of the Register

In order to maintain a consistent, workable, and readily accessible system, available to the whole industry

Only certified products from Companies that are signatories to the FPANZ Code of Ethics will be accepted for listing. Product certification will be achieved based on evidence of meeting industry standards including certificates from registered Compliance Certifier or suitable evidence of overseas agency listing for new product. Self-certification may be acceptable for subsequent changes to listed product.

- a) FPANZ shall provide clerical/secretarial and publishing/subscription services to facilitate the widespread distribution and regular updates of the Register, and
- b) Manufacturers or importers shall make application for listing of products in the Register according to the procedures and criteria specified below, they shall also supply and maintain compatibility details for the equipment listed.

Any equipment manufacturer or importer is eligible to apply for listing, subject to the procedures and criteria listed below.

The Register is publicly available. Cost-recovery charges are levied on manufacturers / importers requesting product listings.

Technical operation and publication of the Register is independent of the equipment manufacturers and importers.

4. Subscriptions and Updates

All enquiries regarding subscriptions and copyright shall be referred to:

Fire Protection Association NZ Inc
Private Box 302372, North Harbour
Auckland 1330

Phone: (09) 414 4450
Email: info@fpanz.org

The Hand Operated Fire-Fighting Equipment Register is no longer published in a printed format and is available solely as a PDF as part of FPA membership or free to end users.

This register is available to all FPA members free of charge and can be downloaded from the member's only section of the Fire Protection Association website,

http://www.fireprotection.org.nz/online-resources/FPA_equipment_registers 

5. Charges

Charges will be made by FPANZ for new listings, and for the provision of an annual audit and amendment service as follows:

- ▶ Annual revalidation of “Section A” listed items per manufacturer / importer

	FPANZ Members	Non FPANZ Members
1-25 items	\$1350	\$2025
26-75 items	\$1596	\$2394
76-150 items	\$1915	\$2872
> 151 items	\$2297	\$3446

- ▶ Initial listing fees for individual items, all submitted together, as follows:

	FPANZ Members
1st Item	\$525
Additional Items	\$65 each

Charges will be made by FPANZ for technical assessment of applications for listing, and amendments to existing listings as follows:

- ▶ Listing of product and other item(s) supported by relevant documentation such as a Cylinder Importation Compliance Certificate.
- ▶ Listing of a product already approved to an acceptable overseas standard and supported by an overseas agency listing

CONTINUED OVERLEAF...

- › Assessment of amendment/upgrade to an existing listed product supported by a manufacturer's / importers declaration
- › Assessment of amendment/upgrade to an existing product or peripheral device supported by a manufacturer's / importers declaration
- › Where manufacturer / importer site visits are required to inspect records or are otherwise considered necessary these will be at the discretion of the independent technical advisor, and this service will be charged at the current hourly rate of the independent technical advisor plus disbursements.

Note if an application is rejected for any reason, FPANZ reserves the right to charge additional fees (based on actual time and costs) for that products reassessment

All charges are in New Zealand Dollars, are exclusive of GST, and are subject to change without notice.

6. Annual Review

If required technical and administrative reviews of the Register will be undertaken annually by the technical editor and/or publisher to revalidate its contents and enable deletion of obsolete products or non-trading manufacturers / importers.

Manufacturers /importers who do not return the necessary documentation after three (3) requests and/or do not pay the applicable charge(s) detailed in section 5, will have their listing marked 'OBSOLETE', and after 12 months deleted.

7. Copyright

Copyright if the Register is held by FPANZ as publisher. All rights are reserved. **The Register may not be copied or reproduced in any way, either in whole or in part, without the express permission of FPANZ,** obtained through the Executive Director.

8. Responsibility

The individual manufacturers or importers are responsible for Equipment listings and the accompanying Compatibility Details of listings. The technical advisor is responsible for reviewing and authorising the listing.

9. Disclaimer

This Register details the listing status of products and components current at the time of issue. This listing status is subject to change without notice at any time.

The currency and validity of any particular copy of the Register is dependent on multiple factors, including ongoing payment of subscription fees, postal services, and timely and correct filing of updates.

Listing in this Register does not imply any warranty whatsoever by the publishers or their technical advisors as to the field performance of products, systems, or components listed.

Listing in this Register does not imply any warranty whatsoever by the publishers or their technical advisors against any defect or failure in service of products, systems, or components listed.

Listing in this Register does not imply any responsibility whatsoever by the publishers or their technical advisors in-regards to patents or other features or conditions applying in respect of any products, systems, or components listed.

Neither the publishers nor their technical advisors, nor any of their officers or employees shall be liable to any person or company for anything contained or implied in, or omitted from, this Register or any update of any part of it.

10. Listing procedures and administration of the Register

10.1 Procedures for a manufacturer / importer to obtain "listing" in the Register

All enquiries for amendments, alterations and additions to listings shall be referred to FPANZ in the first instance for administration purposes:

Fire Protection Association NZ Inc
Private Box 302372, North Harbour
Auckland 1330

Phone: (09) 414 4450
Email: info@fpanz.org

These details will then be passed on to an FPANZ approved inspectorate body.

The general manager, or his/her duly authorised delegate, is responsible for technical review of all applications made by manufacturers / importers for listing of equipment and components.

CONTINUED OVERLEAF...

Supporting documentation and/or a formal Manufacturer's / Importers Declaration as applicable according to the criteria below shall accompany each application for listing.

Listing is open to any equipment manufacturer or importer who meets the criteria.

10.2 Criteria for obtaining product listing in this Register

10.2.1 Listing new products

This shall be in the form of an overseas approvals agency listing certificate e.g. SAI, Globalmark etc & a Cylinder Importation Compliance Certificate.

10.2.2 Amendments/Upgrades to existing listed products

A Manufacturer's / Importers Declaration & accompanying relevant documentation from a recognized compliance certifier.

11. Clearance Certificate

As required by the Hazardous Substances and New Organisms Act and relevant regulations, All fire extinguishers imported into New Zealand are required to be import cleared. A copy of this import clearance certificate is required to be provided. It requires the manufacturer /importer to make a formal legal declaration and to hold and maintain a Technical File capable of justifying this declaration if legally challenged.

This certification and scope will be reviewed by FPANZ in each instance.

A Manufacturer's / importers Declaration shall be made and shall:

- 】 Be appropriately signed on an official declaration
- 】 Constitute a formal declaration of compliance with the relevant requirements of the applicable version of the relevant standard (e.g. AS/NZS 1841)
- 】 Detail what product(s) are covered
- 】 Detail what changes have been made to the product(s) if any.
- 】 Detail what self-testing has been undertaken if any.
- 】 Detail third party/laboratory appraisal testing (to be undertaken (if any).
- 】 Undertake to make any changes to the product(s) as may be required as a result of any non-conformance with the applicable standards discovered subsequent to the making of the Declaration.
- 】 Acknowledge that the FPANZ or their technical advisers carry no liability or responsibility for the product's performance in the field.

FIREWATCH NEW ZEALAND LTD

Manufacturer Code: FW

PO Box 302793
North Harbour
Auckland 0751Ph: (09) 415 3337
Fax: (09) 415 3339
Website: www.firewatch.co.nz

The equipment listed in this register is all approved to AS/NZS 1841 & has been imported & product cleared through an approved agency as required under the Hazardous Substances (Compressed Gases) Regulations.

The company that supplies this equipment in New Zealand is a FPANZ member & a signatory to the FPANZ's Code Of Practice.

Model number	Extinguishing agent	Agent capacity	Rating	FERN number	New Zealand Supplier	Clearance Company
DPF1	ABE POWDER	1kg	1A20B:E	2048-DL-6312	Firewatch	Haztec
DPF1.5	ABE POWDER	1.5kg	2A20B:E	2048-DL-6318	Firewatch	Haztec
DPF2	ABE POWDER	2kg	2A30B:E	2048-DK-6307	Firewatch	Haztec
DPF2.5	ABE POWDER	2.5kg	3A40B:E	2048-DA-6314	Firewatch	Haztec
DPF4.5	ABE POWDER	4.5kg	3A60B:E	2048-DL-6315	Firewatch	Haztec
DPD4.5S	ABE POWDER	4.5kg	3A60B:E	2048-DA-6320	Firewatch	Haztec
DP4.5	ABE POWDER	4.5kg	4A80B:E	2048-DJ-6309	Firewatch	Haztec
DPF9	ABE POWDER	9kg	6A80B:E	2048-DJ-6310	Firewatch	Haztec
DP9	ABE POWDER	9kg	6A80B:E	2048-DF-6316	Firewatch	Haztec
C2	C02	2kg	2B:E	2063-LM-7104	Firewatch	Haztec
C3.5	C02	3.5kg	5B:E	2063-LM-7105	Firewatch	Haztec
C5	C02	5kg	5B:E	2063-LM-7106	Firewatch	Haztec
FS1.6	Foam	1.6lt	1A1F	2085-DE-5412	Firewatch	Haztec
FS2.5	Foam	2.5lt	1A5B1F	2085-DE-5413	Firewatch	Haztec
FS4.5	Foam	4.5lt	2A10B1F	2085-DE-5414	Firewatch	Haztec
FS6	Foam	6lt	3A10B3F	2085-DE-5415	Firewatch	Haztec
FS9	Foam	9lt	4A10B3F	2085-DE-5416	Firewatch	Haztec
MWC7lt	Wet Chemical	7lt	2A4F	2086-DA-3401	Firewatch	Haztec

PSL FIRE & SAFETY

Manufacturer Code:

10 Akatea Road
Glendene
Auckland 0602Ph: (09) 8188048
Email: sales@pslfireandsafety.co.nz
Website: www.pslfireandsafety.co.nz

The equipment listed in this register is all approved to AS/NZS 1841 & has been imported & product cleared through an approved agency as required under the Hazardous Substances (Compressed Gases) Regulations.

The company that supplies this equipment in New Zealand is a FPANZ member & a signatory to the FPANZ's Code Of Practice.

Model number	Extinguishing agent	Agent capacity	Rating	FERN number	New Zealand Supplier	Clearance Company
9040	ABE Powder	1kg	1A:20B:E	20621-BB-6321	PSL Fire & Safety	Haztec
8425	ABE Powder	1kg	1A:20B:E	20621-DA-6301	PSL Fire & Safety	Haztec
8411	ABE Powder	1.5kg	2A:20B:E	20621-DC-6319	PSL Fire & Safety	Haztec
8412	ABE Powder	2kg	3A:30B:E	20621-DB-6305	PSL Fire & Safety	Haztec
8413	ABE Powder	2.5kg	3A:40B:E	20621-DB-6309	PSL Fire & Safety	Haztec
8414	ABE Powder	4.5kg	4A:60B:E	20621-DB-6311	PSL Fire & Safety	Haztec
8415	ABE Powder	6kg	4A:80B:E	20621-DB-6313	PSL Fire & Safety	Haztec
8416	ABE Powder	9kg	6A:80B:E	20621-DC-6315	PSL Fire & Safety	Haztec
8450	Wet Chemical	2Ltr	1A:4F	2126-DA-3404	PSL Fire & Safety	Haztec
8455	Wet Chemical	7Ltr	3A:4F	2126-DA-3403	PSL Fire & Safety	Haztec
8465	Carbon Dioxide	2kg	2B:E	22111-BB-7104	PSL Fire & Safety	Haztec
8466	Carbon Dioxide	3.5kg	10B:E	22111-BB-7105	PSL Fire & Safety	Haztec
8467	Carbon Dioxide	5kg	10B:E	22211-BB-7106	PSL Fire & Safety	Haztec
8485	Water	9Ltr	3A	20421-BB-2401	PSL Fire & Safety	Haztec
8490	Foam	9Ltr	3A:30B	20422-BB-5401	PSL Fire & Safety	Haztec