



Register of Passive Fire Protection Products

ISSUE 1 | REVISION 4.6



Contents

1. Introduction.....	3
2. Legislative and Standards Background	3
3. Operation of the Register	3
4. Subscriptions and Updates.....	3
5. Charges	3
6. Annual Review	3
7. Copyright	3
8. Responsibility	4
9. Disclaimer	4
10. Listing procedures and administration of the Register	4
) 10.1 Procedures for a manufacturer to obtain “listing” in the register	4
) 10.2 Criteria for obtaining product listing in this Register.....	4
11. Manufacturer’s Declaration	4
Annex 1: Form of Manufacturer’s Declaration of Compliance	5
Annex 2: Form for Annual Revalidation	6
Change Log for Issue 4 Revision 6.....	7

Section A: Fire Stopping Products/Solutions: FPA Member Companies

) 3M NEW ZEALAND LTD Industrial & Tapes Division

Blank Opening	9-10
Electrical Penetration Services	10-15
Non-Insulated Non-Combustible Pipes	15-18
Insulated Non-Combustible Pipes	18-19

) BOSS Passive Fire

Blank Opening	20
Construction Joints.....	22
Electrical Penetration Services	
– Data & Comms Cables:	26
– Power Cables:	26-28
– Other Electrical Penetrations:	30
Non-Insulated Non-Combustible Pipes	30-33
Insulated Non-Combustible Pipes:	
– HVAC+R pipes.....	33-36
Combustible Pipes	36-43
Mixed Service Combinations – Bundles	44-46
Ducts/Dampers	46-47

) FIRESTOP CENTRE (Distributor of PROTECTA Brand)

Blanks	48
Non-Insulated Metal Pipes.....	49
Insulated Metal Pipes	50-51
Plastic Pipes.....	52
Electrical Penetration Services	53-54
Seismic/Construction Joints	54-55
HVAC.....	55
Hatches	55
Flush Boxes / Socket Boxes	55

) HILTI NEW ZEALAND LTD

Blank Opening	56-59
Non-Insulated Non-Combustible Pipes	60-63
Insulated Non-Combustible Pipes.....	63-92
Non-Insulated Combustible Pipes.....	93-101
Insulated Combustible Pipes	102
Electrical Penetration Services.....	103-144
Construction Joints.....	145-148

) iPASSIVE

Blank Seals.....	149-150
Non-Insulated Non-Combustible Pipes	150-152
Insulated Non-Combustible Pipes.....	152-166
Non-Insulated Combustible Pipes.....	167-172
Electrical Penetration Services.....	172-181
Seismic/Construction Joints	181-184

) RYANFIRE PRODUCTS LTD

Non-Insulated Non-Combustible Pipes	185-186
Insulated Non-Combustible Pipes	187-189
Non-Insulated Combustible Pipes.....	189-197
Insulated Combustible Pipes	197-198
Electrical Penetration Services.....	198-203
Seismic/Construction Joints	204-205
HVAC.....	206
Mixed Service Penetration Devices.....	206-207
Miscellaneous Penetrations	207

) SNAP FIRE SYSTEMS

Non-Insulated Combustible Pipes.....	208-236
Electrical Penetration Services.....	237
Mixed Service Penetration Devices.....	237

1. Introduction

This register of certified products (“Register”) lists Passive Fire Protection systems that have been formally issued with a laboratory report in accordance to AS 4072.1 – 2005, AS 1530.4-2005.

The register also includes systems tested to latest AS 1530.4-2014 standard.

The Register is published by the Fire Protection Association (New Zealand) incorporated (FPANZ).

The Register has been produced for reference by:

- › Territorial Authorities
- › Fire Engineers
- › Architects
- › Consultants
- › Designers
- › Installation, maintenance and inspection contractors
- › Building contractors
- › Building owners
- › Accredited Inspection Bodies

The Register is intended to be used for both new and existing installations, to ensure code compliant products are being specified, consented, installed. The Register will provide an invaluable listing of code complaint products available to industry.

2. Legislative and Standards Background

All fire stopping systems (*fire stops*) to be specified and accepted as part of the building consent and inspection approvals process shall be in accordance with AS4072.1-2005. Fire test reports or *Variations subject*

to *Formal Opinion* complying with the requirements of AS1530.4-2005 and AS4072.1-2005 shall be available upon request to support the system proposed and demonstrate on site installation where necessary.

3. Operation of the Register

The Register is self-regulating, each product/system supplier has submitted their product with the understanding that they will provide, upon request, the AS1530.4-2005 fire test or AS4072.1-2005 assessment report reference within their companies listing.

Any report featured in the Register of Passive Fire Protection Products will be within date.

Failure to issue the report upon request may result in that entry being removed from the Register.

4. Subscriptions and Updates

This register will be updated every six months from the release date. All enquiries regarding new listings, updates and copyright shall be referred to:

Team@FPANZ
Fire Protection Association NZ Inc
Private Box 302372, North Harbour
Auckland 1330

Phone: (09) 414 4450
Email: info@fpanz.org

The Register of Passive Fire Protection Products is available solely as a PDF and can be accessed through the “downloads & files” at section at http://www.fireprotection.org.nz/online-resources/FPA_equipment_registers 

5. Charges

Charges will be made by FPANZ for new listings, and for the provision of the annual audit and amendment service as follows:

INITIAL INCLUSION	FPANZ Members	Non FPANZ Members
Initial Inclusion Fee (includes 150 entries)	\$950	\$1330
Additional entries 151 – 300	+\$500	+\$700
Additional entries 301 – 450	+\$1000	+\$1400
Additional entries 451+	+\$1500	+\$2100

ANNUAL RENEWAL	FPANZ Members	Non FPANZ Members
Annual Renewal Fee (includes 150 changes/new entries)	\$950	\$1330
Additional entries 151 – 300	+\$500	+\$700
Additional entries 301 – 450	+\$1000	+\$1400
Additional entries 451+	+\$1500	+\$2100

AD HOC CHANGES	FPANZ Members	Non FPANZ Members
Basic Change Fee (includes 150 changes/new entries)	\$550	\$900
Additional entries 151 – 300	+\$500	+\$700
Additional entries 301 – 450	+\$1000	+\$1400
Additional entries 451+	+\$1500	+\$2100

6. Annual Review

Technical and administrative reviews of the Register will be undertaken annually to revalidate its contents and enable deletion of obsolete products/systems, reports outside their validity date or non-trading manufactures/suppliers.

Manufacturers and suppliers who do not return the necessary documentation after three (3) requests and/or do not pay the applicable charge(s) detailed in section 5, will have their listing marked "OBSOLETE", and after 12 months deleted.

7. Copyright

Copyright if the Register is held by FPANZ as publisher. All rights are reserved. **The Register may not be copied or reproduced in any way, either in whole or in part, without the express permission of FPANZ.** Obtained through the Chief Executive Officer.

8. Responsibility

The individual manufacturers or suppliers are responsible for the Register listings and the accompanying fire test performance data. FPANZ simply publish the individual systems for industry awareness purposes only.

9. Disclaimer

The Register details the listing status of products and components current at the time of issue. This listing status is subject to change without notice at any time.

The currency and validity of any particular copy of Register is dependent on multiple factors, including ongoing payment of subscription fees, postal services, and timely and correct filing of updates.

Listing in this Register does not imply any warranty whatsoever by the publishers or their technical advisors

as to the field performance of products, systems or components listed.

Listing in this Register does not imply any responsibility whatsoever by the publishers or their technical advisors in regards to patents or other features or conditions applying in respect of any products, systems or components listed.

Neither the publishers nor their technical advisors, nor any of their officers or employees shall be liable to any person or company for anything contained or implied in, or omitted from, this Register or any update or any part of it.

10. Listing procedures and administration of the Register

All enquiries for listing, amendments, alterations and additions to listings shall be referred to FPANZ in the first instance for administration purposes:

Team@FPANZ
Fire Protection Association NZ Inc
Private Box 302372, North Harbour
Auckland 1330
Phone: (09) 414 4450
Email: info@fpanz.org

These details will then be passed on to an FPANZ approved listing body.

A formal Suppliers or manufacturers declaration will be required concerning the validity and accuracy of the reports detailed within the listing.

Listing is available to any supplier/manufacturer who meets the listing criteria.

Listing Criteria:

- › AS1530.4 -2005 Fire Test Reports / AS4072.1 - 2005 Assessment Reports produced by ILAC accredited laboratories (International Laboratory Accreditation Cooperation).

- › Fire Test Assessment reports in accordance with AS4072.1-2005
- › Fire Test Reports in accordance with AS 1530.4-2005
- › Reports are within date
- › Reports featured in the Register not in the name of the listee must be accompanied by a manufacturers letter confirming the listee has permission to issue the report
- › Suppliers / Manufactures agree to issue listed/referenced test reports upon request

11. Manufacturer's Declaration

A Suppliers or Manufacturers Declaration is a form of self-certification. It requires the Supplier or Manufacturer to make a formal declaration and to hold and maintain a technical file capable of justifying this declaration if legally challenged.

Such technical file would hold information such as supporting fire test data forming part of any formal assessment listed within the Register.

A Supplier or Manufacturers Declaration shall:

- › Be appropriately signed on official letterhead
- › Constitute a formal declaration of compliance with the relevant requirements of the New Zealand Building Code
- › Detail what products are covered
- › Acknowledge that the FPANZ or their technical advisers and officers carry no liability or responsibility for the products performance in the field

The following Declaration of Compliance is required to be completed for all submissions. Except where expressly permitted below, no modification or variation to this Declaration will be accepted.

The wording shall be reproduced on official company/organisation letterhead with the appropriate details inserted [Where indicated thus]. Where alternatives are provided – viz manufacturer/importer, I/we etc., one alternative may be deleted as applicable.

COMPANY LETTERHEAD

Date

Address

Chief Executive Officer
Fire Protection Association NZ Inc
Private Box 302372, North Harbour
Auckland 0751

Declaration of Compliance

On behalf of [Name of company] (Company), I confirm as follows:

- 1. This Declaration of Compliance is made in respect of the product or products currently listed in the Passive Fire Protection Products Register and complies with the listing criteria as detailed in clause 10 page 4 of the register*
- 2. The Company acknowledges that the making of this Declaration is a condition to the Product being listed, or continuing to be listed in the Register*
- 3. The Company agrees and acknowledges that:*
 - (a) the FPANZ gives no warranty in respect of the Product; and*
 - (b) the FPANZ, its officers, employees, contractors or agents shall not in any way be liable or responsible, whether to the Company or to third parties for the performance of the Product.*

The Company agrees and acknowledges that:

- (a) any listed product not complying with the requirements detailed in clause 10 can be removed from the register at the discretion of the FPANZ board without redress by from the manufacturer/importer.*

The register is intended to be a benefit to industry to improve information transparency and building code compliance

Yours faithfully

Name of Company

Name of duly authorised signatory

Title

A copy of the current Register listing is to be sent by FPANZ to each manufacturer annually to obtain administrative revalidation of their listing and contact details, and to ensure that the manufacturer is still trading.

Each manufacturer shall be required to respond on official letterhead according to the following form:

REVALIDATION OF LISTING IN PASSIVE FIRE PROTECTION PRODUCTS REGISTER

I, on behalf of _____(name of Company) confirm that since the date of initial listing, or since the date of the last revalidation whichever is most recent, all published systems comply with the requirements detailed in clause 10 of the register.

I attach a copy of our current register listings, signed on the front page and initialed on all other pages.

Yours faithfully
Name of Company

Name of duly authorised signatory

Title

Change Log for Issue 1 Revision 4.6

The main areas of change in the development of Issue 1 Revision 4.6 are as follows.

1. Replacement of Ryanfire Listing p.185 – 207





FPA Member Companies



Section A: Fire Stopping Products/Solutions FPA Member Companies

<ul style="list-style-type: none"> › 3M NEW ZEALAND LTD Industrial & Tapes Division 	
Blank Opening.....	9-10
Electrical Penetration Services	10-15
Non-Insulated Non-Combustible Pipes.....	15-18
Insulated Non-Combustible Pipes	18-19
› BOSS Passive Fire	
Blank Opening.....	20
Construction Joints	22
Electrical Penetration Services	
– Data & Comms Cables:.....	26
– Power Cables:.....	26-28
– Other Electrical Penetrations:.....	30
Non-Insulated Non-Combustible Pipes.....	30-33
Insulated Non-Combustible Pipes:	
– HVAC+R pipes.....	33-36
Combustible Pipes	36-43
Mixed Service Combinations – Bundles.....	44-46
Ducts/Dampers	46-47
› FIRESTOP CENTRE (Distributor of PROTECTA Brand)	
Blanks.....	48
Non-Insulated Metal Pipes	49
Insulated Metal Pipes.....	50-51
Plastic Pipes.....	52
Electrical Penetration Services	53-54
Seismic/Construction Joints.....	54-55
HVAC	55
Hatches.....	55
Flush Boxes / Socket Boxes.....	55
› HILTI NEW ZEALAND LTD	
Blank Opening.....	56-59
Non-Insulated Non-Combustible Pipes.....	60-63
Insulated Non-Combustible Pipes	63-92
Non-Insulated Combustible Pipes	93-101
Insulated Combustible Pipes.....	102
Electrical Penetration Services	103-144
Construction Joints	145-148
› iPASSIVE	
Blank Seals.....	149-150
Non-Insulated Non-Combustible Pipes.....	150-152
Insulated Non-Combustible Pipes	152-166
Non-Insulated Combustible Pipes	167-172
Electrical Penetration Services	172-181
Seismic/Construction Joints.....	181-184
› RYANFIRE PRODUCTS LTD	
Non-Insulated Non-Combustible Pipes.....	185-186
Insulated Non-Combustible Pipes	187-189
Non-Insulated Combustible Pipes	189-197
Insulated Combustible Pipes.....	197-198
Electrical Penetration Services	198-203
Seismic/Construction Joints.....	204-205
HVAC	206
Mixed Service Penetration Devices	206-207
Miscellaneous Penetrations.....	207
› SNAP FIRE SYSTEMS	
Non-Insulated Combustible Pipes	208-236
Electrical Penetration Services	237
Mixed Service Penetration Devices	237

3M NEW ZEALAND LTD Industrial & Tapes Division

Manufacturer Code: 3M

94 Apollo Drive
Rosedale
Auckland 0632Ph: 0800 474 787
Email: 3mznitb@mmm.com
www.3m.co.nz/fireprotection

The products listed in this register have all been tested to AS1530.4-2005 or Assessed to AS 4072.1-2005 as referenced within the New Zealand Building Code.

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
BLANK OPENING						
Blank	Floor	120 mm Concrete	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material.	-/240/120	Max opening 100 mm diameter	RIR FCO-3220F
Blank	Floor	150 mm Concrete	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material.	-/240/180	Max opening 100 mm diameter	RIR FCO-3220F
Blank	Floor	170 mm Concrete	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material.	-/240/240	Max opening 100 mm diameter	RIR FCO-3220F
Blank	Floor	120 mm Concrete	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material.	-/180/120	Max opening 110 mm diameter	RIR FCO-3219D
Blank	Floor	150 mm Concrete	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material.	-/180/180	Max opening 110 mm diameter	RIR FCO-3219D
Blank	Floor	120 mm Concrete	3M Fire Barrier Pillows 3M Moldable Putty MP+	-/120/90	Max opening 425 x 300 mm	RIR FCO-3217C
Blank	Wall	100 mm Plasterboard / Hollow Mansory	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material.	-/120/120	Max opening 100 mm diameter	RIR FCO-3220F
Blank	Wall	100 mm Concrete / Solid Masonry	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material.	-/120/120	Max opening 100 mm diameter	RIR FCO-3220F
Blank	Wall	150 mm Concrete / Solid Masonry	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material.	-/180/180	Max opening 100 mm diameter	RIR FCO-3220F
Blank	Wall	170 mm Concrete / Solid Masonry	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material.	-/240/240	Max opening 100 mm diameter	RIR FCO-3220F
Blank	Wall	100 mm Plasterboard / Hollow Mansory	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material.	-/120/120	Max opening 100 mm diameter	RIR FCO-3219D
Blank	Wall	100 mm Concrete / Solid Masonry	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material.	-/120/120	Max opening 100 mm diameter	RIR FCO-3219D
Blank	Wall	150 mm Concrete / Solid Masonry	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material.	-/180/180	Max opening 100 mm diameter	RIR FCO-3219D
Blank	Wall	170 mm Concrete / Solid Masonry	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material.	-/240/240	Max opening 100 mm diameter	RIR FCO-3219D
Blank	Wall	116 mm Plasterboard / Hollow Mansory	3M Fire Barrier Pillows 3M Moldable Putty MP+	-/120/30	Max opening 800 x 600 mm	RIR FCO-3217C

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
BLANK OPENING						
Blank	Wall	100 mm Concrete / Solid Masonry	3M Fire Barrier Pillows 3M Moldable Putty MP+	-/180/30	Max opening 800 x 600 mm	RIR FCO-3217C
Blank	Wall	75 mm Concrete / Solid Masonry / Lightweight Concrete / Aerated Autoclaved Concrete (AAC)	3M Fire Barrier Pillows 3M Moldable Putty MP+	-/180/30	Max opening 425 x 300 mm	RIR FCO-3217C
ELECTRICAL PENETRATION SERVICES						
Mixture of Power Supply & Communication Cables	Floor	120 mm Concrete	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material.	-/180/-	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 250 x 140 mm	RIR FCO-3220F
Mixture of Power Supply & Communication Cables	Floor	120 mm Concrete	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300 mm, each side)	-/180/90	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 250 x 140 mm	RIR FCO-3220F
Mixture of Power Supply & Communication Cables	Floor	120 mm Concrete	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/180/120	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 250 x 140 mm	RIR FCO-3220F
Communication Cables only	Floor	120 mm Concrete	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material.	-/240/30	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D2) Max opening 250 x 140 mm	RIR FCO-3220F
Communication Cables only	Floor	120 mm Concrete	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300 mm, each side)	-/240/90	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D2) Max opening 250 x 140 mm	RIR FCO-3220F
Communication Cables only	Floor	120 mm Concrete	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/240/120	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D2) Max opening 250 x 140 mm	RIR FCO-3220F
Mixture of Power Supply & Communication Cables	Floor	120 mm Concrete	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material.	-/120/30	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 250 x 140 mm	RIR FCO-3219D
Mixture of Power Supply & Communication Cables	Floor	120 mm Concrete	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300 mm, each side)	-/120/60	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 250 x 140 mm	RIR FCO-3219D
Mixture of Power Supply & Communication Cables	Floor	120 mm Concrete	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/120/120	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 250 x 140 mm	RIR FCO-3219D
Communication Cables only	Floor	120 mm Concrete	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material.	-/180/30	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D2) Max opening 250 x 140 mm	RIR FCO-3219D
Communication Cables only	Floor	120 mm Concrete	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300 mm, each side)	-/180/90	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D2) Max opening 250 x 140 mm	RIR FCO-3219D

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
ELECTRICAL PENETRATION SERVICES						
Communication Cables only	Floor	120 mm Concrete	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/180/120	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D2) Max opening 250 x 140 mm	RIR FCO-3219D
Mixture of Power Supply & Communication Cables	Floor	120 mm Concrete	3M Fire Barrier Pillows 3M Moldable Putty MP+ CP25WB+ Sealant	-/180/30	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 425 x 300 mm	RIR FCO-3217C
Mixture of Power Supply & Communication Cables	Floor	120 mm Concrete	3M Fire Barrier Pillows 3M Moldable Putty MP+ CP25WB+ Sealant Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300mm, each side)	-/180/90	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 425 x 300 mm	RIR FCO-3217C
Mixture of Power Supply & Communication Cables	Floor	120 mm Concrete	3M Fire Barrier Pillows 3M Moldable Putty MP+ CP25WB+ Sealant Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600mm, each side)	-/180/120	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 425 x 300 mm	RIR FCO-3217C
Power Supply cables only	Floor	120 mm Concrete	3M Fire Barrier Pillows 3M Moldable Putty MP+ CP25WB+ Sealant	-/180/30	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1) Max opening 425 x 300 mm	RIR FCO-3217C
Power Supply cables only	Floor	120 mm Concrete	3M Fire Barrier Pillows 3M Moldable Putty MP+ CP25WB+ Sealant Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300mm, each side)	-/180/90	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1) Max opening 425 x 300 mm	RIR FCO-3217C
Power Supply cables only	Floor	120 mm Concrete	3M Fire Barrier Pillows 3M Moldable Putty MP+ CP25WB+ Sealant Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600mm, each side)	-/180/120	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 425 x 300 mm	RIR FCO-3217C
Mixture of Power Supply & Communication Cables	Wall	116 mm Concrete / Solid Masonry	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material.	-/120/30	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 250 x 140 mm	RIR FCO-3220F
Mixture of Power Supply & Communication Cables	Wall	100 mm Concrete / Solid Masonry	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300 mm, each side)	-/120/60	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 250 x 140 mm	RIR FCO-3220F
Mixture of Power Supply & Communication Cables	Wall	100 mm Concrete / Solid Masonry	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/120/120	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 250 x 140 mm	RIR FCO-3220F
Power Supply cables only	Wall	116 mm Concrete / Solid Masonry	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material.	-/180/30	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1) Max opening 375 x 110 mm	RIR FCO-3220F
Power Supply cables only	Wall	100 mm Concrete / Solid Masonry	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300 mm, each side)	-/180/60	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1) Max opening 375 x 110 mm	RIR FCO-3220F
Power Supply cables only	Wall	100 mm Concrete / Solid Masonry	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/180/120	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1) Max opening 375 x 110 mm	RIR FCO-3220F

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
ELECTRICAL PENETRATION SERVICES						
Single Power Supply cable	Wall	75 mm Concrete / Solid Masonry / Lightweight Concrete / Aerated Autoclaved Concrete (AAC)	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material.	-/120/120	Single Cables up to 20mm diameter Min 10 mm annular gap, Max opening 50 mm diameter	RIR FCO-3220F
Bundle of Power Cables	Wall	75 mm Concrete / Solid Masonry / Lightweight Concrete / Aerated Autoclaved Concrete (AAC)	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 150 mm, each side)"	-/120/120	Cable Bundles up to 80mm diameter Min 15 mm annular gap"	RIR FCO-3220F
Mixture of Power Supply & Communication Cables	Wall	116 mm Concrete / Solid Masonry	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material.	-/120/30	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 250 x 140 mm	RIR FCO-3219D
Mixture of Power Supply & Communication Cables	Wall	100 mm Concrete / Solid Masonry	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300 mm, each side)	-/120/60	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 250 x 140 mm	RIR FCO-3219D
Mixture of Power Supply & Communication Cables	Wall	100 mm Concrete / Solid Masonry	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/120/120	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 250 x 140 mm	RIR FCO-3219D
Power Supply cables only	Wall	116 mm Concrete / Solid Masonry	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material.	-/120/30	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1) Max opening 375 x 110 mm	RIR FCO-3219D
Power Supply cables only	Wall	100 mm Concrete / Solid Masonry	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300 mm, each side)	-/120/60	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1) Max opening 375 x 110 mm	RIR FCO-3219D
Power Supply cables only	Wall	100 mm Concrete / Solid Masonry	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/120/120	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1) Max opening 375 x 110 mm	RIR FCO-3219D
Single Power Supply cable	Wall	75 mm Concrete / Solid Masonry / Lightweight Concrete / Aerated Autoclaved Concrete (AAC)	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material.	-/120/120	Single Cables up to 20mm diameter Min 10 mm annular gap, Max opening 50 mm diameter	RIR FCO-3219D
Bundle of Power Cables	Wall	75 mm Concrete / Solid Masonry / Lightweight Concrete / Aerated Autoclaved Concrete (AAC)	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 150 mm, each side)	-/120/120	Cable Bundles up to 80mm diameter Min 15 mm annular gap	RIR FCO-3219D
Mixture of Power Supply & Communication Cables	Wall	100 mm Concrete / Solid Masonry	3M Fire Barrier Pillows 3M Moldable Putty MP+	-/120/30	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 800 x 600 mm	RIR FCO-3217C
Mixture of Power Supply & Communication Cables	Wall	100 mm Concrete / Solid Masonry	3M Fire Barrier Pillows 3M Moldable Putty MP+ Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300mm, each side)	-/120/60	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 800 x 600 mm	RIR FCO-3217C
Mixture of Power Supply & Communication Cables	Wall	100 mm Concrete / Solid Masonry	3M Fire Barrier Pillows 3M Moldable Putty MP+ Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600mm, each side)	-/120/120	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 800 x 600 mm	RIR FCO-3217C
Single Power Supply cable	Wall	100 mm Concrete / Solid Masonry	3M Fire Barrier Pillows 3M Moldable Putty MP+	-/120/120	Single Cables up to 20mm diameter Max opening 800 x 600 mm	RIR FCO-3217C

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
ELECTRICAL PENETRATION SERVICES						
Bundle of Power Cables	Wall	100 mm Concrete / Solid Masonry	3M Fire Barrier Pillows 3M Moldable Putty MP+ Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 150mm, each side)	-/120/120	Cable Bundles up to 80mm diameter Max opening 800 x 600 mm	RIR FCO-3217C
Mixture of Power Supply & Communication Cables	Wall	75 mm Concrete / Solid Masonry / Lightweight Concrete / Aerated Autoclaved Concrete (AAC)	3M Fire Barrier Pillows 3M Moldable Putty MP+	-/120/30	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 800 x 600 mm	RIR FCO-3217C
Mixture of Power Supply & Communication Cables	Wall	"75 mm Concrete / Solid Masonry / Lightweight Concrete / Aerated Autoclaved Concrete (AAC)	3M Fire Barrier Pillows 3M Moldable Putty MP+ Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300mm, each side)	-/120/60	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 800 x 600 mm	RIR FCO-3217C
Mixture of Power Supply & Communication Cables	Wall	75 mm Concrete / Solid Masonry / Lightweight Concrete / Aerated Autoclaved Concrete (AAC)	3M Fire Barrier Pillows 3M Moldable Putty MP+ Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600mm, each side)	-/120/120	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 800 x 600 mm	RIR FCO-3217C
Single Power Supply cable	Wall	75 mm Concrete / Solid Masonry / Lightweight Concrete / Aerated Autoclaved Concrete (AAC)	3M Fire Barrier Pillows 3M Moldable Putty MP+	-/120/120	Single Cables up to 20mm diameter Max opening 800 x 600 mm	RIR FCO-3217C
Bundle of Power Cables	Wall	75 mm Concrete / Solid Masonry / Lightweight Concrete / Aerated Autoclaved Concrete (AAC)	3M Fire Barrier Pillows 3M Moldable Putty MP+ Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 150mm, each side)	-/120/120	Cable Bundles up to 80mm diameter Max opening 800 x 600 mm	RIR FCO-3217C
Mixture of Power Supply & Communication Cables	Wall	116 mm Plasterboard / Hollow Masonry	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material.	-/120/30	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 250 x 140 mm	RIR FCO-3220F
Mixture of Power Supply & Communication Cables	Wall	100 mm Plasterboard / Hollow Masonry	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300 mm, each side)	-/120/60	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 250 x 140 mm	RIR FCO-3220F
Mixture of Power Supply & Communication Cables	Wall	100 mm Fire Rated Plasterboard	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/120/120	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 250 x 140 mm	RIR FCO-3220F
Power Supply cables only	Wall	116 mm Plasterboard / Hollow Masonry	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material.	-/180/30	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1) Max opening 375 x 110 mm	RIR FCO-3220F
Power Supply cables only	Wall	100 mm Plasterboard / Hollow Masonry	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300 mm, each side)	-/180/60	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1) Max opening 375 x 110 mm	RIR FCO-3220F
Power Supply cables only	Wall	100 mm Plasterboard / Hollow Masonry	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/180/120	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1) Max opening 375 x 110 mm	RIR FCO-3220F
Single Power Supply cable	Wall	100 mm Plasterboard / Hollow Masonry	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material.	-/120/120	Single Cables up to 20mm diameter Min 10 mm annular gap, Max opening 50 mm diameter	RIR FCO-3220F

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
ELECTRICAL PENETRATION SERVICES						
Bundle of Power Cables	Wall	100 mm Plasterboard / Hollow Mansory	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 150 mm, each side)	-/120/120	Cable Bundles up to 80mm diameter Min 15 mm annular gap"	RIR FCO-3220F
Mixture of Power Supply & Communication Cables	Wall	116 mm Plasterboard / Hollow Mansory	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material.	-/120/30	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 250 x 140 mm	RIR FCO-3219D
Mixture of Power Supply & Communication Cables	Wall	100 mm Plasterboard / Hollow Mansory	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300 mm, each side)	-/120/60	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 250 x 140 mm	RIR FCO-3219D
Mixture of Power Supply & Communication Cables	Wall	100 mm Fire Rated Plasterboard	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/120/120	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 250 x 140 mm	RIR FCO-3219D
Power Supply cables only	Wall	116 mm Plasterboard / Hollow Mansory	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material.	-/180/30	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1) Max opening 375 x 110 mm	RIR FCO-3219D
Power Supply cables only	Wall	100 mm Plasterboard / Hollow Mansory	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300 mm, each side)	-/180/60	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1) Max opening 375 x 110 mm	RIR FCO-3219D
Power Supply cables only	Wall	100 mm Plasterboard / Hollow Mansory	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/180/120	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1) Max opening 375 x 110 mm	RIR FCO-3219D
Single Power Supply cable	Wall	100 mm Plasterboard / Hollow Mansory	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material.	-/120/120	Single Cables up to 20mm diameter Min 10 mm annular gap, Max opening 50 mm diameter	RIR FCO-3219D
Bundle of Power Cables	Wall	100 mm Plasterboard / Hollow Mansory	3M Fire Barrier Pillows 3M Moldable Putty MP+ Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 150mm, each side)	-/120/120	Cable Bundles up to 80mm diameter Min 15 mm annular gap	RIR FCO-3219D
Mixture of Power Supply & Communication Cables	Wall	116 mm Plasterboard / Hollow Mansory	3M Fire Barrier Pillows 3M Moldable Putty MP+	-/120/30	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 800 x 600 mm	RIR FCO-3217C
Mixture of Power Supply & Communication Cables	Wall	116 mm Plasterboard / Hollow Mansory	3M Fire Barrier Pillows 3M Moldable Putty MP+ Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300mm, each side)	-/120/60	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 800 x 600 mm	RIR FCO-3217C
Mixture of Power Supply & Communication Cables	Wall	116 mm Plasterboard / Hollow Mansory	3M Fire Barrier Pillows 3M Moldable Putty MP+ Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600mm, each side)	-/120/120	Cable Bundles , with or without Cable Trays (AS1530.4 Appendix D1 & D2) Max opening 800 x 600 mm	RIR FCO-3217C
Single Power Supply cable	Wall	116 mm Plasterboard / Hollow Mansory	3M Fire Barrier Pillows 3M Moldable Putty MP+	-/120/120	Single Cables up to 20mm diameter Max opening 800 x 600 mm	RIR FCO-3217C
Bundle of Power Cables	Wall	116 mm Plasterboard / Hollow Mansory	3M Fire Barrier Pillows with 3M Moldable Putty MP+ Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 150mm, each side)	-/120/120	Cable Bundles up to 80mm diameter Max opening 800 x 600 mm	RIR FCO-3217C

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
ELECTRICAL PENETRATION SERVICES						
uPVC Conduit empty	Wall	75 mm Concrete / Solid Masonry / Lightweight Concrete / Aerated Autoclaved Concrete (AAC)	3M Ultra GS Intumescent Strip 3M Foil Tape 425 3M Moldable Putty MP+	-/120/120	Single uPVC conduits up to 27mm diameter	RIR FCO-3220F
uPVC Conduit empty	Wall	100 mm Concrete / Solid Masonry	3M Ultra GS Intumescent Strip 3M Foil Tape 425 3M Moldable Putty MP+	-/120/120	Single PVC conduits up to 27mm diameter	RIR FCO-3220F
uPVC Conduit empty	Wall	100 mm Plasterboard / Hollow Masonry	3M Ultra GS Intumescent Strip 3M Foil Tape 425 3M Moldable Putty MP+	-/120/120	Single uPVC conduits up to 27mm diameter	RIR FCO-3220F
uPVC Conduit with optic fibre	Wall	75 mm Concrete / Solid Masonry / Lightweight Concrete / Aerated Autoclaved Concrete (AAC)	3M Ultra GS Intumescent Strip 3M Foil Tape 425 3M Moldable Putty MP+	-/120/120	Single uPVC Conduits up to 27mm diameter (with up to 4 optic fibre cables)	RIR FCO-3220F
uPVC Conduit with optic fibre	Wall	100 mm Concrete / Solid Masonry	3M Ultra GS Intumescent Strip 3M Foil Tape 425 3M Moldable Putty MP+	-/120/120	Single uPVC Conduits up to 27mm diameter (with up to 4 optic fibre cables)	RIR FCO-3220F
uPVC Conduit with optic fibre	Wall	100 mm Plasterboard / Hollow Masonry	3M Ultra GS Intumescent Strip 3M Foil Tape 425 3M Moldable Putty MP+	-/120/120	Single uPVC Conduits up to 27mm diameter (with up to 4 optic fibre cables)	RIR FCO-3220F
NON-INSULATED NON-COMBUSTIBLE PIPES						
Copper pipes	Floor	120 mm Concrete	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300 mm, each side)	-/120/60	Up to 200mm diameter, 2.05 mm max wall thickness Max 10 mm annular gap	RIR FCO-3220F
Copper pipes	Floor	120 mm Concrete	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/120/90	Up to 200mm diameter, 2.05 mm max wall thickness Max 10 mm annular gap	RIR FCO-3220F
Copper pipes	Floor	120 mm Concrete	3M Fire Barrier Pillows 3M Moldable Putty MP+	-/180/30	Up to 15mm diameter x 0.91mm wall thickness Max opening 425 x 300 mm	RIR FCO-3217C
Copper pipes	Floor	120 mm Concrete	3M Fire Barrier Pillows 3M Moldable Putty MP+ Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300 mm, each side)	-/180/60	Up to 15mm diameter x 0.91mm wall thickness Max opening 425 x 300 mm	RIR FCO-3217C
Copper pipes	Floor	120 mm Concrete	3M Fire Barrier Pillows 3M Moldable Putty MP+ Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/180/120	Up to 15mm diameter x 0.91mm wall thickness Max opening 425 x 300 mm	RIR FCO-3217C
Steel pipes	Floor	120 mm Concrete	3M Fire Barrier Pillows 3M Moldable Putty MP+	-/180/30	Up to 34mm diameter x 3.5mm wall thickness Max opening 425 x 300 mm	RIR FCO-3217C
Steel pipes	Floor	120 mm Concrete	3M Fire Barrier Pillows 3M Moldable Putty MP+ Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300 mm, each side)	-/180/60	Up to 34mm diameter x 3.5mm wall thickness Max opening 425 x 300 mm	RIR FCO-3217C

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
NON-INSULATED NON-COMBUSTIBLE PIPES						
Steel pipes	Floor	120 mm Concrete	3M Fire Barrier Pillows 3M Moldable Putty MP+ Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/180/120	Up to 34mm diameter x 3.5mm wall thickness Max opening 425 x 300 mm	RIR FCO-3217C
Copper pipes	Wall	100 mm Concrete / Solid Masonry	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300 mm, each side)	-/120/60	Up to 200mm diameter, 2.05 mm max wall thickness Max 10 mm annular gap	RIR FCO-3220F
Copper pipes	Wall	100 mm Concrete / Solid Masonry	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/120/90	Up to 200mm diameter, 2.05 mm max wall thickness Max 10 mm annular gap	RIR FCO-3220F
Copper pipes	Wall	100 mm Plasterboard / Hollow Masonry	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300 mm, each side)	-/120/60	Up to 200mm diameter, 2.05 mm max wall thickness Max 10 mm annular gap	RIR FCO-3220F
Copper pipes	Wall	100 mm Plasterboard / Hollow Masonry	3M Moldable Putty MP+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/120/90	Up to 200mm diameter, 2.05 mm max wall thickness Max 10 mm annular gap	RIR FCO-3220F
Copper pipes	Wall	100 mm Concrete / Solid Masonry	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300 mm, each side)	-/120/60	Up to 200mm diameter, 2.05 mm max wall thickness Max 10 mm annular gap	RIR FCO-3219D
Copper pipes	Wall	100 mm Concrete / Solid Masonry	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/120/90	Up to 200mm diameter, 2.05 mm max wall thickness Max 10 mm annular gap	RIR FCO-3219D
Copper pipes	Wall	150 mm Plasterboard / Hollow Masonry	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300 mm, each side)	-/120/60	Up to 200mm diameter, 2.05 mm max wall thickness Max 5 mm annular gap	RIR FCO-3219D
Copper pipes	Wall	150 mm Plasterboard / Hollow Masonry	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/120/90	Up to 200mm diameter, 2.05 mm max wall thickness Max 5 mm annular gap	RIR FCO-3219D
Copper pipes	Wall	116 mm Concrete / Solid Masonry	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material.	-/120/30	Up to 15mm diameter x 0.91mm wall thickness Max opening 65 mm diameter	RIR FCO-3219D
Copper pipes	Wall	100 mm Concrete / Solid Masonry	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300 mm, each side)	-/120/60	Up to 15mm diameter x 0.91mm wall thickness Max opening 65 mm diameter	RIR FCO-3219D
Copper pipes	Wall	100 mm Concrete / Solid Masonry	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/120/120	Up to 15mm diameter x 0.91mm wall thickness Max opening 65 mm diameter	RIR FCO-3219D
Copper pipes	Wall	150 mm Concrete / Solid Masonry	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material.	-/240/30	"p to 15mm diameter x 0.91mm wall thickness Max opening 65 mm diameter	RIR FCO-3219D
Copper pipes	Wall	150 mm Concrete / Solid Masonry	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/240/60	Up to 15mm diameter x 0.91mm wall thickness Max opening 65 mm diameter	RIR FCO-3219D
Steel pipes	Wall	116 mm Concrete / Solid Masonry	3M Intumescent Sealant IC 15WB+ 100 kg/m3 Mineral Wool backing material.	-/120/30	Up to 34 mm diameter, with 3.5 mm pipe wall thickness, up to 114 mm diameter pipe wall thickness, Max 35 mm annular gap	RIR FCO-3219D

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
NON-INSULATED NON-COMBUSTIBLE PIPES						
Steel pipes	Wall	100 mm Concrete / Solid Masonry	3M Intumescent Sealant IC 15WB+ 100 kg/m ³ Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300 mm, each side)	-/120/60	Up to 34 mm diameter, with 3.5 mm pipe wall thickness, up to 114 mm diameter pipe wall thickness, Max 35 mm annular gap	RIR FCO-3219D
Steel pipes	Wall	100 mm Concrete / Solid Masonry	3M Intumescent Sealant IC 15WB+ 100 kg/m ³ Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/120/120	Up to 34 mm diameter, with 3.5 mm pipe wall thickness, up to 114 mm diameter pipe wall thickness, Max 35 mm annular gap	RIR FCO-3219D
Steel pipes	Wall	150 mm Concrete / Solid Masonry	3M Intumescent Sealant IC 15WB+ 100 kg/m ³ Mineral Wool backing material.	-/240/30	Up to 34 mm diameter, with 3.5 mm pipe wall thickness, up to 114 mm diameter pipe wall thickness, Max 35 mm annular gap	RIR FCO-3219D
Steel pipes	Wall	150 mm Concrete / Solid Masonry	3M Intumescent Sealant IC 15WB+ 100 kg/m ³ Mineral Wool backing material. Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/240/120	Up to 34 mm diameter, with 3.5 mm pipe wall thickness, up to 114 mm diameter pipe wall thickness, Max 35 mm annular gap	RIR FCO-3219D
Copper pipes	Wall	116 mm Plasterboard / Hollow Masonry	3M Fire Barrier Pillows 3M Moldable Putty MP+	-/120/30	Up to 15mm diameter x 0.91mm wall thickness Max opening 800 x 600 mm	RIR FCO-3217C
Copper pipes	Wall	116 mm Plasterboard / Hollow Masonry	3M Fire Barrier Pillows 3M Moldable Putty MP+ Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300 mm, each side)	-/120/60	Up to 15mm diameter x 0.91mm wall thickness Max opening 800 x 600 mm	RIR FCO-3217C
Copper pipes	Wall	116 mm Plasterboard / Hollow Masonry	3M Fire Barrier Pillows 3M Moldable Putty MP+ Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/120/120	Up to 15mm diameter x 0.91mm wall thickness Max opening 800 x 600 mm	RIR FCO-3217C
Steel pipes	Wall	116 mm Plasterboard / Hollow Masonry	3M Fire Barrier Pillows 3M Moldable Putty MP+	-/120/30	Up to 34mm diameter x 3.5mm wall thickness Max opening 800 x 600 mm	RIR FCO-3217C
Steel pipes	Wall	116 mm Plasterboard / Hollow Masonry	3M Fire Barrier Pillows 3M Moldable Putty MP+ Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300 mm, each side)	-/120/60	Up to 34mm diameter x 3.5mm wall thickness Max opening 800 x 600 mm	RIR FCO-3217C
Steel pipes	Wall	116 mm Plasterboard / Hollow Masonry	3M Fire Barrier Pillows 3M Moldable Putty MP+ Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/120/120	Up to 34mm diameter x 3.5mm wall thickness Max opening 800 x 600 mm	RIR FCO-3217C
Copper pipes	Wall	100 mm Concrete / Solid Masonry	3M Fire Barrier Pillows 3M Moldable Putty MP+	-/180/30	Up to 15mm diameter x 0.91mm wall thickness Max opening 800 x 600 mm	RIR FCO-3217C
Copper pipes	Wall	100 mm Concrete / Solid Masonry	3M Fire Barrier Pillows 3M Moldable Putty MP+ Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300 mm, each side)"	-/180/60	Up to 15mm diameter x 0.91mm wall thickness Max opening 800 x 600 mm	RIR FCO-3217C
Copper pipes	Wall	100 mm Concrete / Solid Masonry	3M Fire Barrier Pillows 3M Moldable Putty MP+ Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)"	-/180/120	Up to 15mm diameter x 0.91mm wall thickness Max opening 800 x 600 mm	RIR FCO-3217C

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
NON-INSULATED NON-COMBUSTIBLE PIPES						
Steel pipes	Wall	100 mm Concrete / Solid Masonry	3M Fire Barrier Pillows 3M Moldable Putty MP+	-/180/30	Up to 34mm diameter x 3.5mm wall thickness Max opening 800 x 600 mm	RIR FCO-3217C
Steel pipes	Wall	100 mm Concrete / Solid Masonry	3M Fire Barrier Pillows 3M Moldable Putty MP+ Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300 mm, each side)	-/180/60	Up to 34mm diameter x 3.5mm wall thickness Max opening 800 x 600 mm	RIR FCO-3217C
Steel pipes	Wall	100 mm Concrete / Solid Masonry	3M Fire Barrier Pillows 3M Moldable Putty MP+ Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/180/120	Up to 34mm diameter x 3.5mm wall thickness Max opening 800 x 600 mm	RIR FCO-3217C
Copper pipes	Wall	75 mm Concrete / Solid Masonry / Lightweight Concrete / Aerated Autoclaved Concrete (AAC)	3M Fire Barrier Pillows 3M Moldable Putty MP+	-/180/30	Up to 15mm diameter x 0.91mm wall thickness Max opening 800 x 600 mm	RIR FCO-3217C
Copper pipes	Wall	75 mm Concrete / Solid Masonry / Lightweight Concrete / Aerated Autoclaved Concrete (AAC)	3M Fire Barrier Pillows 3M Moldable Putty MP+ Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300 mm, each side)	-/180/60	Up to 15mm diameter x 0.91mm wall thickness Max opening 800 x 600 mm	RIR FCO-3217C
Copper pipes	Wall	75 mm Concrete / Solid Masonry / Lightweight Concrete / Aerated Autoclaved Concrete (AAC)	3M Fire Barrier Pillows 3M Moldable Putty MP+ Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/180/120	Up to 15mm diameter x 0.91mm wall thickness Max opening 800 x 600 mm	RIR FCO-3217C
Steel pipes	Wall	75 mm Concrete / Solid Masonry / Lightweight Concrete / Aerated Autoclaved Concrete (AAC)	3M Fire Barrier Pillows 3M Moldable Putty MP+	-/180/30	Up to 34mm diameter x 3.5mm wall thickness Max opening 800 x 600 mm	RIR FCO-3217C
Steel pipes	Wall	75 mm Concrete / Solid Masonry / Lightweight Concrete / Aerated Autoclaved Concrete (AAC)	3M Fire Barrier Pillows 3M Moldable Putty MP+ Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 300 mm, each side)	-/180/60	Up to 34mm diameter x 3.5mm wall thickness Max opening 800 x 600 mm	RIR FCO-3217C
Steel pipes	Wall	75 mm Concrete / Solid Masonry / Lightweight Concrete / Aerated Autoclaved Concrete (AAC)	3M Fire Barrier Pillows 3M Moldable Putty MP+ Fire Barrier Duct Wrap 615+ (Single Layer, Wrap length 600 mm, each side)	-/180/120	Up to 34mm diameter x 3.5mm wall thickness Max opening 800 x 600 mm	RIR FCO-3217C
INSULATED NON-COMBUSTIBLE PIPES						
Copper pipes with Armaflex	Floor	120 mm Concrete	3M Fire Barrier Pillows 3M Moldable Putty MP+	-/180/30	Up to 15 mm diameter x 0.91 mm wall thickness, with 19 mm thick Armaflex through the seal, Max opening 425 x 300 mm	RIR FCO-3217C
Steel pipes with Armaflex	Floor	120 mm Concrete	3M Fire Barrier Pillows 3M Moldable Putty MP+	-/180/30	Up to 34 mm diameter x 3.5 mm wall thickness, with 19 mm thick Armaflex through the seal, Max opening 425 x 300 mm	RIR FCO-3217C

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
Copper pipes with Armaflex	Wall	100 mm Concrete / Solid Masonry	3M Fire Barrier Pillows 3M Moldable Putty MP+	-/180/30	Up to 15 mm diameter x 0.91 mm wall thickness, with 19 mm thick Armaflex through the seal, Max opening 800 x 600 mm	RIR FCO-3217C
Steel pipes with Armaflex	Wall	100 mm Concrete / Solid Masonry	3M Fire Barrier Pillows 3M Moldable Putty MP+	-/180/30	Up to 34 mm diameter x 3.5 mm wall thickness, with 19 mm thick Armaflex through the seal, Max opening 800 x 600 mm	RIR FCO-3217C
Copper pipes with Armaflex	Wall	116 mm Plasterboard / Hollow Masonry	3M Fire Barrier Pillows 3M Moldable Putty MP+	-/120/30	Up to 15 mm diameter x 0.91 mm wall thickness, with 19 mm thick Armaflex through the seal, Max opening 800 x 600 mm	RIR FCO-3217C
Steel pipes with Armaflex	Wall	116 mm Plasterboard / Hollow Masonry	3M Fire Barrier Pillows 3M Moldable Putty MP+	-/120/30	Up to 34 mm diameter x 3.5 mm wall thickness, with 19 mm thick Armaflex through the seal, Max opening 800 x 600 mm	RIR FCO-3217C
Copper pipes with Armaflex	Wall	75 mm Concrete / Solid Masonry / Lightweight Concrete / Aerated Autoclaved Concrete (AAC)	3M Fire Barrier Pillows 3M Moldable Putty MP+	-/180/30	Up to 15 mm diameter x 0.91 mm wall thickness, with 19 mm thick Armaflex through the seal, Max opening 800 x 600 mm	RIR FCO-3217C
Steel pipes with Armaflex	Wall	75 mm Concrete / Solid Masonry / Lightweight Concrete / Aerated Autoclaved Concrete (AAC)	3M Fire Barrier Pillows 3M Moldable Putty MP+	-/180/30	Up to 34 mm diameter x 3.5 mm wall thickness, with 19 mm thick Armaflex through the seal, Max opening 800 x 600 mm	RIR FCO-3217C
NON-INSULATED COMBUSTIBLE PIPES						
UPVC Pipes	Floor	80 mm concrete	Tuck-In Wrap Strip , 3000WT Sealant	-/60/60	50- 160 mm diameter , annular gap 9-21 mm	BRANZ FC10453
UPVC Pipes	Floor	100 mm concrete	Tuck-In Wrap Strip , 3000WT Sealant	-/90/90	50- 160 mm diameter , annular gap 9-21 mm	BRANZ FC10453
UPVC Pipes	Floor	120 mm concrete	Tuck-In Wrap Strip , 3000WT Sealant	-/120/120	50- 160 mm diameter , annular gap 9-21 mm	BRANZ FC10453
UPVC Pipes	Floor	150 mm concrete	Tuck-In Wrap Strip , 3000WT Sealant	-/180/180	50- 160 mm diameter , annular gap 9-21 mm	BRANZ FC10453
UPVC Pipes	Wall	120 mm plasterboard or concrete	Tuck-In Wrap Strip , IC15WB Sealant	-/120/120	50 - 110 mm PVC-U pipes , 10 mm annular gap	BRANZ FC10453
PEX Pipes	Wall	103 mm Plasterboard	3M™ 3000 WT Watertight sealant	-/120/120	16 - 26 mm OD PE-X pipes , 10 mm annular gap	Exova 48815900.1
PEX Pipes	Wall	103 mm Concrete	3M™ 3000 WT Watertight sealant	-/120/120	16 - 26 mm OD PE-X pipes , 10 mm annular gap	Exova 48815900.1
SEISMIC/CONSTRUCTION JOINTS						
Perimeter Joints	Floor	120 mm Concrete Slab	3M™ Fire & Water Barrier tape , covering 96 kg.m-3 mineral wool	-/120/120	Maximum gap width 100 mm , mineral wool depth 100 mm	BRANZ FC12674-001-TO
Perimeter Joints	Floor	150 mm Concrete Slab	3M™ Fire & Water Barrier tape , covering 96 kg.m-3 mineral wool	-/180/180	Maximum gap width 100 mm , mineral wool depth 100 mm	BRANZ FC12674-001-TO

BOSS PASSIVE FIRE

Manufacturer Code: BP

c/- Potter Interior Systems	Ph:	0800 768 837
393 Church Street	Fax:	09 579 5661
Penrose Auckland NZ	Email:	info@potters.co.nz



The products listed in this register have all been tested to AS1530.4-2005 or Assessed to AS 4072.1-2005 as referenced within the New Zealand Building Code.

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
BLANK OPENING						
Blank or Empty Aperture	Wall	270mm Thick Wall Systems using AAC, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Pronto Panel, Supapanel, BOSS Batt, FR Plasterboard/GIB, BarrierLine, IntRwall, Shaftliner, Shaftwall.	BOSS FyreBox®	-/120/120	Up to 600mm Wide x 150mm High	Branz FTC 843
Blank or Empty Aperture	Wall / Floor	110mm Thick AAC, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, ProntoPanel, SupaPanel, BOSS Batt, FR Plasterboard/GIB, BarrierLine, IntRwall, Shaftliner, Shaftwall.	BOSS FyreBox®	-/120/90	Up to 600mm Wide x 150mm High	Branz FTC 843
Blank or Empty Aperture	Ceiling	FR Plasterboard/GIB	BOSS FR Downlight Cover - Mitt	-/120/90	Clear 90mm Aperture	CSIRO FSP 1290B
Blank or Empty Aperture	Wall / Floor	50mm Thick Concrete / Masonry	BOSS FireMortar-360	-/240/60	1200mm x 1200mm or 600mm x Any Length Apertures	Branz FTC 575
Blank or Empty Aperture	Wall / Floor	75mm Thick Concrete / Masonry	BOSS FireMortar-360	-/240/120	1200mm x 1200mm or 600mm x Any Length Apertures	Branz FTC 575
Blank or Empty Aperture	Wall / Floor	100mm Thick Concrete / Masonry	BOSS FireMortar-360	-/240/240	1200mm x 1200mm or 600mm x Any Length Apertures	Branz FTC 575
Blank or Empty Aperture	Wall / Floor	100mm Thick Concrete / Masonry	BOSS FireMortar-360	-/360/360	up to 720mm x 720mm Aperture.	Branz FTC 575
Blank or Empty Aperture	Floor	Min 150mm Thick Concrete	BOSS Batt - Single - Sealed with BOSS Ablative Coating	-/60/60	Up to 1600mm Long x 700mm Wide Aperture	Branz FAR 3921.2
Blank or Empty Aperture	Floor	Min 150mm Thick Concrete	BOSS Batt - Single - Sealed with BOSS Ablative Coating	-/60/60	200mm Gap x Unlimited Length	Branz FAR 3921.2
Blank or Empty Aperture	Floor	Min 150mm Thick Concrete	BOSS Batt - Double - Sealed with BOSS Ablative Coating	-/120/120	200mm Gap x Unlimited Length	Branz FAR 3921.2
Blank or Empty Aperture	Wall	FR Plasterboard/GIB / Concrete / Masonry	BOSS Batt - Single - Sealed with BOSS Ablative Coating	-/120/60	1200mm x 1200mm Aperture	Branz FTC 576
Blank or Empty Aperture	Wall	FR Plasterboard/GIB / Concrete / Masonry	BOSS Batt - Double - Sealed with BOSS Ablative Coating	-/120/90	1200mm x 2400mm Aperture	Branz FTC 576

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
BLANK OPENING						
Blank or Empty Aperture	Wall	FR Plasterboard/GIB / Concrete / Masonry	BOSS Batt - Double - Sealed with BOSS Ablative Coating	-/240/90	600mm x 1000mm Aperture	Branz FTC 576
Blank or Empty Aperture	Wall	FR Plasterboard/GIB / Concrete / Masonry	BOSS Batt - Double - Sealed with BOSS Ablative Coating	-/120/90	600mm x 600mm Aperture	Branz FTC 576
Blank or Empty Aperture	Wall / Floor	Concrete / Masonry	BOSS Abesco Cable Transit CT120 - Square	-/240/-	Apertures up to 204mm x 306mm	Branz FAR 2981
Blank or Empty Aperture	Wall / Floor	Concrete / Masonry	BOSS Abesco Cable Transit CT120 - Round	-/240/-	Apertures up to 150mm Dia.	Branz FAR 2981
Blank or Empty Aperture	Wall	FR Plasterboard/GIB	BOSS Abesco Cable Transit CT120 - Square	-/120/-	Apertures up to 204mm x 306mm	Branz FAR 2981
Blank or Empty Aperture	Wall	FR Plasterboard/GIB	BOSS Abesco Cable Transit CT120 - Round	-/120/-	Apertures up to 150mm Dia.	Branz FAR 2981
Blank or Empty Aperture	Wall	Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry / AAC Speedpanel, Korok, Hebel with with local build up to Min 100mm	BOSS PenoPatch™ 60mm	-/120/60	Apertures up to 25mm	Warringtonfire FAS 190100
Blank or Empty Aperture	Wall	Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry / AAC Speedpanel, Korok, Hebel with with local build up to Min 100mm	BOSS PenoPatch™ 100mm	-/60/60	Apertures up to 50mm	Warringtonfire FAS 190100
Blank or Empty Aperture	Wall / Floor	"Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry Speedpanel, Korok, or similar Or Permanent Polymer Formwork Const. 120mm Concrete Floor Slab"	BOSS Batt - Double - Sealed with BOSS FlexiCoat-MAK™ & FireMastic-300™	-/120/120	Up to 1100mm x 1100mm	Branz FTC 842
Blank or Empty Aperture	Wall / Floor	"Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry Speedpanel, Korok, or similar Or Permanent Polymer Formwork Const. 120mm Concrete Floor Slab"	BOSS FlexiBatt™ - Sealed with BOSS FlexiCoat-MAK™ & FireMastic-300™	-/120/120	Up to 1100mm x 1100mm	Branz FTC 842
Blank or Empty Aperture	Wall / Floor	"Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry Speedpanel, Korok, or similar Or Permanent Polymer Formwork Const. 120mm Concrete Floor Slab"	BOSS Batt - Double - Sealed with BOSS FlexiCoat-MAK™	"Up to -/240/180"	200mm Gap x Unlimited Length	Branz FTC 842
Blank or Empty Aperture	Wall / Floor	"Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry Speedpanel, Korok, or similar Or Permanent Polymer Formwork Const. 120mm Concrete Floor Slab"	BOSS FlexiBatt™ - Sealed with BOSS FlexiCoat-MAK™	"Up to -/240/180"	200mm Gap x Unlimited Length	Branz FTC 842

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
CONSTRUCTION JOINTS						
Control Joint	Wall	Minimum 120mm Thick Wall - FR Plasterboard/GIB, AAC, Masonry or Concrete	BOSS FireMastic-HPE™	-/120/120	10-20mm Wide Gap and 25mm Deep Seal	CSIRO FCO-2990B
Linear Gap Seals	Wall	250mm Thick Masonry	BOSS FireMastic-300™	-/300/300	Up to 20mm Wide Gap	Branz FAR 3821.4
Linear Gap Seals	Wall	250mm Thick Masonry	BOSS FireMastic-300™	-/300/180	Up to 50mm Wide Gap	Branz FAR 3821.4
Linear Gap Seals	Wall	250mm Thick Masonry / Mild Steel	BOSS FireMastic-300™	-/300/90	Up to 30mm Wide Gap	Branz FAR 3821.4
Linear Gap Seals	Floor	250mm Thick Masonry	BOSS FireMastic-300™	-/300/180	Up to 50mm Wide Gap	Branz FAR 3821.4
Linear Gap Seals	Wall	100mm Thick Masonry	BOSS FireMastic-300™	-/120/30	Up to 20mm Wide Gap	Branz FAR 3821.4
Linear Gap Seals	Floor	150mm Thick Masonry	BOSS FireMastic-300™	-/240/30	Up to 20mm Wide Gap	Branz FAR 3821.4
Linear Gap Seals	Wall	100mm Thick Masonry / Mild Steel	BOSS FireMastic-300™	-/120/60	Up to 50mm Wide Gap	Branz FAR 3821.4
Linear Gap Seals	Floor	150mm Thick Masonry / Timber	BOSS FireMastic-300™	-/240/90	Up to 50mm Wide Gap	Branz FAR 3821.4
System Joints	Wall	FR Plasterboard / GIB AAC / Hebel Speedpanel / Korok AFS Shaftliner Concrete Solid / Hollow Masonry Metal Clad AAC with an established FRL	BOSS FireMastic-300™	-/300/300	Gaps up to 10mm and Deflection Head Gaps up to 20mm	Branz FAR 3821.4
Linear Gap around Intumescent Dampers	Wall	Perimeter Seal around Intumescent Dampers	BOSS FireMastic-300™	-/300/300	Max 5mm Gap for face fixed damper	Branz FAR 3821.4
Linear Gap around Intumescent Dampers	Wall	Perimeter Seal around Intumescent Dampers	BOSS FireMastic-300™	-/300/300	Max 25mm Gap for in-line installation gap	Branz FAR 3821.4
System Joints	Wall	78mm Speedwall	BOSS FireSilicone-EMA	-/120/120	General system gaps, perimeter seal and tracks	EWFA 34923800.2
Expansion Joints	Wall	140mm Thick Autoclaved Aerated Concrete	BOSS FireStrip-ALX (FR Movement Strip)	-/240/240	50mm Expansion Joint	FAS 190039
Expansion Joints	Wall	140mm Thick Autoclaved Aerated Concrete	BOSS FireStrip-ALX (FR Movement Strip)	-/120/120	100mm Expansion Joint	FAS 190039
Expansion Joints	Floor	140mm Thick Autoclaved Aerated Concrete	BOSS FireStrip-ALX (FR Movement Strip)	-/240/180	50mm Expansion Joint	FAS 190039
Expansion Joints	Floor	140mm Thick Autoclaved Aerated Concrete	BOSS FireStrip-ALX (FR Movement Strip)	-/180/180	100mm Expansion Joint	FAS 190039

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
CONSTRUCTION JOINTS						
Linear Gap Seal	Floor	Min 150mm Thick Concrete	BOSS Batt - Double Layer - Sealed with BOSS Ablative Coating	-/120/120	200mm Gap x Unlimited Length	Branz FAR 3921.2
Linear Gap Seal	Wall / Floor	Hardwood Timber	BOSS FireMastic-300™	-/60/60	Up to 50mm Wide Gap	PFITS FAR190042 Issue 2
Linear Gap Seal	Wall / Floor	Hardwood Timber to FR Plasterboard Ceiling	BOSS FireMastic-300™	-/60/60	Up to 50mm Wide Gap	PFITS FAR190042 Issue 2
Linear Gap Seal	Wall / Ceiling	FR Plasterboard / GIB	BOSS FireMastic-300™	-/60/60	Up to 50mm Wide Gap	PFITS FAR190042 Issue 2
Linear Gap Seal	Floor	AAC - Minimum 670kg/m ³	BOSS FireMastic-300™	-/60/60	Up to 50mm Wide Gap	PFITS FAR190042 Issue 2
Door Frame Backfill	Wall	FR Plasterboard / GIB	BOSS Pyroguard Fire Foam	-/120/30	Door Frame Backfill	CSIRO COA 2277
Timber Penetration	Wall	FR Plasterboard / GIB	BOSS FireMastic-HPE™ with FBL-100 Intumescent Coating System	60/60/60	Timber Penetration - 4 Sided Penetration	PFITS PF19022
Timber Penetration	Wall	FR Plasterboard / GIB	BOSS FireMastic-HPE™ with FBL-100 Intumescent Coating System	60/60/60	Timber Penetration - with Combustible Substrate	PFITS PF19022
Timber Penetration	Wall	FR Plasterboard / GIB	BOSS FireMastic-HPE™ with FBL-100 Intumescent Coating System	60/60/60	Timber Penetration - with Non-Combustible Substrate	PFITS PF19022
Linear Gap Seals	Floor	150mm Thick Concrete / AAC	BOSS FireSilicone-EMA™	-/240/180	Up to 30mm Wide Gap - 15mm Deep - PE backing rod	WarringtonFire FAS 109037.2
Linear Gap Seals	Floor	150mm Thick Concrete / AAC	BOSS FireSilicone-EMA™	-/240/120	Up to 60mm Wide Gap - 30mm Deep - PE backing rod -Top of Slab Only	WarringtonFire FAS 109037.2
Linear Gap Seals	Floor	150mm Thick Concrete / AAC	BOSS FireSilicone-EMA™	-240/180	Up to 60mm Wide Gap - 5mm Deep - 50mm Stone Wool backing -Top of Slab Only	WarringtonFire FAS 109037.2
Linear Gap Seals	Wall	150mm Thick Concrete / Solid Masonry Block	BOSS FireSilicone-EMA™	-/300/300	Up to 30mm Wide Gap - 15mm Deep - PE backing rod -Both sides of wall	WarringtonFire FAS 109037.2
Linear Gap Seals	Wall	150mm Thick Concrete / Solid Masonry Block	BOSS FireSilicone-EMA™	-/240/180	Up to 50mm Wide Gap - 25mm Deep - PE backing rod -Both sides of wall	WarringtonFire FAS 109037.2
Linear Gap Seals	Wall	150mm Thick Concrete / Solid Masonry Block	BOSS FireSilicone-EMA™	-/240/240	Up to 60mm Wide Gap - 5mm Deep - 50mm Stone Wool backing -Both sides of wall	WarringtonFire FAS 109037.2

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
CONSTRUCTION JOINTS						
Linear Gap Seals	Wall	250mm Thick AAC / Timber	BOSS Pyroguard Fire Foam	-/180/180	15mm Gap	CSIRO FCO-3001 A
Linear Gap Seals	Wall	250mm Thick AAC	BOSS Pyroguard Fire Foam	-/240/240	15mm Gap	CSIRO FCO-3001 A
Linear Gap Seals	Wall	250mm Thick AAC	BOSS Pyroguard Fire Foam	-/240/240	50mm Gap with Mineral Rock Fibre	CSIRO FCO-3001 A
Linear Gap Seals	Floor	250mm Thick AAC	BOSS Pyroguard Fire Foam	-/180/180	50mm Gap with Mineral Rock Fibre	CSIRO FCO-3001 A
Linear Gap Seals	Floor	250mm Thick AAC	BOSS Pyroguard Fire Foam	-/60/60	35mm Gap	CSIRO FCO-3001 A
Linear Gap Seals	Floor	250mm Thick AAC	BOSS Pyroguard Fire Foam	-/90/90	25mm Gap	CSIRO FCO-3001 A
Linear Gap Seals	Floor	250mm Thick AAC	BOSS Pyroguard Fire Foam	-/180/180	15mm Gap	CSIRO FCO-3001 A
Blank or Empty Aperture	Wall / Floor	"Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry Speedpanel, Korok, or similar Or Permanent Polymer Formwork Const. 120mm Concrete Floor Slab"	BOSS Batt - Double - Sealed with BOSS FlexiCoat-MAK	"Up to -/240/180"	200mm Gap x Unlimited Length	Branz FTC 842
Blank or Empty Aperture	Wall / Floor	"Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry Speedpanel, Korok, or similar Or Permanent Polymer Formwork Const. 120mm Concrete Floor Slab"	BOSS FlexiBatt - Sealed with BOSS FlexiCoat-MAK	"Up to -/240/180"	200mm Gap x Unlimited Length	Branz FTC 842
ELECTRICAL PENETRATION SERVICES – Data & Comms Cables:						
Data / Comms Cable Bundles	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox® with BOSS P40-MAK Thermal Wrap	-/120/120	"Appx D2 Cables Approx 14mm dia ea: Including - CAT5, CAT5E, CAT6, COAX, MATV, Fire Alarm, EWIS, NBN / Fibre optic cables. - Any quantity of cables"	Branz FTC 843
Data / Comms Cable Bundles	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox® (no thermal wrap required)	-/120/90	"Appx D2 Cables Approx 14mm dia ea: Including - CAT5, CAT5E, CAT6, COAX, MATV, Fire Alarm, EWIS, NBN / Fibre optic cables. - Any quantity of cables"	Branz FTC 843
Comms Cable Bundle + Cable Tray	Wall	96mm Thick - FR Plasterboard/GIB	BOSS FireMastic-300™ with BOSS P40-MAK Thermal Wrap	-/90/90	D2 Configuration - Bundle 60 Cables - Approx 14mm Dia. Ea.	CSIRO COT 2970
Cables	Wall / Floor	50mm Thick Concrete / Masonry	BOSS FireMortar-360	-/240/30	1200mm x 1200mm or 600mm x Any Length Apertures	Branz FTC 575
Cables	Wall / Floor	100mm Thick Concrete / Masonry	BOSS FireMortar-360	-/240/60	1200mm x 1200mm or 600mm x Any Length Apertures	Branz FTC 575
Comms Cable Bundle + Cable Tray	Wall	78mm Speedwall	BOSS Batt - Double Layer - Sealed with BOSS Ablative Coating and BOSS P40-MAK Wrap	-/120/120	300mm x 250mm Aperture. Bunch of 60 x 15mm OD Comms Cables mounted on a 180mm Cable Tray.	CSIRO COT 2823

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
ELECTRICAL PENETRATION SERVICES – Data & Comms Cables:						
Comms Cable Bundle + Cable Tray	Wall	78mm Speedwall	BOSS Batt - Double Layer - Sealed with BOSS Ablative Coating	-/120/90	160mm x 150mm Aperture: Appx D2 Data Cable Configuration	EWFA 33090200.1
Comms / Data Cable Bundles	Wall / Floor	Concrete / Masonry	BOSS Abesco Cable Transit CT120 - Square	-/240/-	CAT5e, CAT6 & RG6 Cables in apertures up to 204mm x 306mm	Branz FAR 2981
Comms / Data Cable Bundles	Wall / Floor	Concrete / Masonry	BOSS Abesco Cable Transit CT120 - Round	-/240/-	CAT5e, CAT6 & RG6 Cables in apertures up to 150mm dia.	Branz FAR 2981
Comms / Data Cable Bundles	Wall	FR Plasterboard/GIB	BOSS Abesco Cable Transit CT120 - Square	-/120/-	CAT5e, CAT6 & RG6 Cables in apertures up to 204mm x 306mm	Branz FAR 2981
Comms / Data Cable Bundles	Wall	FR Plasterboard/GIB	BOSS Abesco Cable Transit CT120 - Round	-/120/-	CAT5e, CAT6 & RG6 Cables in apertures up to 150mm dia.	Branz FAR 2981
Comms / Data Cable Bundles / Cable Tray	Floor	120mm Thick Concrete	BOSS Abesco Cable Transit CT240 - Rectangle	-/240/60	500mm Wide Cable Tray 2 x Bundles of 25 RG6 Coax Cable (50 in Total) 20 x Bundles of 25 CAT5E Cables (500 in Total)	Branz FR 3981
Comms / Data Cable Bundles / Cable Tray	Wall	130mm Thick FR Plasterboard/GIB / MaxiLite or Calcium Silicate Board	BOSS Abesco Cable Transit CT240 - Rectangle	-/120/30	300mm Wide Cable Tray 5 x Bundle of 50 CAT5E Cables (250 Total)	Branz FR 3982
Comms / Data Cable Bundles / Cable Tray	Wall	130mm Thick FR Plasterboard/GIB	BOSS Abesco Cable Transit CT240 - Rectangle	-/120/60	500mm Wide Cable Tray 1 x Bundles of 50 RG6 Coax Cable (50 in Total) 20 x Bundles of 25 CAT5E Cables (500 in Total)	Branz FR 3982
CAT6 Data Cable Bundle	Wall	75mm Thick Hebel / AAC	BOSS FireMastic-HPE™	-/120/60	Bundle of 38 CAT6 Data Cables - Bundle Dia approx 50mm	SFC FRT180473a.1
CAT6 Data Cable Bundles	Wall	118mm Thick - 13mm FR Plasterboard/GIB	BOSS PenoPatch™ 60mm	-/60/30	Bundle of 5 x CAT6 Cables. 20mm Aperture	WarringtonFire FAS 190100
CAT6 Data Cable Bundles	Wall	118mm Thick - 13mm FR Plasterboard/GIB	BOSS PenoPatch™ 60mm	-/60/60	Bundle of 3 x CAT6 Cables. 20mm Aperture	WarringtonFire FAS 190100
CAT6 Data Cable Bundles	Ceiling	FR Plasterboard/GIB Ceiling	BOSS FireMastic-300™ with Fire Spring	-/90/90	Bundle of 7 x CAT6 Cables. 44mm Aperture	SFC FRT180474.2
25mm Conduit	Ceiling	FR Plasterboard/GIB Ceiling	BOSS FireMastic-HPE™	-/90/90	25mm uPVC Conduit	SFC FRT180474.2
Comms Cable Bundles	Wall	CLT - Cross Laminate Timber	BOSS FireMastic-300™	-/90/90	3 x CAT6 Cables	EWFA 54783400.1
Data / Comms Cable Bundles	Wall	Min 140mm Concrete Block Wall	BOSS FirePillows-240 & BOSS FireMastic-300™ with BOSS P40-MAK Wrap	-/180/120	Appendix D2 Configuration Cables	FAS190042
Data / Comms Cable Bundles	Floor	Min 150mm Concrete Slab	BOSS FirePillows-240 & BOSS FireMastic-300™ with BOSS P40-MAK Wrap	-/180/120	Appendix D2 Configuration Cables	FAS190042
Data / Comms Cable Bundles	Wall / Floor	"Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry Speedpanel, Korok, or similar Or Permanent Polymer Formwork Const. 120mm Concrete Floor Slab"	BOSS Batt - Double - Sealed with BOSS FlexiCoat-MAK with FireMastic-300 & P40-MAK Wrap	-/120/120	Appendix D2 Configuration Cables	Branz FTC 842

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
ELECTRICAL PENETRATION SERVICES – Data & Comms Cables:						
Data / Comms Cable Bundles	Wall / Floor	"Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry Speedpanel, Korok, or similar Or Permanent Polymer Formwork Const. 120mm Concrete Floor Slab"	BOSS FlexiBatt - Sealed with BOSS FlexiCoat-MAK with FireMastic-300 & P40-MAK Wrap	-/120/120	Appendix D2 Configuration Cables	Branz FTC 842
HFC / NBN / Optical / Glass Fibre Optic Cable	Wall	90mm Thick FR Plasterboard/GIB	BOSS FireMastic-HPE™ - 20x20mm fillet required only on 1 side of the wall (either side)	-/60/60	Single Core Fibre Optical Cable - 5mm Diameter	CSIRO COT 2921
Fire Alarm System Cable Bundle	Wall	116mm Thick FR Plasterboard	BOSS FireMastic-HPE™	-/120/120	Bundle of 8 Fire Alarm Cables - 2C X 1.5mm ² - Approx Dia ea 10.3mm	SFC FRT180472b.1
ELECTRICAL PENETRATION SERVICES – Power Cables:						
Power Cable Bundles	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox® with BOSS P40-MAK Thermal Wrap	-/120/120	Appx D1 Configuration Cables - Multi-Core up to Cross Section <630mm ² - (500mm ² and smaller). Any quantity of cables	Branz FTC 843
Power Cable Bundles	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox®	-/120/60	Appx D1 Configuration Cables - Multi-Core up to Cross Section <630mm ² - (500mm ² and smaller). Any quantity of cables	Branz FTC 843
Power Cable Bundles	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox® with BOSS P40-MAK Thermal Wrap	-/120/120	Power Cables - 2C+E up to 16mm ² . Any quantity of cables	Branz FTC 843
Power Cable Bundles	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox®	-/120/90	Power Cables - 2C+E up to 16mm ² . Any quantity of cables	Branz FTC 843
Power Cable Bundles	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS Fire® Transit Box with BOSS P40-MAK Thermal Wrap	-/120/120	Cables with Aluminium Core 185mm ² or less	Branz FTC 843

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
ELECTRICAL PENETRATION SERVICES – Power Cables:						
Power Cable Bundles	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS Fire® Transit Box (no thermal wrap required)	-/120/30	Cables with Aluminium Core 185mm ² or less	Branz FTC 843
Power Cable Bundles	Wall	90mm Thick FR Plasterboard/GIB	BOSS FireMastic-HPE™	-/60/60	Bundle of 8 x 2.5mm ² , 3 Core TPS Cables	CSIRO COT 2922
Power Cable Bundles	Wall	144mm Thick FR Plasterboard/GIB	BOSS FireMastic-300™	-/120/120	Bundle of 7 x 2.5mm ² , 12mm x 5.6mm 3-Core TPS Cables	FRT 180403i.1
Power Cable Bundles	Wall	Min 120mm Thick - FR Plasterboard/GIB, AAC, Masonry or Concrete	BOSS FireMastic-HPE™	-/120/120	Up to 10 Cables PVC/PVC, EPR/PO, XLPE/EVA 5mm x 1.5mm ²	CSIRO FCO-2990B
Power Cable Bundles	Wall	Min 120mm Thick - FR Plasterboard/GIB, AAC, Masonry or Concrete	BOSS FireMastic-HPE™	-/120/120	Up to 2 Cables PVC/PVC 1mm x 95mm ² mains cable	CSIRO FCO-2990B
Power Cable	Wall	96mm Thick FR Plasterboard/GIB	BOSS FireMastic-300™	-/90/90	Single TPS Cable 2Core+E 2.5mm ²	CSIRO COT 2969
Power Cable Bundle + Cable Tray	Wall	96mm Thick FR Plasterboard/GIB	BOSS FireMastic -300 with BOSS P40-MAK Wrap	-/90/90	Bundle 3 x 3C+E 6mm ²	CSIRO COT 2972
Power Cable Bundle + Cable Tray	Wall	96mm Thick FR Plasterboard/GIB	BOSS FireMastic-300™ with BOSS P40-MAK Wrap	-/90/90	Bundle 8 x 3C+E 16mm ²	CSIRO COT 2972
Cables	Wall / Floor	50mm Thick Concrete / Masonry	BOSS FireMortar-360	-/240/30	1200mm x 1200mm or 600mm x Any Length Apertures	Branz FTC 575
Cables	Wall / Floor	100mm Thick Concrete / Masonry	BOSS FireMortar-360	-/240/60	1200mm x 1200mm or 600mm x Any Length Apertures	Branz FTC 575
Power Cable Bundles + Cable Tray	Wall	78mm Speedwall / Korok	BOSS Batt - Double Layer - Sealed with BOSS Ablative Coating and BOSS P40-MAK Thermal Wrap	-/120/120	"600mm x 200mm Aperture on (up to) 470mm Wide Cable Tray including: All Appx D1 Configuration Cables up to 630mm ² cross sectional area."	CSIRO COT 2822
Power Cable Bundles + Cable Tray	Wall	78mm Speedwall / Korok	BOSS Batt - Double Layer - Sealed with BOSS Ablative Coating	-/120/30	"575mm x 175mm Aperture including: All Appx D1 Configuration Cables up to 630mm ² cross sectional dia."	EWFA 33090200.1
Power Cables + Cable Tray	Wall	FR Plasterboard/GIB / Concrete / Masonry	BOSS Batt - Single Layer - Sealed with BOSS Ablative Coating	-/120/30	Up to 1200mm Wide x 2400mm Aperture. 3Core or 4Core Cables up to 30mm OD.	Branz FTC 576
Power Cables + Cable Tray	Wall	FR Plasterboard/GIB / Concrete / Masonry	BOSS Batt - Single Layer - Sealed with BOSS Ablative Coating	-/120/60	Up to 1200mm Wide x 2400mm Aperture. 3Core or 4Core Cables up to 20mm OD.	Branz FTC 576
Power Cables + Cable Tray	Wall	FR Plasterboard/GIB / Concrete / Masonry	BOSS Batt - Single Layer - Sealed with BOSS Ablative Coating	-/240/60	Up to 600mm Wide x 1000mm Aperture. 3Core or 4Core Cables up to 20mm.	Branz FTC 576
Power Cables + Cable Tray	Floor	FR Plasterboard/GIB / Concrete / Masonry	BOSS Batt - Single Layer - Sealed with BOSS Ablative Coating	-/120/30	Up to 600mm Wide x 600mm Aperture. 3Core or 4Core Cables up to 30mm OD.	Branz FTC 576
Power Cables + Cable Tray	Floor	FR Plasterboard/GIB / Concrete / Masonry	BOSS Batt - Single Layer - Sealed with BOSS Ablative Coating	-/120/60	Up to 600mm Wide x 600mm Aperture. 3Core or 4Core Cable up to 20mm OD.	Branz FTC 576

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
ELECTRICAL PENETRATION SERVICES – Power Cables:						
Power Cable Bundles	Wall / Floor	Concrete / Masonry	BOSS Abesco Cable Transit CT120 - Square	-/240/-	Any Appx D1 Configuration Cables up to cross section 630mm ² in apertures up to 204mm x 306mm	Branz FAR 2981
Power Cable Bundles	Wall / Floor	Concrete / Masonry	BOSS Cable Transit CT120 - Round	-/240/-	Any Appx D1 Configuration Cables up to cross section 630mm ² in apertures up to 150mm Dia.	Branz FAR 2981
Power Cable Bundles	Wall	FR Plasterboard/GIB	BOSS Abesco Cable Transit CT120 - Square	-/120/-	Any Appx D1 Configuration Cables up to cross section 630mm ² in apertures up to 204mm x 306mm	Branz FAR 2981
Power Cable Bundles	Wall	FR Plasterboard/GIB	BOSS Cable Transit CT120 - Round	-/120/-	Any Appx D1 Configuration Cables up to cross section 630mm ² in apertures up to 150mm Dia.	Branz FAR 2981
Power Cable Bundle	Floor	Comflor® 60 - 130mm Thick	BOSS FireMastic-HPE™ seal around cables, with a patress of BOSS Batt Sealed with BOSS Ablative Coating	-/120/120	Bundle of 22 x TPS Cables - 2C+E 2.5mm ²	SFC FRT180137b.2
Power Cable Bundle	Wall	75mm Thick Hebel / AAC	BOSS FireMastic-HPE™	-/120/60	Bundle of 22 x TPS Cables - 2C+E 2.5mm ²	SFC FRT180473a.1
Power Cable Bundle	Wall	75mm Thick Hebel / AAC	BOSS Abesco Cable Transit CT120 mounted in BOSS Batt (sealed with BOSS Ablative Coating and BOSS FireMastic-300™)	-/120/30	Bundle of Aluminium Cables: - 2 x Aluminum Cable 70mm ² - 2 x Aluminium Cable 120mm ² - 2 x Aluminium Cable 185mm ² - 2 x Aluminium Cable 240mm ²	SFC FRT180473b.2
Power Cable Bundle	Wall	118mm Thick FR Plasterboard/GIB	BOSS PenoPatch™ 60mm	-/60/60	Bundle of 3 x 2Core+E 2.5mm ² TPS Cables	WarringtonFire FAS 190100
Power Cable	Wall	Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry / AAC Speedpanel, Korok, Hebel with with local build up to Min 100mm	BOSS PenoPatch™ 60mm	-/60/60	Single PVC / PVC Sheathed 5mm x 1.5mm ²	WarringtonFire FAS 190100
Power Cable	Wall	Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry / AAC Speedpanel, Korok, Hebel with with local build up to Min 100mm	BOSS PenoPatch™ 60mm	-/60/60	Single EPR / PO Sheathed 5mm x 1.5mm ²	WarringtonFire FAS 190100
Power Cable	Wall	Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry / AAC Speedpanel, Korok, Hebel with with local build up to Min 100mm	BOSS PenoPatch™ 60mm	-/120/60	Single XLPE / EVA Sheathed 5mm x 1.5mm ²	WarringtonFire FAS 190100
Power Cable	Wall	Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry / AAC Speedpanel, Korok, Hebel with with local build up to Min 100mm	BOSS PenoPatch™ 60mm	-/120/60	Single PVC / PVC Sheathed 1mm x 95mm ²	WarringtonFire FAS 190100
Power Cable	Wall	Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry / AAC Speedpanel, Korok, Hebel with with local build up to Min 100mm	BOSS PenoPatch™ 60mm	-/120/60	Single PVC / PVC Sheathed 1mm x 185mm ²	WarringtonFire FAS 190100

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
ELECTRICAL PENETRATION SERVICES – Power Cables:						
Power Cable Bundle	Wall	Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry / AAC Speedpanel, Korok, Hebel with with local build up to Min 100mm	BOSS PenoPatch™ 100mm	-/60/60	Bundle of 3 PVC /PVC Sheathed 5mm x 1.5mm ²	WarringtonFire FAS 190100
Power Cable Bundle	Wall	Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry / AAC Speedpanel, Korok, Hebel with with local build up to Min 100mm	BOSS PenoPatch™ 100mm	-/60/60	Bundle of 3 EPR /PO Sheathed 5mm x 1.5mm ²	WarringtonFire FAS 190100
Power Cable Bundle	Wall	Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry / AAC Speedpanel, Korok, Hebel with with local build up to Min 100mm	BOSS PenoPatch™ 100mm	-/60/60	Bundle of 3 XLPE /EVA Sheathed 5mm x 1.5mm ²	WarringtonFire FAS 190100
Power Cable	Wall	Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry / AAC Speedpanel, Korok, Hebel with with local build up to Min 100mm	BOSS PenoPatch™ 100mm	-/30/30	Single PVC / PVC Sheathed 1mm x 185mm ²	WarringtonFire FAS 190100
Power Cable Bundle	Ceiling	FR Plasterboard/GIB Ceiling	BOSS FireMastic-300™	-/90/90	2 x TPS Cable (2C+E) 2.5mm ²	SFC FRT180474.2
Power Cable Bundle	Ceiling	FR Plasterboard/GIB Ceiling	BOSS FireMastic-HPE™	-/90/90	4 x TPS Cable (2C+E) 2.5mm ²	SFC FRT180474.2
Power Cable Bundle	Ceiling	FR Plasterboard/GIB Ceiling	BOSS FireMastic-HPE™	-/90/90	3 x Mains Power Cables (2C+E)	SFC FRT180474.2
25mm Conduit	Ceiling	FR Plasterboard/GIB Ceiling	BOSS FireMastic-HPE™	-/90/90	25mm uPVC Conduit	SFC FRT180474.2
Conduit Bundle	Ceiling	FR Plasterboard/GIB Ceiling	BOSS MaxiCollar™ + BOSS FireMastic-HPE™ Infill	-/90/90	2 x 25mm uPVC Conduits (with TPS Cable in conduit)	SFC FRT180474.2
Power Cable Bundles	Wall	CLT - Cross Laminate Timber	BOSS FireMastic-300™	-/90/90	5 x TPS Cables (2Core+E 2.5mm ²)	EWFA 547834001
Power Cable Bundles	Wall	Min 140mm Concrete Block Wall	BOSS FirePillows-240 & BOSS FireMastic-300™ with BOSS P40-MAK Wrap	-/180/120	Appendix D1 Configuration Cables	FAS190042
Power Cable Bundles	Floor	Min 150mm Concrete Slab	BOSS FirePillows-240 & BOSS FireMastic-300™ with BOSS P40-MAK Wrap	-/180/120	Appendix D1 Configuration Cables	FAS190042
Power Cable Bundles	Wall / Floor	"Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry Speedpanel, Korok, or similar Or Permanent Polymer Formwork Const. 120mm Concrete Floor Slab"	BOSS Batt - Double - Sealed with BOSS FlexiCoat-MAK with FireMastic-300 & P40- MAK Wrap	-/120/120	Appendix D1 Configuration Cables	Branz FTC 842

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
ELECTRICAL PENETRATION SERVICES – Power Cables:						
Power Cable Bundles	Wall / Floor	"Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry Speedpanel, Korok, or similar Or Permanent Polymer Formwork Const. 120mm Concrete Floor Slab"	BOSS FlexiBatt - Sealed with BOSS FlexiCoat-MAK with FireMastic-300 & P40-MAK Wrap	-/120/120	Appendix D1 Configuration Cables	Branz FTC 842
ELECTRICAL PENETRATION SERVICES – Other Electrical Penetrations:						
Downlight	Ceiling	FR Plasterboard/GIB Ceiling	BOSS FR Downlight Cover - Mitt	-/120/90	90mm Aperture	CSIRO FSP 1290B
Downlight	Ceiling	FR Plasterboard/GIB Ceiling	BOSS FR Downlight Cover - Ventilated	-/120/60	105mm Aperture	CSIRO FSP 1290B
Cable Trays	Wall / Floor	50mm Thick Concrete / Masonry	BOSS FireMortar-360	-/240/30	1200mm x 1200mm or 600mm x Any Length Apertures	Branz FTC 575
Cable Trays	Wall / Floor	100mm Thick Concrete / Masonry	BOSS FireMortar-360	-/240/60	1200mm x 1200mm or 600mm x Any Length Apertures	Branz FTC 575
Cable Trays	Wall	FR Plasterboard/GIB / Concrete / Masonry	BOSS Batt - Single Layer - Sealed with BOSS Ablative Coating	-/120/30	Up to 1200mm x 2400mm Aperture	Branz FTC 576
Cable Trays	Wall	FR Plasterboard/GIB / Concrete / Masonry	BOSS Batt - Double Layer - Sealed with BOSS Ablative Coating	-/240/60	Up to 600mm x 1000mm Aperture	Branz FTC 576
Cable Trays	Floor	FR Plasterboard/GIB / Concrete / Masonry	BOSS Batt - Double Layer - Sealed with BOSS Ablative Coating	-/120/30	Up to 600mm x 600mm Aperture	Branz FTC 576
Cable Trays	Floor	FR Plasterboard/GIB / Concrete / Masonry	BOSS Batt - Double Layer - Sealed with BOSS Ablative Coating	-/120/60	Up to 600mm x 600mm Aperture	Branz FTC 576
NON-INSULATED NON-COMBUSTIBLE PIPES						
Galvanised Steel Pipe Bundles	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox® with BOSS P40-MAK Wrap	-/120/120	Up to 60.3mm OD Pipes. Any quantity of pipes.	Branz FTC 843
Galvanised Steel Pipe Bundles	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox® (no thermal wrap required)	-/120/120	Up to 60.3mm OD Pipes. Any quantity of pipes.	Branz FTC 843

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
NON-INSULATED NON-COMBUSTIBLE PIPES						
Copper Pipe Bundles	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, InTRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox® with BOSS P40-MAK Wrap	-/120/120	Up to 50.8mm OD Pipes. Any quantity of pipes.	Branz FTC 843
Copper Pipe Bundles	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, InTRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox® (no thermal wrap required)	-/120/-	Up to 50.8mm OD Pipes. Any quantity of pipes.	Branz FTC 843
Galvanised Steel Pipe	Wall	144mm Thick - FR Plasterboard/GIB	BOSS FireMastic-300™	-/120/120	34mm OD Pipe	FRT 180403i.1
Copper Pipe	Wall	Min 120mm Thick - FR Plasterboard/GIB, AAC, Masonary or Concrete	BOSS FireMastic-HPE™	-/120/-	15-60mm OD Pipe	CSIRO FCO-2990B
Copper Pipe	Wall	96mm Thick FR Plasterboard/GIB	BOSS FireMastic-300™ with BOSS P40-MAK Wrap	-/90/90	19mm OD Pipe (Appx E pipes)	CSIRO COT 2968
Copper Pipe	Wall	96mm Thick FR Plasterboard/GIB	BOSS FireMastic-300™ with BOSS P40-MAK Wrap	-/90/90	150mm OD Pipe (Appx E pipes)	CSIRO COT 2971
Copper Pipe	Wall	96mm Thick FR Plasterboard/GIB	BOSS FireMastic-300™ with BOSS P40-MAK Wrap	-/90/90	32mm OD Pipe (Appx E pipes)	CSIRO COT 2973
Steel Pipes	Wall / Floor	50mm Thick Concrete / Masonry	BOSS FireMortar-360	-/240/-	1200mm x 1200mm or 600mm x Any Length Apertures	Branz FTC 575
Steel Pipe	Wall	FR Plasterboard/GIB / Concrete / Masonry	BOSS Batt - Single Layer - Sealed with BOSS Ablative Coating	-/120/-	Up to 1200mm x 2400mm Aperture. Up to 60mm OD Pipe	Branz FTC 576
Steel Pipe	Wall	FR Plasterboard/GIB / Concrete / Masonry	BOSS Batt - Double Layer - Sealed with BOSS Ablative Coating	-/120/30	Up to 1200mm x 2400mm Aperture. Up to 60mm OD Pipe	Branz FTC 576
Steel Pipe	Floor	FR Plasterboard/GIB / Concrete / Masonry	BOSS Batt - Double Layer- Sealed with BOSS Ablative Coating	-/120/30	Up to 600mm x 600mm Aperture. Up to 60mm OD Pipe	Branz FTC 576
Copper Pipe 32mm	Floor	Comflor® 60 - 130mm Thick	BOSS FireMastic-300™	-/120/30	32mm OD Pipe	SFC FRT180137d.2
Copper Pipe 150mm	Wall	116mm Thick FR Plasterboard	BOSS FireMastic-300™	-/120/-	152mm OD Pipe	SFC FRT180472a.1
Galvanised Steel Pipe 60mm	Wall	116mm Thick FR Plasterboard	BOSS FireMastic-300™	-/120/120	60.5mm OD Pipe	SFC FRT180472a.1
Galvanised Steel Pipe 60mm	Wall	75mm Thick Hebel / AAC	BOSS FireMastic-300™	-/120/90	60.3mm OD Pipe	SFC FRT180473a.1

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
NON-INSULATED NON-COMBUSTIBLE PIPES						
Steel / Copper Pipe 16mm	Wall	Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry / AAC Speedpanel, Korok, Hebel with with local build up to Min 100mm	BOSS PenoPatch™ 60mm	-/120/-	16mm OD Pipe - 25mm Aperture	WarringtonFire FAS 190100
Steel / Copper Pipe 16mm	Wall	Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry / AAC Speedpanel, Korok, Hebel with with local build up to Min 100mm	BOSS PenoPatch™ 100mm	-/60/-	16mm OD Pipe - 50mm Aperture	WarringtonFire FAS 190100
Galvanised Steel Pipe 42mm	Ceiling	FR Plasterboard/GIB Ceiling	BOSS Thermal Defence Wrap, BOSS UniWrap & FireMastic-300™	-/90/90	42.8mm OD Pipe	SFC FRT180474.2
Copper Pipe 100mm	Wall	Min 140mm Concrete Block Wall	BOSS FirePillows-240 & BOSS FireMastic-300™ with BOSS P40-MAK Wrap	-/180/120	100mm OD Pipe	FAS190042
Copper Pipe 100mm	Floor	Min 150mm Concrete Slab	BOSS FirePillows-240 & BOSS FireMastic-300™ with BOSS P40-MAK Wrap	-/180/120	100mm OD Pipe	FAS190042
Steel Pipes up to 220mm	Wall / Floor	"Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry Speedpanel, Korok, or similar Or Permanent Polymer Formwork Const. 120mm Concrete Floor Slab"	BOSS Batt - Double - Sealed with BOSS FlexiCoat-MAK with FireMastic-300 & P40- MAK Wrap	-/90/30	Pipes up to 220mm	Branz FTC 842
Steel Pipes up to 220mm	Wall / Floor	"Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry Speedpanel, Korok, or similar Or Permanent Polymer Formwork Const. 120mm Concrete Floor Slab"	BOSS FlexiBatt - Sealed with BOSS FlexiCoat- MAK with FireMastic-300 & P40-MAK Wrap	-/90/30	Pipes up to 220mm	Branz FTC 842
Steel Pipes up to 60mm	Wall / Floor	"Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry Speedpanel, Korok, or similar Or Permanent Polymer Formwork Const. 120mm Concrete Floor Slab"	BOSS Batt - Double - Sealed with BOSS FlexiCoat-MAK with FireMastic-300 & P40- MAK Wrap	-/120/120	Pipes up to 60mm	Branz FTC 842
Steel Pipes up to 60mm	Wall / Floor	"Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry Speedpanel, Korok, or similar Or Permanent Polymer Formwork Const. 120mm Concrete Floor Slab"	BOSS FlexiBatt - Sealed with BOSS FlexiCoat- MAK with FireMastic-300 & P40-MAK Wrap	-/120/120	Pipes up to 60mm	Branz FTC 842
Steel & Copper Pipes up to 42mm	Wall / Floor	"Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry Speedpanel, Korok, or similar Or Permanent Polymer Formwork Const. 120mm Concrete Floor Slab"	BOSS Batt - Double - Sealed with BOSS FlexiCoat-MAK with FireMastic-300 & P40- MAK Wrap	-/120/120	Pipes up to 42mm	Branz FTC 842

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
NON-INSULATED NON-COMBUSTIBLE PIPES						
Steel & Copper Pipes up to 42mm	Wall / Floor	"Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry Speedpanel, Korok, or similar Or Permanent Polymer Formwork Const. 120mm Concrete Floor Slab"	BOSS FlexiBatt - Sealed with BOSS FlexiCoat-MAK with FireMastic-300 & P40-MAK Wrap	-/120/120	Pipes up to 42mm	Branz FTC 842
Steel & Copper Pipes up to 150mm	Wall / Floor	"Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry Speedpanel, Korok, or similar Or Permanent Polymer Formwork Const. 120mm Concrete Floor Slab"	BOSS Batt - Double - Sealed with BOSS FlexiCoat-MAK with FireMastic-300 & 2 x P40-MAK Wrap - 600mm Wide	-/120/90	Pipes up to 150mm	Branz FTC 842
Steel & Copper Pipes up to 150mm	Wall / Floor	"Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry Speedpanel, Korok, or similar Or Permanent Polymer Formwork Const. 120mm Concrete Floor Slab"	BOSS FlexiBatt - Sealed with BOSS FlexiCoat-MAK with FireMastic-300 & 2 x P40-MAK Wrap - 600mm Wide	-/120/90	Pipes up to 150mm	Branz FTC 842
INSULATED NON-COMBUSTIBLE PIPES – HVAC+R pipes						
Paircoil Bundles	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox® with BOSS P40-MAK Wrap	-/120/120	Up to 13mm/19mm dia lagged Copper Pipes - Any quantity of paircoil.	Branz FTC 843
Paircoil Bundles	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox®	-/120/90	Up to 13mm/19mm dia lagged Copper Pipes - Any quantity of paircoil.	Branz FTC 843
Insulated Copper Pipe Bundles	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox® with BOSS P40-MAK Wrap	-/120/120	Up to 50.8mm OD Pipe with insulation. Any quantity of pipes.	Branz FTC 843

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES – HVAC+R pipes						
Insulated Copper Pipe Bundles	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox®	-/120/60	Up to 50.8mm OD Pipe with insulation. Any quantity of pipes.	Branz FTC 843
Insulated Copper Pipe Bundles	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox®	-/120/120	Up to 32mm OD Pipe with insulation. Any quantity of pipes.	Branz FTC 843
Paircoil / uPVC Drain / Cable Bundle	Wall	90mm Thick - 13mm FR Plasterboard/GIB	BOSS FireMastic-HPE™ - applied to one side of wall only	-/60/60	6.35mm/9.52mm Insulated Copper Pipes with lagging, 1.5mm ² 2C+E TPS Power Cable, 16mm PVC flexible outlet pipe, coming out of wall cavity.	CSIRO COT2918
Paircoil / Power Cable / Control Cable Bundle	Wall	90mm Thick - 13mm FR Plasterboard/GIB + FR Plasterboard/GIB Patress™	BOSS FireMastic-300™ to patress edges. BOSS FireMastic-HPE™	-/60/60	10mm/15mm Insulated Copper Pipes, 2.5mm ² 2Core+E TPS Power Cable, 1.5mm ² 2C Data Cable and 20mm uPVC outlet pipe	CSIRO COT2919
Paircoil / Power Cable / Control Cable Bundle	Wall	90mm Thick FR Plasterboard/GIB	BOSS MaxiCollar™ / BOSS FireMastic-HPE™	-/60/60	10mm/15mm Insulated Copper Pipes, 2.5mm ² 2Core+E TPS Power Cable, 1.5mm ² 2C Data Cable	CSIRO COT 2920
Paircoil / Power Cable / Data Cable / PVC Pipe Bundle	Wall	Min 116mm FR Plasterboard/GIB, Min 75mm Thick Rigid Walls incl Concrete, Speedwall, Hebel, Reinforced AAC, Solid or Hollow Masonry	BOSS FireMastic-HPE™	-/120/120	Maximum 125mm Aperture with Paircoil 16mm OD and 10mm OD insulated, 2.5mm ² 2Core+E TPS cable, 1mm ² 2C Data Cable and up to 20mm OD PVC Pipe	WF 49599300.7
Paircoil / Power Cable / Data Cable / PVC Pipe Bundle	Wall	Min 75mm Thick Rigid Walls such as Concrete, Speedwall, Hebel, Reinforced AAC, Solid or Hollow Masonry	BOSS FireMastic-HPE™	-/90/90 -/60/60	Maximum 125mm Aperture with Paircoil 16mm OD and 10mm OD insulated, 2.5mm ² 2Core+E TPS cable, 1mm ² 2C Data Cable and up to 20mm OD PVC Pipe	WF 49599300.7
Paircoil / Power Cable / Data Cable / PVC Pipe Bundle	Wall	Min 116mm FR Plasterboard/GIB, Min 75mm Thick Rigid Walls incl Concrete, Speedwall, Hebel, Reinforced AAC, Solid or Hollow Masonry	BOSS FireMastic-HPE™	-/120/120	Maximum 125mm Aperture with 2.5mm ² 2Core+E TPS cable, 1mm ² 2Core Data Cable and up to 20mm OD PVC Pipe, 3 x (up to) 20mm insulated copper pipes	WF 49599300.7
Paircoil / Power Cable / Data Cable / PVC Pipe Bundle	Wall	Min 75mm Thick Rigid Walls such as Concrete, Speedwall, Hebel, Reinforced AAC, Solid or Hollow Masonry	BOSS FireMastic-HPE™	-/90/90 -/60/60	Maximum 125mm Aperture with 2.5mm ² 2C+E TPS cable, 1mm ² 2Core Data Cable and up to 20mm OD PVC Pipe, 3 x (up to) 20mm insulated copper pipes	WF 49599300.7
Paircoil / Power Cable / Data Cable / PVC Pipe Bundle	Wall	Min 116mm FR Plasterboard/GIB, Min 75mm Thick Rigid Walls incl Concrete, Speedwall, Hebel, Reinforced AAC, Solid or Hollow Masonry	BOSS FireMastic-HPE™	-/120/120	Maximum 100mm Aperture with Paircoil 16mm OD and 10mm OD insulated, 2.5mm ² 2Core+E TPS cable, 1mm ² 2Core Data Cable	WF 49599300.7

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES – HVAC+R pipes						
Paircoil / Power Cable / Data Cable / PVC Pipe Bundle	Wall	Min 75mm Thick Rigid Walls such as Concrete, Speedwall, Hebel, Reinforced AAC, Solid or Hollow Masonry	BOSS FireMastic-HPE™	-/90/90 -/60/60	Maximum 100mm Aperture with Paircoil 16mm OD and 10mm OD insulated, 2.5mm ² 2Core+E TPS cable, 1mm ² 2Core Data Cable	WF 49599300.7
Paircoil	Wall	124mm Thick FR Plasterboard/GIB + FR Plasterboard/GIB Patress	BOSS FireMastic-HPE™	-/90/90	Pair Coil 6.3mm OD and 12.6mm OD Pipes - Lagged	EWFA 37995200.2
Copper Pipes	Floor	120mm Thick Concrete / MaxiLite or Calcium Silicate Board	BOSS Abesco Cable Transit CT240 - Rectangle	-/120/30	3 x 34.2mm OD Copper Pipes with lagging	Branz FR 3981
Copper Pipe Bundles	Floor	120mm Thick Concrete	BOSS Abesco Cable Transit CT240 - Rectangle	-/120/90	Multiple Lagged Copper Pipes: -2 x 15mm OD Pipes -2 x 28mm OD Pipes -2 x 22mm OD Pipes -2 x 42mm OD Pipes	Branz FR 3981
Copper Pipe Bundles	Wall	130mm Thick FR Plasterboard/GIB	BOSS Abesco Cable Transit CT240 - Rectangle	-/120/60	Multiple Lagged Copper Pipes: -2 x 15mm OD Pipes -2 x 15.875mm OD Pipes -2 x 34.925mm OD Pipes -2 x 28.575mm OD Pipes	Branz FR 3982
Copper Pipe	Wall	130mm Thick FR Plasterboard/GIB	BOSS Abesco Cable Transit CT120 - Square	-/120/60	42mm OD Pipe with lagging	Branz FR 3982
Copper Pipe	Wall	Minimum 120mm Thick - FR Plasterboard/GIB, AAC, Masonry or Concrete	BOSS FireMastic-HPE™	-/120/120	15mm OD Pipe with continuous lagging	CSIRO FCO-2990B
Copper Pipe	Wall	Minimum 120mm Thick - FR Plasterboard/GIB, AAC, Masonry or Concrete	BOSS FireMastic-HPE™	-/120/120	Up to 40mm OD Pipe with continuous lagging	CSIRO FCO-2990B
Copper Pipe	Wall	Minimum 120mm Thick - FR Plasterboard/GIB, AAC, Masonry or Concrete	BOSS FireMastic-HPE™	-/120/90	>40mm to 60mm OD Pipe with continuous lagging	CSIRO FCO-2990B
Paircoil / PVC Pipe Bundle	Floor	Comflor® 60 - 130mm Thick	BOSS FireMastic-HPE™ sealed around services (with a Patress of BOSS Batt sealed with BOSS Ablative Coating)	-/120/120	16mm & 6mm Pair Coil and 25mm uPVC Drain Pipe	SFC FRT180137b.2
Insulated Copper Pipe 50mm	Wall	116mm Thick FR Plasterboard	BOSS MaxiCollar™ with BOSS P40-Mak Wrap and BOSS FireMastic-300	-/120/90	50mm OD Pipe lagged with Thermobreak 30mm Tube Insulation	SFC FRT180472c.1
Insulated Copper Pipe 80mm	Wall	75mm Thick Hebel / AAC	BOSS MaxiCollar™ with BOSS P40-Mak Wrap and BOSS FireMastic-300 on BOSS Batt Sealed with BOSS Ablative Coating	-/120/120	76.1mm OD Pipe lagged with Thermobreak 50mm Tube Insulation	SFC FRT180473b.1
Paircoil / Power Cable / Data Cable / PVC Pipe Bundle	Ceiling	FR Plasterboard/GIB Ceiling	BOSS MaxiCollar™ with BOSS FireMastic-HPE™ Infill	-/90/90	Paircoil - 16mm + 10mm Lagged Copper 25mm uPVC Conduit 1 x TPS Cable (2C+E) 2.5mm ² 1 x CAT 6 Data Cable	SFC FRT180474.2

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES – HVAC+R pipes						
Insulated Steel & Copper Pipes up to 80mm	Wall / Floor	"Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry Speedpanel, Korok, or similar Or Permanent Polymer Formwork Const. 120mm Concrete Floor Slab"	BOSS Batt - Double - Sealed with BOSS FlexiCoat-MAK with BOSS MaxiCollar & P40-MAK Wrap	-/120/120	Pipes up to 80mm with Continuous Thermobreak Lagging	Branz FTC 842
Insulated Steel & Copper Pipes up to 80mm	Wall / Floor	"Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry Speedpanel, Korok, or similar Or Permanent Polymer Formwork Const. 120mm Concrete Floor Slab"	BOSS FlexiBatt - Sealed with BOSS FlexiCoat-MAK with BOSS MaxiCollar & P40-MAK Wrap	-/120/120	Pipes up to 80mm with Continuous Thermobreak Lagging	Branz FTC 842
COMBUSTIBLE PIPES						
uPVC Pipe & Conduit Bundles up to 55.8mm	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox® with BOSS P40-MAK Wrap	-/120/120	Up to 55.8mm OD Pipe / Conduit. Any quantity of pipes.	Branz FTC 843
uPVC Pipe & Conduit Bundles up to 55.8mm	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox®	-/120/120	Up to 55.8mm OD Pipe / Conduit. Any quantity of pipes.	Branz FTC 843
PEX Pipe Bundles up to 32mm	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox® with BOSS P40-MAK Wrap	-/120/120	Up to 32mm OD Pipe. Any quantity of pipes.	Branz FTC 843
PEX Pipe Bundles up to 32mm	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox®	-/120/60	Up to 32mm OD Pipe. Any quantity of pipes.	Branz FTC 843
Lagged PEX Pipe Bundles up to 32mm	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox®	-/120/90	Up to 32mm OD Pipe with insulation. Any quantity of pipes.	Branz FTC 843

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
COMBUSTIBLE PIPES						
PEX-AL-PEX Pipe Bundles up to 32mm	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox® with BOSS P40-MAK Wrap	-/120/120	Up to 32mm OD Pipe. Any quantity of pipes.	Branz FTC 843
PEX-AL-PEX Pipe Bundles up to 32mm	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox®	-/120/60	Up to 32mm OD Pipe. Any quantity of pipes.	Branz FTC 843
Lagged PEX-AL-PEX Pipe Bundles up to 32mm	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox®	-/120/90	Up to 32mm OD Pipe with insulation. Any quantity of pipes.	Branz FTC 843
HDPE Pipes up to 32mm	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox® with BOSS P40-MAK Wrap	-/120/120	Up to 32mm OD Pipe. Any quantity of pipes.	Branz FTC 843
HDPE Pipes up to 32mm	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox®	-/120/60	Up to 32mm OD Pipe. Any quantity of pipes.	Branz FTC 843
PP (Polypropylene) Pipes up to 32mm	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox® with BOSS P40-MAK Wrap	-/120/120	Up to 32mm OD Pipe. Any quantity of pipes.	Branz FTC 843
PP (Polypropylene) Pipes up to 32mm	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox®	-/120/60	Up to 32mm OD Pipe. Any quantity of pipes.	Branz FTC 843

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
COMBUSTIBLE PIPES						
PP-R (Aquatherm) Pipes up to 32mm	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox® with BOSS P40-MAK Wrap	-/120/120	Up to 32mm OD Pipe. Any quantity of pipes.	Branz FTC 843
PP-R (Aquatherm) Pipes up to 32mm	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox®	-/120/60	Up to 32mm OD Pipe. Any quantity of pipes.	Branz FTC 843
PB (Polybutylene) Pipes up to 32mm	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox® with BOSS P40-MAK Wrap	-/120/120	Up to 32mm OD Pipe. Any quantity of pipes.	Branz FTC 843
PB (Polybutylene) Pipes up to 32mm	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox®	-/120/60	Up to 32mm OD Pipe. Any quantity of pipes.	Branz FTC 843
cPVC Pipe up to 60.3mm	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox® with BOSS P40-MAK Wrap	-/120/120	Up to 60.3mm OD Pipe. Any quantity of pipes.	Branz FTC 843
cPVC Pipe up to 60.3mm	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox®	-/120/120	Up to 60.3mm OD Pipe. Any quantity of pipes.	Branz FTC 843

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
COMBUSTIBLE PIPES						
Lagged PE-RT Pipe or PE-RT Kelox Pipe up to 32mm	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partwall, Barrierline, InTRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox® with BOSS P40-MAK Wrap	-/120/120	Up to 32mm OD Pipe with insulation. Any quantity of pipes.	Branz FTC 843
Lagged PE-RT Pipe or PE-RT Kelox Pipe up to 32mm	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partwall, Barrierline, InTRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox®	-/120/-	Up to 32mm OD Pipe with insulation. Any quantity of pipes.	Branz FTC 843
Lagged PE-RT Pipe or PE-RT Kelox Pipe up to 25mm	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partwall, Barrierline, InTRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox® with BOSS P40-MAK Wrap	-/120/120	Up to 25mm OD Pipe. Any quantity of pipes.	Branz FTC 843
Lagged PE-RT Pipe or PE-RT Kelox Pipe up to 25mm	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partwall, Barrierline, InTRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox®	-/120/-	Up to 25mm OD Pipe. Any quantity of pipes.	Branz FTC 843
PP-R Pipe (Aquatherm) 20mm	Wall	118mm Thick - 13mm FR Plasterboard/GIB	BOSS MaxiCollar™ MC-32 / infilled with BOSS FireMastic-HPE™	-/60/60	20mm OD Pipe	FRT 180403b.1
PP-R Pipe (Aquatherm) 32mm	Wall	118mm Thick - 13mm FR Plasterboard/GIB	BOSS MaxiCollar™ MC-32 / infilled with BOSS FireMastic-HPE™	-/60/60	32mm OD Pipe	FRT 180403b.1
PEX-AL-PEX Pipe 25mm	Wall	118mm Thick - 13mm FR Plasterboard/GIB	BOSS MaxiCollar™ MC-32 / infilled with BOSS FireMastic-HPE™	-/60/30	25mm OD Pipe	FRT 180403c.1
PEX Pipe 25mm	Wall	118mm Thick - 13mm FR Plasterboard/GIB	BOSS UniWrap® in Metal Sleeve	-/60/60	25mm OD Pipe	FRT 180403c.1
PEX Pipe 25mm	Wall	118mm Thick - 13mm FR Plasterboard/GIB	BOSS MaxiCollar™ MC-32 / infilled with BOSS FireMastic-HPE™	-/60/30	25mm OD Pipe	FRT 180403c.1
PEX Pipes 2 x 20mm	Wall	118mm Thick - 13mm FR Plasterboard/GIB	BOSS Maxi Collar MC-40 / infilled BOSS Fire Mastic-HPE	-/60/30	2 X 20mm OD Pipes	FRT 180403c.1
uPVC Pipe 40mm	Wall	118mm Thick - 13mm FR Plasterboard/GIB	BOSS MaxiCollar™ MC-40	-/60/60	40mm OD Pipe	FRT 180403d.1

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
COMBUSTIBLE PIPES						
uPVC Pipe 50mm	Wall	118mm Thick - 13mm FR Plasterboard/GIB	BOSS MaxiCollar™ MC-50 / BOSS FireMastic - 300	-/60/60	50mm OD Pipe	FRT 180403d.1
CPVC Pipe 40-50mm	Wall	118mm Thick - 13mm FR Plasterboard/GIB	BOSS MaxiCollar™ MC-50	-/60/30	50mm OD Pipe	FRT 180403d.1
uPVC Pipe 80mm	Wall	118mm Thick - 13mm FR Plasterboard/GIB	BOSS MaxiCollar™ MC-80	-/60/60	80mm OD Pipe	FRT 180403d.1
PEX Pipe 20mm	Wall	90mm Thick 13mm FR Plasterboard/GIB	BOSS FireMastic-HPE™	-/60/60	20mm OD Pipe	CSIRO COT 2923
PEX Pipe 20mm	Wall	90mm Thick - 13m FR Plasterboard/GIB + FR Plasterboard/GIB Patress	FireMastic-300™ to patress edges. BOSS FireMastic-HPE™ around pipe	-/60/60	20mm OD Pipe	CSIRO COT 2917
PEX Pipe up to 20mm	Wall	Min 116mm FR Plasterboard/GIB, Min 75mm Thick Rigid Walls incl Concrete, Speedwall, Hebel, AAC, Solid or Hollow Masonry	BOSS FireMastic-HPE™	-/120/120	Up to 20mm OD Pipe	WF 49599300.7
PEX Pipe up to 20mm	Wall	Min 75mm Thick Rigid Walls such as Concrete, Speedwall, Hebel, AAC, Solid or Hollow Masonry	BOSS FireMastic-HPE™	-/90/90 -/60/60	Up to 20mm OD Pipe	WF 49599300.7
PEX AL Pipe up to 20mm	Wall	Min 116mm FR Plasterboard/GIB, Min 75mm Thick Rigid Walls incl Concrete, Speedwall, Hebel, Reinforced AAC, Solid or Hollow Masonry	BOSS FireMastic-HPE™	-/120/120	Up to 20mm OD Pipe	WF 49599300.7
PEX AL Pipe up to 20mm	Wall	Min 75mm Thick Rigid Walls such as Concrete, Speedwall, Hebel, Reinforced AAC, Solid or Hollow Masonry	BOSS FireMastic-HPE™	-/90/90 -/60/60	Up to 20mm OD Pipe	WF 49599300.7
CPVC Pipe 32-40mm	Wall	Min 116mm FR Plasterboard/GIB, Min 75mm Thick Rigid Walls incl Concrete, Speedwall, Hebel, Reinforced AAC, Solid or Hollow Masonry	BOSS FireMastic-HPE™	-/120/120	Up to 43mm OD Pipe	WF 49599300.7
CPVC Pipe 32-40mm	Wall	Min 75mm Thick Rigid Walls such as Concrete, Speedwall, Hebel, Reinforced AAC, Solid or Hollow Masonry	BOSS FireMastic-HPE™	-/90/90 -/60/60	Up to 43mm OD Pipe	WF 49599300.7
uPVC Pipe or NBN Conduit 16-25mm	Wall	Min 116mm FR Plasterboard/GIB, Min 75mm Thick Rigid Walls incl Concrete, Speedwall, Hebel, Reinforced AAC, Solid or Hollow Masonry	BOSS FireMastic-HPE™ - only a 20mm Surface Fillet required	-/120/120	Up to 25mm OD Pipe	WF 49599300.7
uPVC Pipe or NBN Conduit 16-25mm	Wall	Min 75mm Thick Rigid Walls such as Concrete, Speedwall, Hebel, Reinforced AAC, Solid or Hollow Masonry	BOSS FireMastic-HPE™ - only a 20mm Surface Fillet required	-/90/90 -/60/60	Up to 25mm OD Pipe	WF 49599300.7
uPVC Pipe or NBN Conduit 16-20mm	Wall	Min 116mm FR Plasterboard/GIB, Min 75mm Thick Rigid Walls incl Concrete, Speedwall, Hebel, Reinforced AAC, Solid or Hollow Masonry	BOSS FireMastic-HPE™ - only a 20mm Surface Fillet required	-/120/120	Up to 20mm OD Pipe	WF 49599300.7

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
COMBUSTIBLE PIPES						
uPVC Pipe or NBN Pipe 16-20mm	Wall	Min 75mm Thick Rigid Walls such as Concrete, Speedwall, Hebel, Reinforced AAC, Solid or Hollow Masonry	BOSS FireMastic-HPE™ - only a 20mm Surface Fillet required	-/90/90 -/60/60	Up to 20mm OD Pipe	WF 49599300.7
PEX Pipe 20mm	Wall	96mm Thick FR Plasterboard/GIB	BOSS FireMastic-HPE™	-/90/90	20mm OD pipe	CSIRO COT 2967
PEX PIPE 25mm	Wall	101mm Thick FR Plasterboard/GIB	BOSS FireMastic-HPE™	-/90/30	25mm OD pipe	CSIRO FSP 1583
PEX PLUS Pipe 20mm	Wall	101mm Thick FR Plasterboard/GIB	BOSS FireMastic-HPE™	-/90/30	20mm OD pipe	CSIRO FSP 1583
PEX/AL/PEX Pipe 25mm	Wall	144mm Thick FR Plasterboard/GIB	BOSS FireMastic-HPE™	-/120/30	25mm OD pipe	FRT 180403h.1
PEX Pipe 25mm	Wall	144mm Thick FR Plasterboard/GIB	BOSS FireMastic-HPE™	-/120/120	25mm OD pipe	FRT 180403h.1
PEX Pipe 25mm	Wall	144mm Thick FR Plasterboard/GIB	BOSS MaxiCollar™ MC-32 / BOSS FireMastic-HPE™	-/120/60	25mm OD pipe	FRT 180403h.1
CPVC Pipe 50-60mm	Wall	144mm Thick FR Plasterboard/GIB	BOSS FireMastic-HPE™	-/120/60	60mm OD Pipe	FRT 180403g.1
PEX Pipe 32mm	Wall	144mm Thick FR Plasterboard/GIB	BOSS FireMastic-HPE™	-/120/-	32mm OD pipe	FRT 180403h.1
uPVC Pipe 40mm	Wall	144mm Thick FR Plasterboard/GIB	BOSS FireMastic-HPE™	-/120/120	42mm OD Pipe	FRT 180403g.1
uPVC Pipe 50mm	Wall	144mm Thick FR Plasterboard/GIB	BOSS FireMastic-HPE™	-/120/120	55mm OD Pipe	FRT 180403g.1
uPVC Pipe 80mm	Wall	144mm Thick FR Plasterboard/GIB	BOSS FireMastic-HPE™	-/90/90	82mm OD Pipe	FRT 180403g.1
uPVC Pipe 100/110mm	Wall	144mm Thick FR Plasterboard/GIB	BOSS MaxiCollar™ MC-100	-/120/120	110mm OD Pipe	FRT 180403g.1
PP-R Pipe (Aquatherm) 50mm	Wall	144mm Thick FR Plasterboard/GIB	BOSS FireMastic-HPE™	-/120/-	50mm OD Pipe	FRT 180403e.1
PP-R Pipe (Aquatherm) 65mm	Wall	144mm Thick FR Plasterboard/GIB	BOSS FireMastic-HPE™	-/120/-	63mm OD Pipe	FRT 180403e.1
CPVC Pipe 25-32mm	Wall	116mm Thick FR Plasterboard/GIB	BOSS FireMastic-HPE™	-/120/120	33mm OD Pipe	CSIRO COT 3043
CPVC Pipe 40-50mm	Wall	116mm Thick FR Plasterboard/GIB	BOSS MaxiCollar™ MC-50	-/120/120	48mm OD Pipe	CSIRO COT 3038
CPVC Pipe 40-50mm	Wall	116mm Thick FR Plasterboard/GIB	BOSS MaxiCollar™ MC-40	-/120/90	42mm OD Pipe	CSIRO COT 3039
CPVC Pipe 25-32mm	Wall	116mm Thick FR Plasterboard/GIB	BOSS MaxiCollar™ MC-32	-/120/120	33mm OD Pipe	CSIRO COT 3040
CPVC Pipe 50-60mm	Wall	116mm Thick FR Plasterboard/GIB	BOSS MaxiCollar™ MC-65	-/120/90	60mm OD Pipe	CSIRO COT 3045
CPVC Pipe 32-40mm	Wall	116mm Thick FR Plasterboard/GIB	BOSS UniWrap® and BOSS FireMastic - 300	-/120/90	48mm OD Pipe	CSIRO COT 3041

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
COMBUSTIBLE PIPES						
CPVC Pipe 25-32mm	Wall	116mm Thick FR Plasterboard/GIB	BOSS UniWrap® and BOSS FireMastic - 300	-/120/60	33mm OD Pipe	CSIRO COT 3042
CPVC Pipe 50-60mm	Wall	116mm Thick FR Plasterboard/GIB	BOSS UniWrap® and BOSS FireMastic - 300	-/120/90	60mm OD Pipe	CSIRO COT 3044
uPVC Pipe	Wall	78mm Speedwall + FR Plasterboard/GIB Patress	BOSS Abesco Collar RFC-100	-/120/120	110mm OD Pipe	EWFA 33090200.1
uPVC Pipe 100/110mm	Wall	78mm Speedwall	BOSS MaxiCollar™ MC-100	-/120/90	110mm OD Pipe	EWFA 33090200.1
uPVC Pipe 25-40mm	Wall	FR Plasterboard/GIB / 120mm Masonry	BOSS Abesco Collar RFC-25 / RFC-32 / RFC-40	-/120/120	25mm / 32mm / 40mm Conduit & Pipe	Branz FAR 3991
uPVC Pipe 25-40mm	Floor	120mm Thick Concrete	BOSS Abesco Collar RFC-25 / RFC-32 / RFC-40	-/120/120	25mm / 32mm / 40mm Conduit & Pipe	Branz FAR 3991
uPVC Pipe 50mm	Wall	FR Plasterboard/GIB	BOSS Abesco Collar RFC-50	-/120/60	50mm Pipe	Branz FAR 3991
uPVC Pipe 50mm	Wall	120mm Masonry	BOSS Abesco Collar RFC-50	-/120/90	50mm Pipe	Branz FAR 3991
uPVC Pipe 50mm	Floor	120mm Thick Concrete	BOSS Abesco Collar RFC-50	-/120/120	50mm Pipe	Branz FAR 3991
uPVC Pipe 50mm	Floor	150mm Thick Concrete	BOSS Abesco Collar RFC-50	-/180/180	50mm Pipe	Branz FAR 3991
uPVC Pipe 50mm	Floor	170mm Thick Concrete	BOSS Abesco Collar RFC-50	-/240/240	50mm Pipe	Branz FAR 3991
uPVC Pipe 65-80mm	Wall	FR Plasterboard/GIB	BOSS Abesco Collar RFC-65 / RFC-80	-/120/60	65mm / 80mm Pipe	Branz FAR 3991
uPVC Pipe 65-80mm	Wall	120mm Masonry	BOSS Abesco Collar RFC-65 / RFC-80	-/120/90	65mm / 80mm Pipe	Branz FAR 3991
uPVC Pipe 65-80mm	Floor	120mm Thick Concrete	BOSS Abesco Collar RFC-65 / RFC-80	-/120/120	65mm / 80mm Pipe	Branz FAR 3991
uPVC Pipe 65-80mm	Floor	150mm Thick Concrete	BOSS Abesco Collar RFC-65 / RFC-80	-/180/180	65mm / 80mm Pipe	Branz FAR 3991
uPVC Pipe 65-80mm	Floor	170mm Thick Concrete	BOSS Abesco Collar RFC-65 / RFC-80	-/240/240	65mm / 80mm Pipe	Branz FAR 3991
uPVC Pipe 100mm	Wall	FR Plasterboard/GIB	BOSS Abesco Collar RFC-100	-/120/60	100mm Pipe	Branz FAR 3991
uPVC Pipe - 100mm	Wall	120mm Masonry	BOSS Abesco Collar RFC-100	-/120/90	100mm Pipe	Branz FAR 3991
uPVC Pipe - 100mm	Floor	120mm Thick Concrete	BOSS Abesco Collar RFC-100	-/120/120	100mm Pipe	Branz FAR 3991
uPVC Pipe - 100mm	Floor	150mm Thick Concrete	BOSS Abesco Collar RFC-100	-/180/180	100mm Pipe	Branz FAR 3991
uPVC Pipe - 100mm	Floor	170mm Thick Concrete	BOSS Abesco Collar RFC-100	-/240/240	100mm Pipe	Branz FAR 3991
uPVC Pipe - 150mm	Floor	120mm Thick Concrete	BOSS Abesco Collar RFC-150	-/180/180	150mm Pipe	Branz FAR 3991
uPVC Pipe - 225mm	Floor	120mm Thick Concrete	BOSS Abesco Collar RFC-225	-/240/240	225mm Pipe	Branz FAR 3991
PEX Pipe 32mm	Floor	Comflor® 60 - 130mm Thick	BOSS FireMastic-HPE™	-/120/-	32mm OD Pipe	SFC FRT180137b.2
uPVC Pipe 100mm	Floor	Comflor® 60 - 130mm Thick	BOSS Batt Sealed with BOSS Ablative Coating, BOSS MaxiCollar™ and BOSS FireMastic-300™	-/120/120	109.8mm OD Pipe	SFC FRT180137a.2
HDPE Pipe 75mm	Floor	Comflor® 60 - 130mm Thick	BOSS Batt Sealed with BOSS Ablative Coating, BOSS MaxiCollar™ and BOSS FireMastic-300™	-/120/120	75mm OD Pipe	SFC FRT180137b.2

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
COMBUSTIBLE PIPES						
uPVC Pipe 25mm	Floor	Comflor® 60 - 130mm Thick	BOSS Batt Sealed with BOSS Ablative Coating, BOSS MaxiCollar™ and BOSS FireMastic-300™	-/120/120	33.6mm OD Pipe	SFC FRT180137a.2
uPVC Pipe 40mm	Wall	116mm Thick FR Plasterboard	BOSS UniWrap® in Metal Sleeve and BOSS FireMastic-300™	-/120/120	48.3mm OD Pipe	SFC FRT180472c.1
uPVC Pipe 50mm	Wall	116mm Thick FR Plasterboard	BOSS UniWrap® in Metal Sleeve and BOSS FireMastic-300™	-/120/120	60.3mm OD Pipe	SFC FRT180472c.1
uPVC Pipe 32mm	Wall	75mm Thick Hebel / AAC	BOSS FireMastic-HPE™	-/120/90	42.3mm OD Pipe	SFC FRT180473a.1
uPVC Pipe 50mm	Wall	75mm Thick Hebel / AAC	BOSS MaxiCollar™ and BOSS FireMastic-300™	-/120/120	55.7mm OD Pipe	SFC FRT180473b.1
uPVC Pipe 80mm	Wall	75mm Thick Hebel / AAC	BOSS MaxiCollar™ and BOSS FireMastic-300™	-/120/120	82.1mm OD Pipe	SFC FRT180473b.1
uPVC Pipe 40mm	Wall	75mm Thick Hebel / AAC	BOSS MaxiCollar™ and BOSS FireMastic-300™	-/120/90	48.2mm OD Pipe	SFC FRT180473a.1
PEX Pipe 16mm	Wall	118mm Thick - 13mm FR Plasterboard/GIB	BOSS PenoPatch™ - 60mm	-/60/60	16mm OD Pipe	WarringtonFire FAS 190100
uPVC Pipe 16mm	Wall	Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry / AAC Speedpanel, Korok, Hebel with with local build up to Min 100mm	BOSS PenoPatch™ 60mm	-/60/60	16mm OD Pipe - 25mm Aperture	WarringtonFire FAS 190100
uPVC Pipe 16mm	Wall	Min 100mm FR Plasterboard / GIB Min 100mm Concrete / Masonry / AAC Speedpanel, Korok, Hebel with with local build up to Min 100mm	BOSS PenoPatch™ 100mm	-/60/60	16mm OD Pipe - 50mm Aperture	WarringtonFire FAS 190100
uPVC Pipe 32mm	Ceiling	FR Plasterboard/GIB Ceiling	BOSS MaxiCollar™	-/90/90	42.3mm OD Pipe	SFC FRT180474.2
uPVC Conduit 25mm	Ceiling	FR Plasterboard/GIB Ceiling	BOSS FireMastic-HPE™	-/90/90	25mm uPVC Conduit	SFC FRT180474.2
uPVC Conduit Bundle	Ceiling	FR Plasterboard/GIB Ceiling	BOSS MaxiCollar™ + BOSS FireMastic-HPE™ Infill	-/90/90	2 x 25mm uPVC Conduits (with TPS Cable in conduit)	SFC FRT180474.2
PEX Pipe up to 20mm	Wall	CLT - Cross Laminate Timber	BOSS MaxiCollar™	-/90/90	Up to 20mm OD Pipe.	EWFA 54783400.1
PEX Pipe up to 20mm	Wall	CLT - Cross Laminate Timber	BOSS FireMastic-HPE™	-/90/90	Up to 20mm OD Pipe.	EWFA 54783400.1
PEX Pipe 20mm	Wall	118mm FR Plasterboard	BOSS FireMastic-HPE™ - applied to one side of wall only	-/60/60 -/90/90	Up to 20mm OD Pipe coming from inside wall cavity.	CSIRO FSP 2053 + 2084
uPVC Pipe 43mm	Wall	118mm FR Plasterboard	BOSS FireMastic-HPE™ - applied to one side of wall only	-/60/60 -/90/90	Up to 43mm OD Pipe coming from inside wall cavity.	CSIRO FSP 2053 + 2084
3 Piece Tap Set	Wall	118mm FR Plasterboard	BOSS FireMastic-HPE™ - applied to one side of wall only	-/120/120	Faucet incorporating 3 piece hand basin tap set.	CSIRO FSP 2084
PEX Pipe 20mm	Wall	128mm FR Plasterboard Shaftwall / Shaftliner	BOSS FireMastic-HPE™ - applied to one side of wall only	-/90/90 -/120/120	Up to 20mm OD Pipe coming from inside wall cavity.	CSIRO FSP 2073 + 2054
uPVC Pipe 43mm	Wall	128mm FR Plasterboard Shaftwall / Shaftliner	BOSS FireMastic-HPE™ - applied to one side of wall only	-/90/90 -/120/120	Up to 43mm OD Pipe coming from inside wall cavity.	CSIRO FSP 2073 + 2054
3 Piece Tap Set	Wall	128mm FR Plasterboard Shaftwall / Shaftliner	BOSS FireMastic-HPE™ - applied to one side of wall only	-/90/90 -/120/120	Faucet incorporating 3 piece hand basin tap set.	CSIRO FSP 2073

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
MIXED SERVICE COMBINATIONS - BUNDLES						
Power Cables / Data & Comms Cables / Plastic Pipes & Conduits / Lagged and Unlagged Steel & Copper Pipes / Pair Coil	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox® with BOSS P40-MAK Wrap	-/120/120	Any combination and any quantity of the following items: <ul style="list-style-type: none"> - Appx D1 Power (Exempt 630mm²) or Appx D2 Data Cables - Aluminium Power Cables 185mm² or less - Fire Alarm Cables - Security Cable - Coax Cable (MATV) - CAT5, CAT5E & CAT6 Data Cable - Up to 13mm/19mm Pair Coil - Insulated Copper Pipes - Up to 50.8mm OD Copper Pipe Lagged / Unlagged - Up to 55.8mm OD uPVC Pipe & Conduit - Up to 60.3mm OD cPVC Pipe - up to 32mm OD PEX & PEX-AL-PEX Pipes - Up to 32mm PP, PP-R, PB & HDPE Pipes - Up to 60.3mm OD Steel Pipe - Up to 32mm PE-RT & PE-RT Kelox Pipes 	Branz FTC 843
Pair Coil / Cable Bundles	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox® (no thermal wrap required)	-/120/90	Any combination and any quantity of the following items: <ul style="list-style-type: none"> - Comms & Data Cables - Power Cables up to 16mm² 2C+E - Up to 13mm/19mm Pair Coil - Insulated Copper Pipes 	Branz FTC 843
Power Cables / Data & Comms Cables / Plastic Pipes & Conduits / Lagged and Unlagged Steel & Copper Pipes / Pair Coil	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox® (no thermal wrap required)	-/120/60	Any combination and any quantity of the following items: <ul style="list-style-type: none"> - Appx D1 Power (Exempt 630mm²) or Appx D2 Data Cables - Fire Alarm Cables - Security Cable - Coax Cable (MATV) - CAT5, CAT5E & CAT6 Data Cable - Up to 13mm/19mm Pair Coil - Insulated Copper Pipes - Up to 50.8mm OD Lagged Copper Pipe - Up to 55.8mm OD uPVC Pipe & Conduit - Up to 60.3mm OD cPVC Pipe - up to 32mm OD PEX & PEX-AL-PEX Pipes - Up to 32mm PP, PP-R, PB & HDPE Pipes - Up to 60.3mm OD Steel Pipe 	Branz FTC 843
Power Cables / Data & Comms Cables / Plastic Pipes & Conduits / Lagged and Unlagged Steel & Copper Pipes / Pair Coil	Wall / Floor / Ceiling	FR Plasterboard/GIB, AAC, Hebel, Concrete, Block, Masonry, Dintel, AFS, Speedpanel, Korok, Supapanel, Pronto Panel, BOSS Batt, CLT, Shaftwall / Shaftliner, Partiwall, Barrierline, IntRwall, Concrete Floor Slabs, Plasterboard Ceilings and Ceiling Floor Systems.	BOSS FyreBox® (no thermal wrap required)	-/120/90	Any combination and any quantity of the following items: <ul style="list-style-type: none"> - Power Cables up to 16mm² 2C+E - Data & Comms Cables - Fire Alarm Cables - Security Cable - Coax Cable (MATV) - CAT5, CAT5E & CAT6 Data Cable - Up to 13mm/19mm Pair Coil - Insulated Copper Pipes - Up to 32mm OD Copper Pipe Lagged / Unlagged - Up to 55.8mm OD uPVC Pipe & Conduit - Up to 60.3mm OD cPVC Pipe - Up to 32mm OD Lagged PEX & PEX-AL-PEX Pipes - Up to 60.3mm OD Steel Pipe" 	Branz FTC 843

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
MIXED SERVICE COMBINATIONS - BUNDLES						
Paircoil / uPVC Drain / Cable Bundle - (one-sided penetration)	Wall	90mm Thick - 13mm FR Plasterboard/GIB	BOSS FireMastic-HPE™ applied to one side of the wall only	-/60/60	6.35mm/9.52mm Insulated Copper Pipes with non-rated lagging, 1.5mm ² 2C+E TPS Power Cable and a 16mm PVC flexible outlet pipe, coming out of wall cavity.	CSIRO COT2918
Paircoil / Power Cable / Control Cable Bundle	Wall	90mm Thick -13mm FR Plasterboard/GIB + FR Plasterboard/GIB Pattress	BOSS FireMastic-300™ to patress edges. BOSS FireMastic-HPE™ to annular gap	-/60/60	10mm/15mm Insulated Copper Pipes with non-rated lagging, 2.5mm ² 2C+E TPS Power Cable, and a 1.5mm ² 2 Core Data Cable and 20mm uPVC outlet pipe.	CSIRO COT2919
Paircoil / Power Cable / Control Cable Bundle	Wall	90mm Thick - 13mm FR Plasterboard/GIB	BOSS MaxiCollar™ / BOSS FireMastic-HPE™	-/60/60	10mm/15mm Insulated Copper Pipes with non-rated lagging, 2.5mm ² 2C+E TPS Power Cable, and a 1.5mm ² 2 Core Data Cable.	CSIRO COT 2920
Paircoil / Power Cable / Data Cable / PVC Pipe Bundle	Wall	Min 116mm FR Plasterboard/GIB, Min 75mm Thick Rigid Walls incl Concrete, Speedwall, Hebel, Reinforced AAC, Solid or Hollow Masonry	BOSS FireMastic-HPE™	-/120/120	Maximum 125mm Aperture with Paircoil 16mm OD and 10mm OD insulated, 2.5mm ² 2C+E TPS cable, 1mm ² 2C Data Cable and up to 20mm OD PVC Pipe	WF 49599300.7
Paircoil / Power Cable / Data Cable / PVC Pipe Bundle	Wall	Min 75mm Thick Rigid Walls such as Concrete, Speedwall, Hebel, Reinforced AAC, Solid or Hollow Masonry	BOSS FireMastic-HPE™	-/90/90 -/60/60	Maximum 125mm Aperture with Paircoil 16mm OD and 10mm OD insulated, 2.5mm ² 2C+E TPS cable, 1mm ² 2C Data Cable and up to 20mm OD PVC Pipe	WF 49599300.7
Paircoil / Power Cable / Data Cable / PVC Pipe Bundle	Wall	Min 116mm FR Plasterboard/GIB, Min 75mm Thick Rigid Walls incl Concrete, Speedwall, Hebel, Reinforced AAC, Solid or Hollow Masonry	BOSS FireMastic-HPE™	-/120/120	Maximum 125mm Aperture with 2.5mm ² 2C+E TPS cable, 1mm ² 2C Data Cable and up to 20mm OD PVC Pipe, 3 X up to 20mm insulated copper pipes	WF 49599300.7
Paircoil / Power Cable / Data Cable / PVC Pipe Bundle	Wall	Min 75mm Thick Rigid Walls such as Concrete, Speedwall, Hebel, Reinforced AAC, Solid or Hollow Masonry	BOSS FireMastic-HPE™	-/90/90 -/60/60	Maximum 125mm Aperture with 2.5mm ² 2C+E TPS cable, 1mm ² 2C Data Cable and up to 20mm OD PVC Pipe, 3 X up to 20mm insulated copper pipes	WF 49599300.7
Paircoil / Power Cable / Data Cable / PVC Pipe Bundle	Wall	Min 116mm FR Plasterboard/GIB, Min 75mm Thick Rigid Walls incl Concrete, Speedwall, Hebel, Reinforced AAC, Solid or Hollow Masonry	BOSS FireMastic-HPE™	-/120/120	Maximum 100mm Aperture with Paircoil 16mm OD and 10mm OD insulated, 2.5mm ² 2C+E TPS cable, 1mm ² 2C Data Cable	WF 49599300.7
Paircoil / Power Cable / Data Cable / PVC Pipe Bundle	Wall	Min 75mm Thick Rigid Walls such as Concrete, Speedwall, Hebel, Reinforced AAC, Solid or Hollow Masonry	BOSS FireMastic-HPE™	-/90/90 -/60/60	Maximum 100mm Aperture with Paircoil 16mm OD and 10mm OD insulated, 2.5mm ² 2C+E TPS cable, 1mm ² 2C Data Cable	WF 49599300.7
Paircoil	Wall	124mm Thick - 16mm Fire Rated Plasterboard Wall + FR Plasterboard/GIB Pattress	BOSS FireMastic-HPE™	-/90/90	Pair Coil 6.3mm OD and 12.6mm OD - Lagged through 80mm Aperture.	EWFA 37995200.2
Power Cables / Comms Cables / Data Cables Bundles	Wall / Floor	Concrete / Masonry	BOSS Abesco Cable Transit CT120 - Square	-/240/-	Any Appx D1 Configuration Cables up to cross section 630mm ² and CAT5e, CAT6 and RG6 Comms Cables in apertures up to 204mm x 306mm	Branz FAR 2981

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
MIXED SERVICE COMBINATIONS - BUNDLES						
Power Cables / Comms Cables / Data Cables Bundles	Wall / Floor	Concrete / Masonry	BOSS Abesco Cable Transit CT120 - Round	-/240/-	Any Appx D1 Configuration Cables up to cross section 630mm ² and CAT5e, CAT6 and RG6 Comms Cables in apertures up to 150mm Dia.	Branz FAR 2981
Power Cables / Comms Cables / Data Cables Bundles	Wall	FR Plasterboard/GIB	BOSS Abesco Cable Transit CT120 - Square	-/120/-	Any Appx D1 Configuration Cables up to cross section 630mm ² and CAT5e, CAT6 and RG6 Comms Cables in apertures up to 204mm x 306mm	Branz FAR 2981
Power Cables / Comms Cables / Data Cables Bundles	Wall	FR Plasterboard/GIB	BOSS Abesco Cable Transit CT120 - Round	-/120/-	Any Appx D1 Configuration Cables up to cross section 630mm ² and CAT5e, CAT6 and RG6 Comms Cables in apertures up to 150mm Dia.	Branz FAR 2981
Power Cables / Comms Cables / Cable Tray Bundle	Floor	120mm Thick Concrete	BOSS Abesco Cable Transit CT240 - Rectangle	-/240/-	300mm and 200mm Wide Cable Tray - 8 x 0.6 / 1Kv 3 Phase + Earth - Overall nominal 20mm -2 x 0.6 / 1Kv 120mm ² CU Earth Cable - Nominal Ext. Dia. 16mm -8 x 16mm ² 3C Underground Cable - Nominal Ext. Dia. 23mm -Bundle of 50 Comms Cables (0.5 Dia Conductor two pair per cable)	Branz FR 3981
Power Cables / Comms Cables / Cable Tray Bundle	Wall	130mm Thick FR Plasterboard/GIB	BOSS Abesco Cable Transit CT240 - Rectangle	-/120/30	300mm and 200mm Wide Cable Tray - 8 x 0.6 / 1Kv 3 Phase + Earth - Overall nominal 20mm -2 x 0.6 / 1Kv 120mm ² CU Earth Cable - Nominal Ext. Dia. 16mm -8 x 16mm ² 3C Underground Cable - Nominal Ext. Dia. 23mm -Bundle of 100 Comms Cables (0.4mm with three pair per cable)	Branz FR 3982
Paircoil / Power Cable / Control Cable Bundle	Wall	90mm Thick - 13mm FR Plasterboard/GIB + FR Plasterboard/GIB Patress™	BOSS FireMastic-300™ to patress edges. BOSS FireMastic-HPE™	-/60/60	10mm/15mm Insulated Copper Pipes, 2.5mm ² 2Core+E TPS Power Cable, 1.5mm ² 2C Data Cable and 20mm uPVC outlet pipe	CSIRO COT2919
Copper Pipes / Comms Cables / Data Cables / COAX Cables / Cable Tray	Floor	120mm Thick Concrete / MaxiLite or Calcium Silicate Board	BOSS Abesco Cable Transit CT240 - Rectangle	-/120/30	3 x 34.2mm OD Copper Pipes with Lagging 100 Comms Cables 9 x RG6 COAX Cables 3 x Bundles CAT5E Data Cables (150 Total)	Branz FR 3981
DUCTS/DAMPERS						
Ducts, Inside Exposure	Wall	Min 116mm FR Plasterboard / GIB Min 100mm Concrete / Masonry Min 78mm Speedpanel Min 75mm AAC	BOSS 3M Duct Wrap 615+	120/120/120	Ducts Up to 3600mm x 3600mm	CSIRO FCO-3273
Ducts, External Exposure - Horizontal	Wall	FR Plasterboard / GIB Concrete / Masonry	BOSS 3M Duct Wrap 615+	180/180/180	Ducts Up to 1250mm x 1000mm	Branz FAR 4812-TO
Ducts, External Exposure Vertical	Floor	Min 150mm Concrete	BOSS 3M Duct Wrap 615+	240/240/240	Ducts Up to 1250mm x 1000mm	Branz FAR 4812-TO
Ducts / Dampers	Wall / Floor	100mm Thick Concrete / Masonry	BOSS FireMortar-360	-/240/30	1200mm x 1200mm or 600mm x Any Length Apertures	Branz FTC 575

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.
DUCTS/DAMPERS						
Damper	Wall	FR Plasterboard/GIB / Concrete / Masonry	BOSS Batt - Single Layer - Sealed with BOSS Ablative Coating	-/120/-	Up to 1200mm Wide x 2400mm Aperture. 600mm x 600mm Damper	Branz FTC 576
Linear Gap around Intumescent Dampers	Wall	Perimeter Seal around Intumescent Dampers	BOSS FireMastic-300™	-/300/300	Max 5mm Gap for face fixed damper	Branz FAR 3821.4
Linear Gap around Intumescent Dampers	Wall	Perimeter Seal around Intumescent Dampers	BOSS FireMastic-300™	-/300/300	Max 25mm Gap for in-line installation gap	Branz FAR 3821.4

FIRESTOP CENTRE**(DISTRIBUTOR OF PROTECTA, 3M AND TRAFALGAR BRANDS)**

Manufacturer Code: FC

Unit J, 657 Great South Rd
Penrose
AUCKLAND

Ph: 09 483 4000 or 09 483 5000
Email: info@firestopcentre.co.nz
Website: www.firestopcentre.co.nz



The products listed in this register have all been tested to AS1530.4-2005 or Assessed to AS 4072.1-2005 as referenced within the New Zealand Building Code.

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.	ID/Ref
BLANKS							
Blank	Floor	Concrete or Aerated Concrete	2 layers Protecta FR Board 60mm double-sided positioned anywhere in the aperture.	-/180/120	Max opening 2400mm x 1200mm	Exova EWFA 51478400-A.1	FC256
Blank	Floor	Concrete or Aerated Concrete	1 layer Protecta FR Board 60mm double-sided positioned anywhere in the aperture.	-/120/90	Max opening 2400mm x 1200mm	Exova EWFA 51478400-A.1	FC257
Blank	Wall	Concrete, Aerated Concrete or Masonry	2 layers Protecta FR Board 60mm double-sided positioned anywhere in the aperture.	-/240/180	Unlimited width, Max 1200mm high	Exova EWFA 51478400-A.1	FC252
Blank	Wall	Concrete, Aerated Concrete or Masonry	1 layer Protecta FR Board 60mm double-sided positioned anywhere in the aperture.	-/240/90	Unlimited width, Max 1200mm high	Exova EWFA 51478400-A.1	FC253
Blank	Wall/Roof	Plasterboard or Concrete/AC/Masonry	1 layer Protecta FR Board 60mm double-sided friction fitted between top of wall and substrate above.	-/240/90	Unlimited width, Max 1200mm high	Exova EWFA 51478400-A.1	FC311
Blank	Wall	Plasterboard	Protecta FR Board 50mm single-sided flush with plasterboard each side of wall.	-/120/120	Unlimited width, Max 1200mm high	Exova EWFA 51478400-A.1	FC258
Blank	Wall	Plasterboard 13mm Single-layer	Protecta FR Acrylic Sealant 12.5mm each side, no backing required	-60/60	Up to 150x150mm	Exova EWFA 53619700-B.1	FC329
Blank	Wall	Plasterboard 13mm Double-layer	Protecta FR Acrylic Sealant 12.5mm each side with stone wool backing	-120/120	Up to 300x300mm	Exova EWFA 53619700-B.1	FC261
Blank	Floor	Concrete or Aerated Concrete	Protecta FR Acrylic Sealant 25mm top only or 15mm top and bottom with stone wool backing	Up to -/240/240	Up to 300x300mm	Exova EWFA 53619700-B.1	FC262
Blank	Floor	Concrete or Aerated Concrete	Protecta EX Mortar 50mm, backed with 50mm stone wool	-180/180	Up to 2400x1200mm	Exova EWFA 53619700-C.3	FC267
Blank	Floor	Concrete or Aerated Concrete	Protecta EX Mortar 100mm	-240/240	Up to 2400x1200mm	Exova EWFA 53619700-C.3	FC268
Blank	Wall	Concrete, Aerated Concrete or Masonry	Protecta EX Mortar 50mm, backed with 50mm stone wool	-180/120	Up to 2400x1200mm	Exova EWFA 53619700-C.3	FC264
Blank	Wall	Concrete, Aerated Concrete or Masonry	Protecta EX Mortar 100mm	-240/240	Up to 2400x1200mm	Exova EWFA 53619700-C.3	FC265
Blank	Wall	Concrete, Aerated Concrete or Masonry	Protecta FR Board 60mm to each side of the wall, pattress fitted	-240/180	Up to 600x600mm	Exova EWFA 51478400-A.1	FC255
Blank	Wall	Plasterboard or Concrete	Protecta FR Collar to both sides of the wall	Up to -/120/120	Up to 160mm diam	Warringtonfire 51478400	FC436
Blank	Floor	Concrete or Aerated Concrete	Protecta FR Collar to underside of floor	Up to -/120/120	Up to 160mm diam	Warringtonfire 51478400	FC443

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.	ID/Ref
NON-INSULATED METAL PIPES							
Steel	Wall	Plasterboard	Protecta FR Board 50mm single-sided flush with plasterboard each side of wall.	Up to -/120/60	Up to 114mm diam	Exova EWFA 51478400-A.1	FC313
Steel	Wall	Concrete, Aerated Concrete or Masonry	Protecta FR Acrylic Sealant 15mm both sides	-/240/-	Up to 219mm diam	Exova EWFA 53619700-B.1	FC327
Steel, Copper or Alupex	Wall	Concrete, Aerated Concrete or Masonry	Protecta FR Acrylic Sealant 25mm one side only	Up to -/240/-	Steel to 219mm, Copper to 54mm, Alupex to 75mm	Exova EWFA 53619700-B.1	FC328
Steel	Wall	Plasterboard 13mm single-layer	Protecta FR Acrylic Sealant 25mm one side only	-/60/30	Up to 22mm diam	Exova EWFA 53619700-B.1	FC330
Steel, Copper or Alupex	Wall	Plasterboard	Protecta FR Acrylic Sealant 12.5mm each side	Up to -/120/-	Steel to 219mm, Copper to 54mm, Alupex to 75mm	Exova EWFA 53619700-B.1	FC333
Steel or Copper	Floor	Concrete or Aerated Concrete from 60mm	Protecta FR Acrylic Sealant 15-25mm one side only	Up to -/240/120	Steel to 219mm, Copper to 54mm	Exova EWFA 53619700-B.1	FC335
Steel or Copper	Floor	Concrete or Aerated Concrete from 100mm	Protecta FR Acrylic Sealant 25mm both sides	Up to -/240/240	Steel to 219mm, Copper to 54mm	Exova EWFA 53619700-B.1	FC300
Steel or Copper	Floor	Concrete or Aerated Concrete from 100mm	Protecta EX Mortar 50mm, backed with 50mm stone wool	Up to -/180/180	Steel to 219mm, Copper to 15mm	Exova EWFA 53619700-C.3	FC339
Steel	Floor	Concrete or Aerated Concrete from 100mm	Protecta EX Mortar 100mm	Up to -/240/-	Steel to 219mm	Exova EWFA 53619700-C.3	FC340
Steel	Wall	Concrete, Aerated Concrete or Masonry	Protecta EX Mortar 50mm, backed with 50mm stone wool	-/120/-	Steel to 219mm	Exova EWFA 53619700-C.3	FC345
Steel	Wall	Concrete, Aerated Concrete or Masonry	Protecta EX Mortar 100mm	-/240/-	Steel to 219mm	Exova EWFA 53619700-C.3	FC346
Steel, Copper, Ferrous	Wall	Plasterboard	3M CP 25WB+ Sealant with 3M E-5A-4 Endothermic Mat for insulation rating	Up to -/120/120	Steel to 114mm, Copper / Ferrous to 15mm	Exova RIR 23263-01	FC350
Steel, Copper, Ferrous	Wall	Concrete, Aerated Concrete or Masonry	3M CP 25WB+ Sealant with 3M E-5A-4 Endothermic Mat for insulation rating	Up to -/240/120	Steel to 114mm, Copper / Ferrous to 15mm	Exova RIR 23263-01	FC293
Steel or Copper	Wall	Concrete, Aerated Concrete or Masonry	1 layer Protecta FR Board 60mm double-sided positioned anywhere in the aperture.	-/240/-	Steel to 325mm, Copper to 54mm	Exova EWFA 51478400-A.1	FC351
Steel, Copper or Alupex	Wall	Plasterboard or Concrete	Protecta FR Putty Cord fillet each side of wall (annular space can be zero)	Up to -/120/120	Steel to 30mm, Copper to 12mm, Alupex to 20mm	Exova EWFA 53619700-A.4	FC352
Steel or Copper	Floor	Concrete or Aerated Concrete from 100mm	Protecta FR Putty Cord fillet to bottom side of floor only (annular space can be zero)	Up to -/120/120	Steel to 30mm, Copper to 12mm	Exova EWFA 53619700-A.4	FC357
Steel or Copper	Floor	Concrete or Aerated Concrete from 100mm	Protecta FR Putty Cord fillet to top side of floor only (annular space can be zero)	Up to -/120/120	Steel to 22mm, Copper to 10mm	Exova EWFA 53619700-A.4	FC358

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.	ID/Ref
INSULATED METAL PIPES							
Steel (Interrupted Insulation)	Wall	Concrete, Aerated Concrete or Masonry	2 layers Protecta FR Board 60mm double-sided	Up to -/240/180	Up to 219mm diam	Exova EWFA 51478400-A.1	FC177
Steel or Copper (Continuous or Interrupted)	Wall	Concrete, Aerated Concrete or Masonry	1 layer Protecta FR Board 60mm double-sided positioned anywhere in the aperture.	Up to -/240/240	Steel to 324mm, Copper to 54mm	Exova EWFA 51478400-A.1	FC178
Steel (Interrupted)	Floor	Concrete or Aerated Concrete from 120mm	2 layers Protecta FR Board 60mm double-sided	-/180/60	Up to 219mm diam	Exova EWFA 51478400-A.1	FC185
Steel or Copper (Interrupted)	Floor	Concrete or Aerated Concrete from 60mm	1 layer Protecta FR Board 60mm double-sided positioned anywhere in the aperture.	Up to -/120/120	Steel to 219mm, Copper to 54mm	Exova EWFA 51478400-A.1	FC186
Steel, Copper (Continuous, Combustible)	Wall	Plasterboard	Protecta FR Board 50mm single-sided each side of wall, with Protecta FR Pipe Wrap.	Up to -/120/120	Up to 324mm diam	Exova EWFA 51478400-A.1	FC274
Steel (Continuous)	Wall	Plasterboard	Protecta FR Board 50mm single-sided flush with plasterboard each side of wall.	-/120/120	Up to 324mm diam	Exova EWFA 51478400-A.1	FC272
Steel or Alupex (Interrupted)	Wall	Plasterboard	Protecta FR Board 50mm single-sided flush with plasterboard each side of wall.	Up to -/120/120	Steel to 219mm, Alupex to 75mm	Exova EWFA 51478400-A.1	FC189
Steel, Copper or Alupex (Interrupted)	Wall	Concrete, Aerated Concrete or Masonry	Protecta FR Acrylic Sealant 25mm one side only	Up to -/240/240	Steel to 219mm, Copper to 54mm, Alupex to 75mm	Exova EWFA 53619700-B.1	FC116
Steel (Continuous)	Wall	Concrete, Aerated Concrete or Masonry	Protecta FR Acrylic Sealant 25mm one side only	-/180/180	Up to 324mm diam	Exova EWFA 53619700-B.1	FC278
Steel (Interrupted)	Wall	Concrete, Aerated Concrete or Masonry	Protecta FR Acrylic Sealant 15mm both sides	-/240/120	Up to 219mm diam	Exova EWFA 53619700-B.1	FC117
Steel (Continuous)	Wall	Concrete, Aerated Concrete or Masonry	Protecta FR Acrylic Sealant 15mm both sides	-/240/240	Up to 324mm diam	Exova EWFA 53619700-B.1	FC279
Steel (Continuous, Combustible)	Wall	Concrete, Aerated Concrete from 100mm	Protecta FR Acrylic Sealant 25mm both sides	Up to -/240/180	Up to 114mm diam	Exova EWFA 53619700-B.1	FC324
Steel (Continuous)	Wall	Plasterboard	Protecta FR Acrylic Sealant 12.5mm both sides	-/120/90	Steel to 324mm	Exova EWFA 53619700-B.1	FC119
Steel, Copper or Alupex (Interrupted)	Wall	Plasterboard	Protecta FR Acrylic Sealant 12.5mm both sides	Up to -/120/120	Steel to 219mm, Copper to 54mm, Alupex to 75mm	Exova EWFA 53619700-B.1	FC121
Steel or Copper (Interrupted)	Floor	Concrete or Aerated Concrete from 60mm	Protecta FR Acrylic Sealant 15-25mm one side only	Up to -/240/180	Steel to 219mm, Copper to 54mm	Exova EWFA 53619700-B.1	FC125
Steel (Continuous)	Floor	Concrete or Aerated Concrete from 60mm	Protecta FR Acrylic Sealant 25mm top side only	-/240/240	Up to 324mm diam	Exova EWFA 53619700-B.1	FC302
Steel (Continuous, Combustible)	Floor	Concrete or Aerated Concrete from 100mm	Protecta FR Acrylic Sealant 25mm both sides	-/60/60	Up to 165mm diam	Exova EWFA 53619700-B.1	FC299
Steel (Interrupted)	Floor	Concrete or Aerated Concrete from 70mm	Protecta FR Acrylic Sealant 15mm both sides	-/240/120	Up to 219mm diam	Exova EWFA 53619700-B.1	FC298
Steel (Interrupted)	Floor	Concrete or Aerated Concrete from 100mm	Protecta EX Mortar 50mm, backed with 50mm stone wool	-/180/90	Up to 219mm diam	Exova EWFA 53619700-C.3	FC202
Steel (Continuous)	Floor	Concrete or Aerated Concrete from 100mm	Protecta EX Mortar 50mm, backed with 50mm stone wool	Up to -/240/240	Up to 324mm diam	Exova EWFA 53619700-C.3	FC338

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.	ID/Ref
INSULATED METAL PIPES							
Steel (Interrupted)	Floor	Concrete or Aerated Concrete from 100mm	Protecta EX Mortar 100mm	Up to -/240/240	Up to 219mm diam	Exova EWFA 53619700-C.3	FC204
Steel (Combustible insulation)	Floor	Concrete or Aerated Concrete from 100mm	Protecta EX Mortar 100mm with Protecta FR Pipe Wrap	Up to -/240/120	Up to 324mm diam	Exova EWFA 53619700-C.3	FC205
Steel (Continuous)	Wall	Concrete, Aerated Concrete or Masonry	Protecta EX Mortar 50mm, backed with 50mm stone wool	-/120/90	Up to 219mm diam	Exova EWFA 53619700-C.3	FC195
Steel (Interrupted)	Wall	Concrete, Aerated Concrete or Masonry	Protecta EX Mortar 50mm, backed with 50mm stone wool	Up to -/180/120	Up to 219mm diam	Exova EWFA 53619700-C.3	FC196
Steel (Continuous, Combustible)	Wall	Concrete, Aerated Concrete or Masonry	Protecta EX Mortar 100mm with Protecta FR Pipe Wrap	Up to -/240/60	Up to 165mm diam	Exova EWFA 53619700-C.3	FC344
Steel (Interrupted)	Wall	Concrete, Aerated Concrete or Masonry	Protecta EX Mortar 100mm	Up to -/240/240	Up to 219mm diam	Exova EWFA 53619700-C.3	FC199
Steel (Continuous, Combustible)	Wall	Plasterboard	Protecta EX Mortar 50mm with 2 layers Protecta FR Pipe Wrap each side	-/120/60	Up to 165mm diam	Exova EWFA 53619700-C.3	FC163
Steel or Alupex (Interrupted)	Wall	Plasterboard	Protecta EX Mortar 25mm each side, with stone wool backing	Up to -/120/90	Steel to 219mm, Alupex to 75mm	Exova EWFA 53619700-C.3	FC212
Steel (Continuous Insulation)	Wall	Concrete, Aerated Concrete or Masonry	2 layers Protecta FR Board 60mm double-sided	Up to -/240/180	Up to 324mm diam	Exova EWFA 51478400-A.1	FC275
Steel or Copper (Interrupted)	Wall	Plasterboard or Concrete	Protecta FR Putty Cord fillet each side of wall (annular space can be zero)	Up to -/120/120	Steel to 324mm, Copper to 54mm	Exova EWFA 53619700-A.4	FC353
Steel or Copper (Continuous Insulation)	Wall	Plasterboard or Concrete	Protecta FR Putty Cord fillet each side of wall (annular space can be zero)	Up to -/120/120	Steel to 324mm, Copper to 54mm	Exova EWFA 53619700-A.4	FC354
Steel or Copper (Interrupted)	Floor	Concrete or Aerated Concrete from 100mm	Protecta FR Putty Cord fillet to top side of floor only (annular space can be zero)	Up to -/240/240	Steel to 324mm, Copper to 54mm	Exova EWFA 53619700-A.4	FC359
Steel or Copper (Continuous Insulation)	Floor	Concrete or Aerated Concrete from 100mm	Protecta FR Putty Cord fillet to top side of floor only (annular space can be zero)	Up to -/240/240	Steel to 324mm, Copper to 54mm	Exova EWFA 53619700-A.4	FC360
Steel (Continuous, Combustible)	Wall	Concrete or Aerated Concrete from 100mm	1 layer Protecta FR Board 60mm double-sided positioned anywhere in the aperture, with wrap.	-/120/45	Steel to 165mm	Exova EWFA 51478400-A.1	FC363
Steel, Copper or Alupex (Combustible)	Wall	Plasterboard	Protecta FR Acrylic Sealant 25mm both sides	Up to -/120/120	Steel to 165mm, Copper to 54mm, Alupex to 75mm	Exova EWFA 53619700-B.1	FC365
Steel, Copper (Continuous, Combustible)	Wall	Plasterboard or Concrete	Protecta Collar to each side of the wall	Up to -/120/90	Up to 54mm diam	Warringtonfire 51478400	FC437
Steel, Copper (Continuous, Combustible)	Floor	Concrete or Aerated Concrete from 100mm	Protecta Collar to underside of floor	-/240/60	Up to 54mm diam	Warringtonfire 51478400	FC441
Copper Pair Coil with FR insulation	Wall	Plasterboard or Concrete	Trafalgar FyrePEX sealant 25mm both sides	-/120/120	Up to 110mm diam	BRANZ FAR 4849	FC451
Copper Pair Coils with FR insulation	Wall	Concrete or Hebel PowerPanel	Trafalgar FyrePEX sealant 60mm from either side	-/90/90	Up to 120mm diam	BRANZ FAR 4849	FC452
Copper Pair Coils with FR insulation	Floor	Concrete	Trafalgar FyrePEX sealant 60mm from either side	-/120/120	Up to 120mm diam	BRANZ FAR 4849	FC453

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.	ID/Ref
INSULATED METAL PIPES							
Copper Pair Coils with PE foam insulation	Floor	Concrete	Trafalgar FyreCHOKE Collar to underside of floor	-/120/120	Up to 80mm diam	CSIRO FSP 1709	FC459
Copper Pair Coils with PE foam insulation	Wall	Plasterboard or Concrete	Trafalgar FyreCHOKE Collar to each side of the wall	Up to -/90/45	Up to 80mm diam	CSIRO FSP 1801	FC460
Copper Pair Coils with PE foam insulation	Wall	Hebel AAC panel wall	Trafalgar FyreCHOKE Collar to each side of the wall	-/90/60	Up to 80mm diam	CSIRO FSP 1795	FC462
PLASTIC PIPES							
PVC, PE, PP Pipes	Wall	Plasterboard	Protecta Collar to each side of wall	Up to -/90/60	Up to 160mm diam	Exova EWFA 51478400-B.1	FC144
PVC, PE, PP Pipes	Wall	Concrete, Aerated Concrete or Masonry	Protecta Collar to each side of wall	Up to -/240/240	Up to 160mm diam	Exova EWFA 51478400-B.1	FC145
PVC, PE, PP Pipes	Floor	Concrete or Aerated Concrete from 60mm	Protecta Collar to underside of floor	Up to -/90/60	Up to 160mm diam	Exova EWFA 51478400-B.1	FC146
PVC, PE, PP Pipes	Wall	Concrete, Aerated Concrete or Masonry	Protecta FR Acrylic Sealant 25mm both sides	Up to -/240/240	Up to 32mm diam	Exova EWFA 53619700-B.1	FC325
PVC, PE, PP Pipes	Floor	Concrete or Aerated Concrete from 100mm	Protecta EX Mortar 100mm with Protecta FR Pipe Wrap	Up to -/240/240	Up to 250mm diam	Exova EWFA 53619700-C.3	FC206
PEX Pipes	Wall	Plasterboard or Concrete	3M 3000WT Sealant 26mm to both sides with 25mm fillet	-180/120	Up to 25mm diam	Exova RIR 45239800.1	FC282
PVC Pipes	Floor	Concrete or Aerated Concrete from 75mm	3M Tuck-In Wrap Strips	Up to -/180/180	Up to 160mm diam	BRANZ FAR 4568	FC247
PVC Pipes	Wall	Plasterboard or Concrete	3M Tuck-In Wrap Strips	Up to -/120/120	Up to 110mm diam	BRANZ FAR 4568	FC288
Reinforced PP Acoustic Pipes	Wall	Plasterboard or Concrete	Protecta Collar to each side of the wall	Up to -/120/120	Up to 160mm diam	Warringtonfire 51478400	FC432
PEX Pipes	Wall	Plasterboard or Concrete	Protecta Collar to each side of the wall	-/120/90	Single to 25mm, Bundles to 55mm	Warringtonfire 51478400	FC435
PVC, PE Pipes	Wall	Plasterboard or Concrete	Protecta Collar to each side of the wall with FR Board insert	Up to -/120/60	Up to 110mm diam	Warringtonfire 51478400	FC438
Reinforced PP Acoustic Pipes	Floor	Concrete or Aerated Concrete from 100mm	Protecta Collar to underside of floor	Up to -/240/240	Up to 160mm diam	Warringtonfire 51478400	FC439
Large Size PVC, PE, PP Pipes	Floor	Concrete or Aerated Concrete from 100mm	Protecta Collar to underside of floor	Up to -/240/240	Up to 400mm diam	Warringtonfire 51478400	FC440
PVC, PE, PP Pipes	Floor	Concrete or Aerated Concrete from 100mm	Protecta Collar to top side of floor	Up to -/240/240	Up to 160mm diam	Warringtonfire 51478400	FC444
PEX, AluPEX Pipes	Floor	Concrete or Aerated Concrete from 120mm	Trafalgar FyrePEX sealant 60mm from either side	-/120/120	16mm	BRANZ FAR 4849	FC454
PEX, AluPEX Pipes	Wall	Plasterboard or Concrete	Trafalgar FyrePEX sealant 25mm both sides	-/120/120	PEX to 25mm. AluPex to 20mm	BRANZ FAR 4849	FC455

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.	ID/Ref
ELECTRICAL PENETRATION SERVICES							
Cables - single, bundled, trays, conduits	Wall	Concrete, Aerated Concrete or Masonry	2 layers Protecta FR Board 60mm double-sided	Up to -/180/120	Cables to 80mm, Bundles to 100mm	Exova EWFA 51478400-A.1	FC175
Cables - single, bundled, trays, conduits	Floor	Concrete or Aerated Concrete from 120mm	2 layers Protecta FR Board 60mm double-sided	Up to -/120/120	Cables to 80mm, Bundles to 100mm	Exova EWFA 51478400-A.1	FC182
Cables - single, bundled, trays, conduits	Floor	Concrete or Aerated Concrete from 60mm	1 layer Protecta FR Board 60mm double-sided positioned anywhere in the aperture.	Up to -/90/45	Cables to 80mm, Bundles to 100mm	Exova EWFA 51478400-A.1	FC183
Cables - single, bundled, trays, conduits	Wall	Plasterboard	1 layer Protecta FR Board 50mm single-sided flush with plasterboard each side of wall	-/60/60	Cables single or bundled to 80mm	Exova EWFA 51478400-A.1	FC188
Cables - single	Wall	Concrete, Aerated Concrete or Masonry	Protecta FR Acrylic to one side of wall or anywhere inbetween	Up to -/240/120	Single cable up to 21mm	Exova EWFA 53619700-B.1	FC113
Cables - single or bundled	Wall	Concrete, Aerated Concrete or Masonry	Protecta FR Acrylic to both sides of wall	Up to -/240/240	Cables to 80mm, Bundles to 100mm	Exova EWFA 53619700-B.1	FC114
Cables - single or bundled	Wall	Plasterboard from single-layer 13mm	Protecta FR Acrylic Sealant to each side of wall	Up to -/60/45	Cables to 21mm, Bundles to 100mm	Exova EWFA 53619700-B.1	FC174
Cables - single or bundled	Wall	Plasterboard	Protecta FR Acrylic Sealant to each side of wall	Up to -/120/120	Cables to 80mm, Bundles to 100mm	Exova EWFA 53619700-B.1	FC118
Cables - single or bundled	Floor	Concrete or Aerated Concrete from 60mm	Protecta FR Acrylic Sealant 15mm to top and bottom of floor	Up to -/120/120	Single or bundled cables up to 80mm diam	Exova EWFA 53619700-B.1	FC124
Cables - single or bundled	Floor	Concrete or Aerated Concrete from 100mm	Protecta EX Mortar 50mm, backed with 50mm stone wool	Up to -/180/180	Single or bundled cables up to 21mm diam, conduits	Exova EWFA 53619700-C.3	FC201
Cables - single or bundled	Floor	Concrete or Aerated Concrete from 100mm	Protecta EX Mortar 100mm	Up to -/180/180	Single or bundled cables up to 80mm diam, conduits	Exova EWFA 53619700-C.3	FC337
Cables - trays	Floor	Concrete or Aerated Concrete from 100mm	Protecta EX Mortar 50mm, backed with 50mm stone wool	-/90/60	Single or bundled cables up to 21mm diam, conduits	Exova EWFA 53619700-C.3	FC336
Cables - trays	Floor	Concrete or Aerated Concrete from 100mm	Protecta EX Mortar 100mm	-/120/60	Single or bundled cables up to 80mm diam, conduits	Exova EWFA 53619700-C.3	FC203
Cables - single or bundled, conduits	Wall	Concrete, Aerated Concrete or Masonry	Protecta EX Mortar 50mm, backed with 50mm stone wool	Up to -/180/90	Single or bundled cables up to 21mm diam, conduits	Exova EWFA 53619700-C.3	FC194
Cables - trays	Wall	Concrete, Aerated Concrete or Masonry	Protecta EX Mortar 50mm, backed with 50mm stone wool	-/180/60	Single or bundled cables up to 21mm diam, conduits	Exova EWFA 53619700-C.3	FC342
Cables - single or bundled, conduits	Wall	Concrete, Aerated Concrete or Masonry	Protecta EX Mortar 100mm	Up to -/240/240	Single or bundled cables up to 80mm diam, conduits	Exova EWFA 53619700-C.3	FC197
Cables - single, bundles, trays, conduits	Wall	Plasterboard	Protecta EX Mortar 25mm each side, backed with mineral wool	Up to -/120/120	Single or bundled cables up to 80mm diam, conduits	Exova EWFA 53619700-C.3	FC211
Conduit	Wall	Plasterboard	3M IC 15WB+ Sealant 26mm each side	Up to -/180/90	Conduits up to 26mm	Exova RIR 45239800a.1	FC347
Cables - single	Wall	Plasterboard	Protecta FR Putty Cord to both sides of wall	Up to -/120/120	Single cables up to 80mm diam	Exova EWFA 53619700-A.4	FC312
Cables - bundles	Wall	Plasterboard or Concrete from 100mm	Protecta FR Putty Cord to both sides of wall	Up to -/120/120	Cable bundles up to 50mm	Exova EWFA 53619700-A.4	FC349
Conduit, empty or up to 4 fibre optic cables	Wall	Plasterboard, concrete, masonry or AAC	3M Ultra GS Wrap and 3M Mouldable Putty both sides of wall	-/120/120	Conduits up to 26mm	CSIRO FCO-3220	FC285

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.	ID/Ref
ELECTRICAL PENETRATION SERVICES							
Cables D1 and D2 including cable trays	Wall	Plasterboard, concrete or masonry	3M CP 25WB+ Sealant with 3M E-5A-4 Endothermic Mat for insulation rating	Up to -/120/120	All D1 and D2 cables, including trays	Exova RIR 23263-01	FC217
Cables D1 and D2 including cable trays	Floor	Concrete or Aerated Concrete from 120mm	3M CP 25WB+ Sealant with 3M E-5A-4 Endothermic Mat for insulation rating	Up to -/180/120	All D1 and D2 cables, including trays	Exova RIR 23263-01	FC216
Cables - single	Wall	Concrete, Aerated Concrete or Masonry	1 layer Protecta FR Board 60mm double-sided positioned anywhere in the aperture.	-/240/90	Single cable up to 21mm	Exova EWFA 51478400-A.1	FC176
Cables - bundles - and Conduits	Wall	Concrete, Aerated Concrete or Masonry	2 layers Protecta FR Board 60mm double-sided	Up to -/180/180	Single or bundled cables up to 80mm diam, conduits	Exova EWFA 51478400-A.1	FC310
Cables - single, bundled, trays, conduits	Wall	Concrete, Aerated Concrete or Masonry	Protecta FR Board 60mm to each side of the wall, pattress fitted	Up to -/240/180	Single or bundled cables up to 80mm diam	Exova EWFA 51478400-A.1	FC181
Cables - single or bundled	Floor	Concrete or Aerated Concrete from 100mm	Protecta FR Putty Cord to top of floor only	Up to -/120/120	Single or bundled cables up to 50mm diam	Exova EWFA 53619700-A.4	FC355
Cables - single or bundled	Floor	Concrete or Aerated Concrete from 100mm	Protecta FR Putty Cord to bottom of floor only	Up to -/120/60	Single or bundled cables up to 75mm diam	Exova EWFA 53619700-A.4	FC356
Cables - single or bundled	Wall	Plasterboard or Concrete from 100mm	Protecta FR Collar to both sides of wall	-/120/60	Cable bundles up to 160mm	Warringtonfire 51478400	FC434
Cables - single or bundled	Floor	Concrete or Aerated Concrete from 100mm	Protecta FR Collar to underside of floor only	Up to -/180/180	Cable bundles up to 160mm	Warringtonfire 51478400	FC442
Cable -single	Ceiling	Plasterboard	Trafalgar FyreFLEX to depth of plasterboard ceiling	-/60/-	Single electric cable	CSIRO FCO-1579	FC431
Downlight	Ceiling	Plasterboard	Trafalgar FyreHAT inserted into ceiling	Up to -/120/90	Downlights through apertures up to 105mm	CSIRO FSP 1290B	FC448
Conduit, empty or filled with cables	Wall	Plasterboard or Concrete from 100mm	Protecta FR Acrylic sealant 25mm to both sides of wall	Up to -/120/120	Conduits up to 40mm	Exova EWFA 53619700-B.1	FC468
Conduit, empty or filled with cables	Floor	Concrete or Aerated Concrete from 100mm	Protecta FR Acrylic sealant 25mm to top and bottom surface	Up to -/240/240	Conduits up to 40mm	Exova EWFA 53619700-B.1	FC466
SEISMIC/CONSTRUCTION JOINTS							
Floor joints or Floor to Wall gaps	Floor	Concrete or Aerated Concrete from 64mm	Protecta FR IPT Sealant 15mm top and bottom of floor	Up to -/240/240	Gaps/Joints up to 30mm	UL Assessment 4788415167	FC314
Floor joints or Floor to Wall gaps	Floor	Concrete or Aerated Concrete from 64mm	Protecta FR IPT Sealant 25mm at any position within floor	Up to -/240/180	Gaps/Joints up to 30mm	UL Assessment 4788415167	FC137
Wall joints or Top of Wall to Floor above	Wall	Concrete, Aerated Concrete or Masonry from 64mm	Protecta FR IPT Sealant 12.5mm each side of wall	Up to -/120/120	Gaps/Joints up to 30mm	UL Assessment 4788415167	FC136
Wall joints or Top of Wall to Floor above	Wall	Plasterboard from 13mm Single-layer	Protecta FR IPT Sealant 12.5mm each side of wall	Up to -/120/120	Gaps/Joints up to 30mm	UL Assessment 4788415167	FC135
Floor joints or Floor to Wall gaps	Floor	Concrete or Aerated Concrete from 64mm	Protecta FR ASF Sealant 25mm to top face of floor	Up to -/120/120	Gaps/Joints up to 100mm	UL Assessment 4787654631	FC109
Wall joints or Top of Wall to Floor above	Wall	Concrete, Aerated Concrete or Masonry from 90mm	Protecta FR ASF Sealant to each side of wall	Up to -/120/120	Gaps/Joints up to 30mm	UL Assessment 4787654631	FC108

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref.	ID/Ref
SEISMIC/CONSTRUCTION JOINTS							
Wall joints or Top of Wall to Floor above	Wall	Plasterboard from 10mm Single-layer	Protecta FR ASF Sealant to each side of wall	Up to -/120/120	Gaps/Joints up to 30mm	UL Assessment 4787654631	FC107
Wall joints or Top of Wall to Floor above	Wall	Concrete, Aerated Concrete or Masonry from 75mm	Protecta FR Acrylic Sealant to each side of wall or one side only	Up to -/240/240	Gaps/Joints up to 50mm	Exova EWFA 53619700-B.1	FC111
HVAC							
Ducts, Horizontal or Vertical	N/A	Open spaces or through any non fire-rated construction	3M Duct Wrap 615+ Single Layer	-/120/120	Ducts up to 1250 x 1000mm	BRANZ FAR4812	FC232
Ducts, Internal or External Fire	Wall	Plasterboard or Concrete	3M Duct Wrap 615+ Single Layer	-/120/120	Ducts up to 1250 x 1000mm	CSIRO FCO-3273	FC230
Ducts, Internal or External Fire	Floor	Concrete	3M Duct Wrap 615+ Single Layer	-/120/120	Ducts up to 1250 x 1000mm	BRANZ FAR4812	FC231
Ducts, Internal or External Fire	Floor	Concrete	Protecta FR Damper	Up to -/180/120	Ducts up to 1000mm, round or rectangular	Warringtonfire FAS190052	FC474
Ducts, Internal or External Fire	Wall	Concrete	Protecta FR Damper	Up to -/120/120	Ducts up to 1250mm round, 1700x1200mm rectangular	Warringtonfire FAS190052	FC475
Ducts, Internal or External Fire	Wall	Plasterboard	Protecta FR Damper	Up to -/120/120	Ducts up to 1250mm round, 1700x1250mm rectangular	Warringtonfire FAS190052	FC477
Ducts, External Fire	Wall	Plasterboard or Concrete	Trafalgar FyreWrap	Up to -/180/180	Ducts up to 1200 x 1200mm	BRANZ FAR4205	FC482
Ducts, External Fire	Floor	Concrete	Trafalgar FyreWrap	Up to -/180/180	Ducts up to 1200 x 1200mm	BRANZ FAR4206	FC482
Ducts, Internal Fire	Wall	Plasterboard, Concrete or Hebel	Trafalgar FyreWrap	Up to -/120/120	Ducts up to 3600 x 3600mm	CSIRO FCO3226	FC482
HATCHES							
Inspection Hatch	Ceiling	Plasterboard from single layer 13mm	FSC Fire-rated Inspection Hatch - no framing required. All ceilings up to 60mins	Up to 60/60/60	300mm x 300mm	BRANZ FAR4709	FC81
FLUSH BOXES / SOCKET BOXES							
Flush boxes - single or back-to-back	Wall	Plasterboard from single layer 13mm	Protecta FR Putty Pad fitted to interior of box	Up to -/90/90	Up to double box 130mm x 70mm	Exova EWFA 53619700-A.2	FC152

HILTI NEW ZEALAND LTD

Manufacturer Code: HI

Level 1, Building B,
600 Great South Road,
Ellerslie, Auckland 1051Ph: 0800 444 5844
Email: servicenz@hilti.com
Website: www.hilti.co.nz

The products listed in this register have all been tested to AS1530.4-2005 or Assessed to AS 4072.1-2005 as referenced within the New Zealand Building Code.

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
BLANK OPENING						
40mm x 40mm Square Blank Opening, no services	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides, Backfilling material (Optional): Mineral Stone Wool with minimum density of 100kg/m ³ "	-/120/120	"Blank opening: max. 40mm x 40mm or circular opening of equivalent size Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
150mm x 150mm Square Blank Opening, no services	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Backfilling material: Mineral Stone Wool with minimum density of 100kg/m ³ . (Tightly compressed, Min. Thickness 50mm)"	-/120/120	"Blank opening: max. 150mm x 150mm or circular opening of equivalent size Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Blank seal / Empty Speed sleeve	Wall	Plaster Board Wall; lined with min. 2 x 16mm Fire Rated Plasterboard on each side of stud	"Hilti CFS-SL S Speed Sleeve + Hilti CFS-S ACR sealant around sleeve on each side of wall"	-/120/120	"Opening Size: 63 -76mm OD Annular Seal Depth min. 20mm. (See Report Ref. for full installation details)"	Branz Appraisal No. 813 (2013)
Blank seal / Empty Speed sleeve	Wall	Plaster Board Wall; lined with min. 2 x 13mm Fire Rated Plasterboard on each side of stud	"Hilti CFS-SL S Speed Sleeve + Hilti CFS-S ACR sealant around sleeve on each side of wall"	-/120/60	"Opening Size: 63 -76mm OD Annular Seal Depth min. 20mm. (See Report Ref. for full installation details)"	Branz Appraisal No. 813 (2013)
Blank seal / Empty Speed sleeve	Wall	Plaster Board Wall; lined with min. 2 x 16mm Fire Rated Plasterboard on each side of stud	"Hilti CFS-SL M Speed Sleeve + Hilti CFS-S ACR sealant around sleeve on each side of wall"	-/120/120	"Opening Size: 113 -122mm OD Annular Seal Depth min. 20mm (See Report Ref. for full installation details)"	Branz Appraisal No. 813 (2013)
Blank seal / Empty Speed sleeve	Wall	Plaster Board Wall; lined with min. 2 x 13mm Fire Rated Plasterboard on each side of stud	"Hilti CFS-SL M Speed Sleeve + Hilti CFS-S ACR sealant around sleeve on each side of wall"	-/120/60	"Opening Size: 113 -122mm OD Annular Seal Depth min. 20mm (See Report Ref. for full installation details)"	Branz Appraisal No. 813 (2013)
Blank Opening, no services	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	Hilti Firestop Plug CFS-PL	-/120/120	"Blank opening size: 52mm ≤ Ø ≤ 202mm with or without uPVC conduit sleeve Min. seal thickness: 150mm Wall cavity insulation: Mineral Stone Wool with Min. thickness: 50mm, Min. density: 100kg/m ³ (See Report Ref. for full installation details)"	EWFA RIR 27937400.1

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
BLANK OPENING						
Blank Opening, no services	Wall	Plaster Board Wall; ; lined with min. 1 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm (+ Aperture Beading))	Hilti Firestop Cable Collar CFS-CC	-/60/60	"Min. seal thickness: 200mm Max. blank opening size: 108mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Stone Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100
Blank Opening, no services	Wall	Plaster Board Wall; ; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	Hilti Firestop Cable Collar CFS-CC	-/120/120	"Min. seal thickness: 200mm Max. blank opening size: 108mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Stone Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100
Blank Opening	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX	-/120/120	"Max. opening area: 400mm x 400mm or equivalent surface area of 0.16m2 or max. diameter ≤ 400mm Min. seal thickness: 150mm (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Blank Opening	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Flexible Firestop Foam CFS-F FX for full seal depth If necessary, Aperture Beading: 13mm or 16mm Fire Grade Plasterboard each side of stud"	-/120/120	"Max. opening area: 400mm x 400mm or equivalent surface area of 0.16m2 or max. diameter ≤ 400mm Min. seal thickness: 150mm (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Blank Opening, no services	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL If necessary, Aperture Beading: 13mm or 16mm Fire Grade Plasterboard each side of stud "	-/120/120	"Max. opening size: 1000mm x 1000mm Wall cavity filled with Mineral Stone Wool (Min. thickness 50mm, Density 100kg/m3) OR Aperture lined with Fire Rated Plasterboard each side of stud as required. Min. seal thickness: 200mm (See Report Ref. for full installation details)"	EWFA RIR 28870-02
40mm x 40mm Square Blank Opening, no services	Wall	Rigid Wall; Concrete / Solid or Hollow Masonry (Min. Wall Thickness 75mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides, Backfilling material (Optional): Mineral Stone Wool with minimum density of 100kg/m3"	-/120/120	"Blank opening: max. 40mm x 40mm or circular opening of equivalent size Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
40mm x 40mm Square Blank Opening, no services	Wall	Rigid Wall; Concrete / Solid or Hollow Masonry (Min. Wall Thickness 150mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides, Backfilling material (Optional): Mineral Stone Wool with minimum density of 100kg/m3"	-/120/120	"Blank opening: max. 40mm x 40mm or circular opening of equivalent size Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
150mm x 150mm Square Blank Opening, no services	Wall	Rigid Wall; Concrete / Solid or Hollow Masonry (Min. Wall Thickness 75mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Backfilling material: Mineral Stone Wool with minimum density of 100kg/m3. (Tightly compressed, Min. Thickness 50mm)"	-/120/120	"Blank opening: max. 150mm x 150mm or circular opening of equivalent size Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
BLANK OPENING						
150mm x 150mm Square Blank Opening, no services	Wall	Rigid Wall; Concrete / Solid or Hollow Masonry (Min. Wall Thickness 150mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Backfilling material: Mineral Stone Wool with minimum density of 100kg/m ³ . (Tightly compressed, Min. Thickness 50mm)"	-/120/120	"Blank opening: max. 150mm x 150mm or circular opening of equivalent size Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Blank seal / Empty Speed sleeve	Wall	Rigid Wall; Concrete / Masonry Wall (Min. Thickness 100mm)	"Hilti CFS-SL S Speed Sleeve + Hilti CFS-S ACR sealant around sleeve on each side of wall"	-/120/120	"Opening Size: 63 -76mm OD Annular Seal Depth min. 20mm Max. wall thickness: 200mm (See Report Ref. for full installation details)"	Branz Appraisal No. 813 (2013)
Blank seal / Empty Speed sleeve	Wall	Rigid Wall; Concrete / Masonry Wall (Min. Thickness 100mm)	"Hilti CFS-SL M Speed Sleeve + Hilti CFS-S ACR sealant around sleeve on each side of wall"	-/120/120	"Opening Size: 113 -122mm OD Annular Seal Depth min. 20mm Max. wall thickness: 200mm (See Report Ref. for full installation details)"	Branz Appraisal No. 813 (2013)
Blank Opening, no services	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 75mm (+ Aperture Beading))	Hilti Firestop Plug CFS-PL	-/120/120	"Blank opening size: 52mm ≤ Ø ≤ 202mm with or without uPVC conduit sleeve Min. seal thickness: 150mm Wall cavity insulation: Mineral Stone Wool with Min. thickness: 50mm, Min. density: 100kg/m ³ (See Report Ref. for full installation details)"	EWFA RIR 27937400.1
Blank Opening, no services	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 75mm (+ Aperture Beading))	Hilti Firestop Cable Collar CFS-CC	-/120/120	"Min. seal thickness: 200mm Max. blank opening size: 108mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Blank Opening	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Solid or Hollow Masonry (Min. Wall Thickness 75mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX	-/120/120	"Max. opening area: 400mm x 400mm or equivalent surface area of 0.16m ² or max. diameter ≤ 400mm Min. seal thickness: 150mm (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Blank Opening, no services	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL"	-/120/120	"Max. opening size: 1000mm x 1000mm Wall cavity filled with Mineral Stone Wool (Min. thickness 50mm, Density 100kg/m ³) OR Aperture lined with Fire Rated Plasterboard each side of stud as required. Min. seal thickness: 200mm (See Report Ref. for full installation details)"	EWFA RIR 28870-02
150mm x 150mm Square Blank Opening, no services	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Intumescent Sealant CP 611A on topside + Backfilling material: Mineral Stone Wool with minimum density of 100kg/m ³ . (Tightly compressed, Min. Thickness 95mm)"	-/120/120	"Blank opening: max. 150mm x 150mm or circular opening of equivalent size Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
150mm x 150mm Square Blank Opening, no services	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Intumescent Sealant CP 611A on topside + Backfilling material: Mineral Stone Wool with minimum density of 100kg/m ³ . (Tightly compressed, Min. Thickness 125mm)"	-/120/120	"Blank opening: max. 150mm x 150mm or circular opening of equivalent size Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
BLANK OPENING						
Blank seal / Empty sleeve	Floor	Rigid Floor; Concrete Floor (Min. Floor Thickness 150mm)	"Hilti CFS-SL S Speed Sleeve + Hilti CFS-S ACR sealant around sleeve on each side of wall"	-/120/120	"Opening Size: 63 -76mm Annular Seal Depth min. 20mm Max. wall thickness: 200mm (See Report Ref. for full installation details)"	Branz Appraisal No. 813 (2013)
Blank seal / Empty sleeve	Floor	Rigid Floor; Concrete Floor (Min. Floor Thickness 150mm)	"Hilti CFS-SL M Speed Sleeve + Hilti CFS-S ACR sealant around sleeve on each side of wall"	-/120/120	"Opening Size: 113 -122mm Annular Seal Depth min. 20mm Max. wall thickness: 200mm (See Report Ref. for full installation details)"	Branz Appraisal No. 813 (2013)
Blank Opening	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX for full seal depth	-/120/120	"Min. seal thickness: 150mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Blank Opening, no services	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	Hilti Firestop Plug CFS-PL	-/120/120	"Min. seal thickness: 150mm Blank opening size: 52mm ≤ Ø ≤ 202mm, with or without uPVC conduit sleeve (See Report Ref. for full installation details)"	EWFA RIR 27937400.1
Blank Opening, no services	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	Hilti Firestop Cable Collar CFS-CC on each side	-/120/120	"Max. blank opening size: 108mm Min. seal thickness: 250mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Blank Opening, no services	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	Hilti Firestop Cable Collar CFS-CC on underside only	-/120/120	"Max. blank opening size: 108mm Min. seal thickness: 250mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side Gap fully filled with Hilti Mortar CP 636 in the upper part of the collar (See Report Ref. for full installation details)"	EWFA RIR 38022100
Blank Opening	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX for full seal depth	-/120/120	"Max. opening area: 400mm x 400mm or equivalent surface area of 0.16m ² or max. diameter ≤ 400mm Min. seal thickness: 150mm (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Blank Opening without support	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL"	-/120/60	"Max. opening size: 1000mm x 700mm Min. seal thickness: 200mm (See Report Ref. for full installation details)"	EWFA RIR 28870-02
Blank Opening, without Support	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL"	-/120/120	"Max. opening size: 500mm x 700mm Min. seal thickness: 200mm (See Report Ref. for full installation details)"	EWFA RIR 28870-02
Blank Opening with support	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL"	-/120/120	"Max. opening size: 1000mm x 1000mm Min. seal thickness: 200mm (See Report Ref. for full installation details)"	EWFA RIR 28870-02

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED NON-COMBUSTIBLE PIPES						
"Copper or Ferrous (steel and iron) pipes Ø100-125mm × 1.42mm (min.) Ø125-150mm × 1.63mm (min.) "	Wall	4hr Rigid Wall; 230mm Thick Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 230mm (Including Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod	-/240/-	"Annular gap width: 5mm to 20mm Min. seal thickness: 230mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03
"Copper, Ferrous or Brass pipes Up to Ø65mm × 0.91mm (min.) Ø80-100mm × 1.22mm (min.) "	Wall	4hr Rigid Wall; 230mm Thick Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 230mm (Including Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod	-/240/-	"Annular gap width: 5mm to 20mm Min. seal thickness: 230mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03
"Copper, Ferrous or Brass pipes Up to Ø65mm × 0.91mm (min.) Ø80-100mm × 1.22mm (min.) "	Wall	4hr Rigid Wall; 230mm Thick Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 230mm (Including Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod + Protective insulation: 38mm or 50mm Bradford Fibertex 450 Rockwool for 600mm each side of the wall. Note: Insulation should not be sustained through the wall.	-/240/120	"Annular gap width: 5mm to 20mm Min. seal thickness: 230mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03
"Copper or Ferrous (steel and iron) pipes Ø100-125mm × 1.42mm (min.) Ø125-150mm × 1.63mm (min.) "	Wall	4hr Rigid Wall; 230mm Thick Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 230mm (Including Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod + Protective insulation: 38mm or 50mm Bradford Fibertex 450 Rockwool for 600mm each side of the wall. Note: Insulation should not be sustained through the wall.	-/240/120	"Annular gap width: 5mm to 20mm Min. seal thickness: 230mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03
"Copper, Ferrous or Brass pipes Up to Ø65mm × 0.91mm (min.) Ø80-100mm × 1.22mm (min.) "	Wall	2hr Rigid Wall; 150mm Thick Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 150mm (Including Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod	-/120/-	"Annular gap width: 5mm to 20mm Min. seal thickness: 150mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03
"Copper or Ferrous (steel and iron) pipes Ø100-125mm × 1.42mm (min.) Ø125-150mm × 1.63mm (min.) "	Wall	2hr Rigid Wall; 150mm Thick Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 150mm (Including Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod	-/120/-	"Annular gap width: 5mm to 20mm Min. seal thickness: 150mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03
"Copper, Ferrous or Brass pipes Up to Ø65mm × 0.91mm (min.) Ø80-100mm × 1.22mm (min.) "	Wall	2hr Rigid Wall; 150mm Thick Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 150mm (Including Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod + Protective insulation: 38mm or 50mm Bradford Fibertex 450 Rockwool for 600mm each side of the wall. Note: Insulation should not be sustained through the wall.	-/120/120	"Annular gap width: 5mm to 20mm Min. seal thickness: 150mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03
"Copper or Ferrous (steel and iron) pipes Ø100-125mm × 1.42mm (min.) Ø125-150mm × 1.63mm (min.) "	Wall	2hr Rigid Wall; 150mm Thick Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 150mm (Including Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod + Protective insulation: 38mm or 50mm Bradford Fibertex 450 Rockwool for 600mm each side of the wall. Note: Insulation should not be sustained through the wall opening.	-/120/120	"Annular gap width: 5mm to 20mm Min. seal thickness: 150mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED NON-COMBUSTIBLE PIPES						
"Copper, Ferrous or Brass pipes Up to Ø65mm × 0.91mm (min.) Ø80-100mm × 1.22mm (min.) "	Wall	2hr Rigid Wall; Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 100mm (Including Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod + Protective insulation: 38mm or 50mm Bradford Fibertex 450 Rockwool for 600mm each side of the wall. Note: Insulation should not be sustained through the wall.	-/120/120	"Annular gap width: 5mm to 20mm Min. seal thickness: 100mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03
"Copper or Ferrous (steel and iron) pipes Ø100-125mm × 1.42mm (min.) Ø125-150mm × 1.63mm (min.) "	Wall	2hr Rigid Wall; Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 100mm (Including Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod + Protective insulation: 38mm or 50mm Bradford Fibertex 450 Rockwool for 600mm each side of the wall. Note: Insulation should not be sustained through the wall.	-/120/120	"Annular gap width: 5mm to 20mm Min. seal thickness: 100mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03
"Copper, Ferrous or Brass pipes Up to Ø65mm × 0.91mm (min.) Ø80-100mm × 1.22mm (min.) "	Wall	1.5hr Rigid Wall; 150mm Thick Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 150mm (+ Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod	-/90/-	"Annular gap width: 5mm to 20mm Min. seal thickness: 150mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03
"Copper or Ferrous (steel and iron) pipes Ø100-125mm × 1.42mm (min.) Ø125-150mm × 1.63mm (min.) "	Wall	1.5hr Rigid Wall; 150mm Thick Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 150mm (+ Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod	-/90/-	"Annular gap width: 5mm to 20mm Min. seal thickness: 150mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03
"Copper, Ferrous or Brass pipes Up to Ø65mm × 0.91mm (min.) Ø80-100mm × 1.22mm (min.) "	Wall	1.5hr Rigid Wall; 150mm Thick Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 150mm (+ Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod + Protective insulation: 38mm or 50mm Bradford Fibertex 450 Rockwool for 600mm each side of the wall. Note: Insulation should not be sustained through the wall.	-/90/90	"Annular gap width: 5mm to 20mm Min. seal thickness: 150mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03
"Copper or Ferrous (steel and iron) pipes Ø100-125mm × 1.42mm (min.) Ø125-150mm × 1.63mm (min.) "	Wall	1.5hr Rigid Wall; 150mm Thick Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 150mm (+ Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod + Protective insulation: 38mm or 50mm Bradford Fibertex 450 Rockwool for 600mm each side of the wall. Note: Insulation should not be sustained through the wall.	-/90/90	"Annular gap width: 5mm to 20mm Min. seal thickness: 150mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03
"Copper, Ferrous or Brass pipes Up to Ø65mm × 0.91mm (min.) Ø80-100mm × 1.22mm (min.) "	Wall	1.5hr Rigid Wall; 150mm Thick Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 100mm (+ Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod + Protective insulation: 38mm or 50mm Bradford Fibertex 450 Rockwool for 600mm each side of the wall. Note: Insulation should not be sustained through the wall.	-/90/90	"Min. seal thickness: 100mm Min. depth of sealant: 20mm Annular gap width: 5mm to 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03
"Copper or Ferrous (steel and iron) pipes Ø100-125mm × 1.42mm (min.) Ø125-150mm × 1.63mm (min.) "	Wall	1.5hr Rigid Wall; 150mm Thick Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 100mm (+ Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod + Protective insulation: 38mm or 50mm Bradford Fibertex 450 Rockwool for 600mm each side of the wall. Note: Insulation should not be sustained through the wall.	-/90/90	"Annular gap width: 5mm to 20mm Min. seal thickness: 100mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03
"Copper, Ferrous or Brass pipes Up to Ø65mm × 0.91mm (min.) Ø80-100mm × 1.22mm (min.) "	Wall	1hr Rigid Wall; 75mm Thick Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 75mm (+ Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod	-/60/-	"Min. seal thickness: 75mm Min. depth of sealant: 20mm Annular gap width: 5mm to 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED NON-COMBUSTIBLE PIPES						
"Copper or Ferrous (steel and iron) pipes Ø100-125mm × 1.42mm (min.) Ø125-150mm × 1.63mm (min.)"	Wall	1hr Rigid Wall; 75mm Thick Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 75mm (+ Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod	-/60/-	"Annular gap width: 5mm to 20mm Min. seal thickness: 75mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03
"Copper, Ferrous or Brass pipes Up to Ø65mm × 0.91mm (min.) Ø80-100mm × 1.22mm (min.)"	Wall	1hr Rigid Wall; 75mm Thick Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 75mm (+ Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod + Protective insulation: 38mm or 50mm Bradford Fibertex 450 Rockwool for 600mm each side of the wall. Note: Insulation should not be sustained through the wall.	-/60/60	"Annular gap width: 5mm to 20mm Min. seal thickness: 75mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03
"Copper or Ferrous (steel and iron) pipes Ø100-125mm × 1.42mm (min.) Ø125-150mm × 1.63mm (min.)"	Wall	1hr Rigid Wall; 75mm Thick Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 75mm (+ Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod + Protective insulation: 38mm or 50mm Bradford Fibertex 450 Rockwool for 600mm each side of the wall. Note: Insulation should not be sustained through the wall.	-/60/60	"Annular gap width: 5mm to 20mm Min. seal thickness: 75mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03
"Copper, Ferrous or Brass pipes Up to Ø65mm × 0.91mm (min.) Ø80-100mm × 1.22mm (min.)"	Wall	1.5hr Plaster Board Wall; lined with min. 2 x 13mm or min. 1 x 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 150mm (+ Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod	-/90/-	"Annular gap width: 5mm to 20mm Min. seal thickness: 150mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03
"Copper or Ferrous (steel and iron) pipes Ø100-125mm × 1.42mm (min.) Ø125-150mm × 1.63mm (min.)"	Wall	1.5hr Plaster Board Wall; lined with min. 2 x 13mm or min. 1 x 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 150mm (+ Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod	-/90/-	"Annular gap width: 5mm to 20mm Min. seal thickness: 150mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03
"Copper, Ferrous or Brass pipes Up to Ø65mm × 0.91mm (min.) Ø80-100mm × 1.22mm (min.)"	Wall	1.5hr Plaster Board Wall; lined with min. 2 x 13mm or min. 1 x 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 150mm (+ Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod + Protective insulation: 38mm or 50mm Bradford Fibertex 450 Rockwool for 600mm each side of the wall. Note: Insulation should not be sustained through the wall.	-/90/90	"Annular gap width: 5mm to 20mm Min. seal thickness: 150mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03
"Copper or Ferrous (steel and iron) pipes Ø100-125mm × 1.42mm (min.) Ø125-150mm × 1.63mm (min.)"	Wall	1.5hr Plaster Board Wall; lined with min. 2 x 13mm or min. 1 x 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 150mm (+ Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod + Protective insulation: 38mm or 50mm Bradford Fibertex 450 Rockwool for 600mm each side of the wall. Note: Insulation should not be sustained through the wall.	-/90/90	"Annular gap width: 5mm to 20mm Min. seal thickness: 150mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03
"Copper, Ferrous or Brass pipes Up to Ø65mm × 0.91mm (min.) Ø80-100mm × 1.22mm (min.)"	Wall	1.5hr Plaster Board Wall; lined with min. 2 x 13mm or min. 1 x 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod + Protective insulation: 38mm or 50mm Bradford Fibertex 450 Rockwool for 600mm each side of the wall. Note: Insulation should not be sustained through the wall.	-/90/90	"Annular gap width: 5mm to 20mm Min. seal thickness: 100mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03
"Copper or Ferrous (steel and iron) pipes Ø100-125mm × 1.42mm (min.) Ø125-150mm × 1.63mm (min.)"	Wall	1.5hr Plaster Board Wall; lined with min. 2 x 13mm or min. 1 x 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod + Protective insulation: 38mm or 50mm Bradford Fibertex 450 Rockwool for 600mm each side of the wall. Note: Insulation should not be sustained through the wall.	-/90/90	"Annular gap width: 5mm to 20mm Min. seal thickness: 100mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED NON-COMBUSTIBLE PIPES						
"Copper, Ferrous or Brass pipes Up to Ø65mm × 0.91mm (min.) Ø80-100mm × 1.22mm (min.) "	Wall	1hr Plaster Board Wall; lined with min. 2 x 13mm or min. 1 x 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 75mm (Including Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod	-/60/-	"Annular gap width: 5mm to 20mm Min. seal thickness: 75mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03
"Copper or Ferrous (steel and iron) pipes Ø100-125mm × 1.42mm (min.) Ø125-150mm × 1.63mm (min.) "	Wall	1hr Plaster Board Wall; lined with min. 2 x 13mm or min. 1 x 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 75mm Including Aperture Beading)	Hilti CP 606 Acrylic Sealant + PE foam backing rod	-/60/-	"Annular gap width: 5mm to 20mm Min. seal thickness: 75mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03
"Copper, Ferrous or Brass pipes Up to Ø65mm × 0.91mm (min.) Ø80-100mm × 1.22mm (min.) "	Wall	1hr Plaster Board Wall; lined with min. 2 x 13mm or min. 1 x 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 75mm (including Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod + Protective insulation: 38mm or 50mm Bradford Fibertex 450 Rockwool for 600mm each side of the wall. Note: Insulation should not be sustained through the wall.	-/60/60	"Annular gap width: 5mm to 20mm Min. seal thickness: 75mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28418-03
"Copper or Ferrous (steel and iron) pipes Ø100-125mm × 1.42mm (min.) Ø125-150mm × 1.63mm (min.) "	Wall	1hr Flexible Wall; lined with min. 2 x 13mm or min. 1 x 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 75mm (Including Aperture Beading))	Hilti CP 606 Acrylic Sealant + PE foam backing rod + Protective insulation: 38mm or 50mm Bradford Fibertex 450 Rockwool for 600mm each side of the wall. Note: Insulation should not be sustained through the wall.	-/60/60	"Annular gap width: 5mm to 20mm Min. seal thickness: 75mm Min. depth of sealant: 20mm (See Report Ref. for full installation details)"	EWFR RIR 28418-03
INSULATED NON-COMBUSTIBLE PIPES						
Ø22mm × 1mm Copper Pipe, insulated with 20mm thick Stonewool	Wall	1hr Plaster Board Wall; lined with min. 1 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A Insulation: 20mm thick Rockwool RS800 continuous through the seal with 200mm extension on each side "	-/60/60	"Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side. For timber stud wall: Wall cavity filled with Mineral Stone Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100
Ø22mm × 1mm Copper Pipe, insulated with 20mm thick Stonewool	Wall	2hr Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A Insulation: 20mm thick Rockwool RS800 continuous through the seal with 200mm extension on each side "	-/120/90	"Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side. For timber stud wall: Wall cavity filled with Mineral Stone Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
Ø22mm × 1mm Copper Pipe, insulated with 20mm thick Stonewool	Wall	2hr Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 75mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A Insulation: 20mm thick Rockwool RS800 continuous through the seal with 200mm extension on each side "	-/120/90	"Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side. For timber stud wall: Wall cavity filled with Mineral Stone Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100
Ø22mm × 1mm Copper Pipe, insulated with 20mm thick Stonewool	Floor	2hr Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A Insulation: 20mm thick Rockwool RS800 continuous through the seal with 200mm extension on each side "	-/120/120	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Ø22mm × 1mm Copper Pipe, insulated with 20mm thick Stonewool	Floor	2hr Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC on underside only + Hilti Firestop Intumescent Sealant CP 611A on underside only Insulation: 20mm thick Rockwool RS800 continuous through the seal with 200mm extension on each side"	-/120/120	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
10mm ≤ Ø ≤ 22mm Copper Pipe insulated with Butyl Based Elastomeric Foam Insulation (7.5mm ≤ Ø ≤ 32mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 22mm Copper Pipe insulated with Butyl Based Elastomeric Foam Insulation (7.5mm ≤ Ø ≤ 32mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX "	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Copper Pipe insulated with Butyl Based Elastomeric Foam Insulation (8mm ≤ Ø ≤ 36.5mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/60/60	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
18mm ≤ Ø ≤ 42mm Copper Pipe insulated with Butyl Based Elastomeric Foam Insulation (8mm ≤ Ø ≤ 36.5mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/60/60	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Copper Pipe insulated with Butyl Based Elastomeric Foam Insulation (8mm ≤ Ø ≤ 36.5mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Additional protection thickness: 19mm Additional protection length: 250mm (LI) local interrupted Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Copper Pipe insulated with Butyl Based Elastomeric Foam Insulation (8mm ≤ Ø ≤ 36.5mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Min. final penetration seal thickness: 150mm Additional protection thickness: 19mm Additional protection length: 250mm (LI) local interrupted Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX for full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Copper Pipe insulated with Butyl Based Elastomeric Foam Insulation (8mm ≤ Ø ≤ 36.5mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: Beading of 2 x 13mm or 16mm Fire Rated Plasterboard"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Min. final penetration seal thickness: 150mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Copper Pipe insulated with Butyl Based Elastomeric Foam Insulation (8mm ≤ Ø ≤ 36.5mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: Beading of 2 x 13mm or 16mm Fire Rated Plasterboard"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Min. final penetration seal thickness: 150mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
22mm ≤ Ø ≤ 42mm insulated with Butyl Based Elastomeric Foam Insulation (14.5mm ≤ Ø ≤ 36.5mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
22mm ≤ Ø ≤ 42mm insulated with Butyl Based Elastomeric Foam Insulation (14.5mm ≤ Ø ≤ 36.5mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm"	EWFA RIR 30726700
10mm ≤ Ø ≤ 35mm Copper Pipe insulated with Butyl Based Elastomeric Foam Insulation (7.5mm ≤ Ø ≤ 35mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: Beading of 2 x 13mm or 16mm Fire Rated Plasterboard"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Min. final penetration seal thickness: 150mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 35mm Copper Pipe insulated with Butyl Based Elastomeric Foam Insulation (7.5mm ≤ Ø ≤ 35mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: Beading of 2 x 13mm or 16mm Fire Rated Plasterboard"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Min. final penetration seal thickness: 150mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 22mm Copper Pipe insulated with Butyl Based Elastomeric Foam Insulation (7.5mm ≤ Ø ≤ 32mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 22mm Copper Pipe insulated with Butyl Based Elastomeric Foam Insulation (7.5mm ≤ Ø ≤ 32mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Copper Pipe insulated with Butyl Based Elastomeric Foam Insulation (8mm ≤ Ø ≤ 36.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/60/60	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Copper Pipe insulated with Butyl Based Elastomeric Foam Insulation (8mm ≤ Ø ≤ 36.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/60/60	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
18mm ≤ Ø ≤ 42mm Copper Pipe insulated with Butyl Based Elastomeric Foam Insulation (8mm ≤ Ø ≤ 36.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Additional protection thickness: 19mm Additional protection length: 250mm (LI) local interrupted Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Copper Pipe insulated with Butyl Based Elastomeric Foam Insulation (8mm ≤ Ø ≤ 36.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Additional protection thickness: 19mm Additional protection length: 250mm (LI) local interrupted Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX for full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Copper Pipe insulated with Butyl Based Elastomeric Foam Insulation (8mm ≤ Ø ≤ 36.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: Beading of 2 x 13mm or 16mm Fire Rated Plasterboard"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Min. final penetration seal thickness: 150mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Copper Pipe insulated with Butyl Based Elastomeric Foam Insulation (8mm ≤ Ø ≤ 36.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: Beading of 2 x 13mm or 16mm Fire Rated Plasterboard"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Min. final penetration seal thickness: 150mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
22mm ≤ Ø ≤ 42mm insulated with Butyl Based Elastomeric Foam Insulation (14.5mm ≤ Ø ≤ 36.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
22mm ≤ Ø ≤ 42mm insulated with Butyl Based Elastomeric Foam Insulation (14.5mm ≤ Ø ≤ 36.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
10mm ≤ Ø ≤ 35mm Copper Pipe insulated with Butyl Based Elastomeric Foam Insulation (7.5mm ≤ Ø ≤ 35mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: Beading of 2 x 13mm or 16mm Fire Rated Plasterboard"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Min. final penetration seal thickness: 150mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 35mm Copper Pipe insulated with Butyl Based Elastomeric Foam Insulation (7.5mm ≤ Ø ≤ 35mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: Beading of 2 x 13mm or 16mm Fire Rated Plasterboard"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Min. final penetration seal thickness: 150mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 22mm Steel Pipe with Elastomeric Combustible Insulation (7.5mm ≤ Ø ≤ 32mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 22mm Steel Pipe with Elastomeric Combustible Insulation (7.5mm ≤ Ø ≤ 32mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Steel Pipe with Elastomeric Combustible Insulation (8mm ≤ Ø ≤ 36.5mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/60/60	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Steel Pipe with Elastomeric Combustible Insulation (8mm ≤ Ø ≤ 36.5mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/60/60	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Copper Pipe with Elastomeric Combustible Insulation (8mm ≤ Ø ≤ 36.5mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Additional protection thickness: 19mm Additional protection length: 250mm (LI) local interrupted Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
18mm ≤ Ø ≤ 42mm Copper Pipe with Elastomeric Combustible Insulation (8mm ≤ Ø ≤ 36.5mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Additional protection thickness: 19mm Additional protection length: 250mm (LI) local interrupted Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX for full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
22mm ≤ Ø ≤ 42mm Steel Pipe with Elastomeric Combustible Insulation (14.5mm ≤ Ø ≤ 36.5mm)	Wall	Plaster Board Wall; ; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
22mm ≤ Ø ≤ 42mm Steel Pipe with Elastomeric Combustible Insulation (14.5mm ≤ Ø ≤ 36.5mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX "	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
42.4mm ≤ Ø ≤ 76mm Steel Pipe with Elastomeric Combustible Insulation (16.5mm ≤ Ø ≤ 40.5mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1.4mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
42.4mm ≤ Ø ≤ 76mm Steel Pipe with Elastomeric Combustible Insulation (16.5mm ≤ Ø ≤ 40.5mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX "	-/90/90	"Pipe wall thickness: 1.4mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10.2mm ≤ Ø ≤ 76mm Steel Pipe with Elastomeric Combustible Insulation (7.5mm ≤ Ø ≤ 40.5mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Additional protection thickness: 19mm Additional protection length: 250mm (LI) local interrupted Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10.2mm ≤ Ø ≤ 76mm Steel Pipe with Elastomeric Combustible Insulation (7.5mm ≤ Ø ≤ 40.5mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Additional protection thickness: 19mm Additional protection length: 250mm (LI) local interrupted Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX for full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
76mm ≤ Ø ≤ 159mm Steel Pipe with Elastomeric Combustible Insulation (40.5mm ≤ Ø ≤ 45mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1.8mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
76mm ≤ Ø ≤ 159mm Steel Pipe with Elastomeric Combustible Insulation (40.5mm ≤ Ø ≤ 45mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/90/90	"Pipe wall thickness: 1.8mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10.2mm ≤ Ø ≤ 60mm Steel Pipe with Elastomeric Combustible Insulation (7.5mm ≤ Ø ≤ 39mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: Beading of 2 x 13mm or 16mm Fire Rated Plasterboard"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Min. final penetration seal thickness: 150mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10.2mm ≤ Ø ≤ 60mm Steel Pipe with Elastomeric Combustible Insulation (7.5mm ≤ Ø ≤ 39mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: Beading of 2 x 13mm or 16mm Fire Rated Plasterboard"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Min. final penetration seal thickness: 150mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 22mm Steel Pipe with Elastomeric Combustible Insulation (7.5mm ≤ Ø ≤ 33.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 22mm Steel Pipe with Elastomeric Combustible Insulation (7.5mm ≤ Ø ≤ 33.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Steel Pipe with Elastomeric Combustible Insulation (8mm ≤ Ø ≤ 36.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/60/60	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
18mm ≤ Ø ≤ 42mm Steel Pipe with Elastomeric Combustible Insulation (8mm ≤ Ø ≤ 36.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/60/60	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Steel Pipe with Elastomeric Combustible Insulation (8mm ≤ Ø ≤ 36.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Additional protection thickness: 19mm Additional protection length: 250mm (L) local interrupted Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Steel Pipe with Elastomeric Combustible Insulation (8mm ≤ Ø ≤ 36.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Additional protection thickness: 19mm Additional protection length: 250mm (L) local interrupted Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX for full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
22mm ≤ Ø ≤ 42mm Steel Pipe with Elastomeric Combustible Insulation (14.5mm ≤ Ø ≤ 36.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
22mm ≤ Ø ≤ 42mm Steel Pipe with Elastomeric Combustible Insulation (14.5mm ≤ Ø ≤ 36.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
42.4mm ≤ Ø ≤ 76mm Steel Pipe with Elastomeric Combustible Insulation (16.5mm ≤ Ø ≤ 40.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
42.4mm $\leq \varnothing \leq$ 76mm Steel Pipe with Elastomeric Combustible Insulation (16.5mm $\leq \varnothing \leq$ 40.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/90/90	"Pipe wall thickness: 1mm $\leq \varnothing \leq$ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10.2mm $\leq \varnothing \leq$ 76mm Steel Pipe with Elastomeric Combustible Insulation (7.5mm $\leq \varnothing \leq$ 40.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm $\leq \varnothing \leq$ 14.2mm Additional protection thickness: 19mm Additional protection length: 250mm (L) local interrupted Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10.2mm $\leq \varnothing \leq$ 76mm Steel Pipe with Elastomeric Combustible Insulation (7.5mm $\leq \varnothing \leq$ 40.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm $\leq \varnothing \leq$ 14.2mm Additional protection thickness: 19mm Additional protection length: 250mm (L) local interrupted Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX for full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
76mm $\leq \varnothing \leq$ 159mm Steel Pipe with Elastomeric Combustible Insulation (40.5mm $\leq \varnothing \leq$ 45mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1mm $\leq \varnothing \leq$ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
76mm $\leq \varnothing \leq$ 159mm Steel Pipe with Elastomeric Combustible Insulation (40.5mm $\leq \varnothing \leq$ 45mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/90/90	"Pipe wall thickness: 1mm $\leq \varnothing \leq$ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10.2mm $\leq \varnothing \leq$ 60mm Steel Pipe with Elastomeric Combustible Insulation (7.5mm $\leq \varnothing \leq$ 39mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: Beading of 2 x 13mm or 16mm Fire Rated Plasterboard"	-/120/120	"Pipe wall thickness: 1mm $\leq \varnothing \leq$ 14.2mm Min. final penetration seal thickness: 150mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
10.2mm ≤ Ø ≤ 60mm Steel Pipe with Elastomeric Combustible Insulation (7.5mm ≤ Ø ≤ 39mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: Beading of 2 x 13mm or 16mm Fire Rated Plasterboard"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Min. final penetration seal thickness: 150mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 42mm Copper Pipe with Elastomeric Combustible Insulation (7.5mm ≤ Ø ≤ 36.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 200mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 42mm Copper Pipe with Elastomeric Combustible Insulation (7.5mm ≤ Ø ≤ 36.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 200mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 35mm Copper Pipe with Elastomeric Combustible Insulation (7.5mm ≤ Ø ≤ 35mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 200mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 35mm Copper Pipe with Elastomeric Combustible Insulation (7.5mm ≤ Ø ≤ 35mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 200mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 60mm Steel Pipe with Elastomeric Combustible Insulation (7.5mm ≤ Ø ≤ 33.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 200mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 60mm Steel Pipe with Elastomeric Combustible Insulation (7.5mm ≤ Ø ≤ 33.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 200mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
76mm ≤ Ø ≤ 159mm Steel Pipe with Elastomeric Combustible Insulation (8mm ≤ Ø ≤ 36.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 200mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1.8mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
76mm ≤ Ø ≤ 159mm Steel Pipe with Elastomeric Combustible Insulation (8mm ≤ Ø ≤ 36.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 200mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/90/90	"Pipe wall thickness: 1.8mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
Ø 159mm Steel Pipe with Elastomeric Combustible Insulation (14.5mm ≤ Ø ≤ 36.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 200mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/120/120	"Pipe wall thickness: 2mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
Ø 159mm Steel Pipe with Elastomeric Combustible Insulation (14.5mm ≤ Ø ≤ 36.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 200mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/120/120	"Pipe wall thickness: 2mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
159mm ≤ Ø ≤ 813mm Steel Pipe with Elastomeric Combustible Insulation (16.5mm ≤ Ø ≤ 40.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 200mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: Mineral Stone Wool / Rockwool Klimarock"	-/120/120	"Pipe wall thickness: 2mm ≤ Ø ≤ 14.2mm Additional protection thickness: 40mm Additional protection length: 500mm (LI) local interrupted Additional protection density: 40kg/m ³ Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
159mm ≤ Ø ≤ 813mm Steel Pipe with Elastomeric Combustible Insulation (16.5mm ≤ Ø ≤ 40.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 200mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX Additional Protection: Mineral Stone Wool / Rockwool Klimarock"	-/120/120	"Pipe wall thickness: 2mm ≤ Ø ≤ 14.2mm Additional protection thickness: 40mm Additional protection length: 500mm (LI) local interrupted Additional protection density: 40kg/m ³ Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 35mm Copper Pipe with Elastomeric Combustible Insulation (7.5mm ≤ Ø ≤ 35mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
10mm $\leq \varnothing \leq$ 35mm Copper Pipe with Elastomeric Combustible Insulation (7.5mm $\leq \varnothing \leq$ 35mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/120/120	"Pipe wall thickness: 1mm $\leq \varnothing \leq$ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
35mm $\leq \varnothing \leq$ 42mm Copper Pipe with Elastomeric Combustible Insulation (9mm $\leq \varnothing \leq$ 36.5mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/60/60	"Pipe wall thickness: 1mm $\leq \varnothing \leq$ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
35mm $\leq \varnothing \leq$ 42mm Copper Pipe with Elastomeric Combustible Insulation (9mm $\leq \varnothing \leq$ 36.5mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/60/60	"Pipe wall thickness: 1mm $\leq \varnothing \leq$ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
35mm $\leq \varnothing \leq$ 42mm Copper Pipe with Elastomeric Combustible Insulation (9mm $\leq \varnothing \leq$ 36.5mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: Mineral Stone Wool / Rockwool Klimarock"	-/120/120	"Pipe wall thickness: 1mm $\leq \varnothing \leq$ 14.2mm Additional protection thickness: 40mm Additional protection length: 250mm (LI) local interrupted Additional protection density: 40kg/m ³ Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
35mm $\leq \varnothing \leq$ 42mm Copper Pipe with Elastomeric Combustible Insulation (9mm $\leq \varnothing \leq$ 36.5mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX Additional Protection: Mineral Wool / Rockwool Klimarock"	-/120/120	"Pipe wall thickness: 1mm $\leq \varnothing \leq$ 14.2mm Additional protection thickness: 40mm Additional protection length: 250mm (LI) local interrupted Additional protection density: 40kg/m ³ Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10.2mm $\leq \varnothing \leq$ 60mm Steel Pipe with Elastomeric Combustible Insulation (7.5mm $\leq \varnothing \leq$ 39mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/120/120	"Pipe wall thickness: 1mm $\leq \varnothing \leq$ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10.2mm $\leq \varnothing \leq$ 60mm Steel Pipe with Elastomeric Combustible Insulation (7.5mm $\leq \varnothing \leq$ 39mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/120/120	"Pipe wall thickness: 1mm $\leq \varnothing \leq$ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
60mm ≤ Ø ≤ 76mm Steel Pipe with Elastomeric Combustible Insulation (9mm ≤ Ø ≤ 40.5mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
60mm ≤ Ø ≤ 76mm Steel Pipe with Elastomeric Combustible Insulation (9mm ≤ Ø ≤ 40.5mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
60mm ≤ Ø ≤ 76mm Steel Pipe with Elastomeric Combustible Insulation (9mm ≤ Ø ≤ 40.5mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: Mineral Stone Wool / Rockwool Klimarock"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Additional protection thickness: 40mm Additional protection length: 250mm (LI) local interrupted Additional protection density: 40kg/m ³ Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
60mm ≤ Ø ≤ 76mm Steel Pipe with Elastomeric Combustible Insulation (9mm ≤ Ø ≤ 40.5mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX Additional Protection: Mineral Wool / Rockwool Klimarock"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Additional protection thickness: 40mm Additional protection length: 250mm (LI) local interrupted Additional protection density: 40kg/m ³ Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
76mm ≤ Ø ≤ 108mm Steel Pipe with Elastomeric Combustible Insulation (14mm ≤ Ø ≤ 42.5mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1.8mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
76mm ≤ Ø ≤ 108mm Steel Pipe with Elastomeric Combustible Insulation (14mm ≤ Ø ≤ 42.5mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/90/90	"Pipe wall thickness: 1.8mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
10.2mm ≤ Ø ≤ 114.3mm Steel Pipe with Elastomeric Combustible Insulation (15.5mm ≤ Ø ≤ 42.5mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10.2mm ≤ Ø ≤ 114.3mm Steel Pipe with Elastomeric Combustible Insulation (15.5mm ≤ Ø ≤ 42.5mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
76mm ≤ Ø ≤ 159mm Steel Pipe with Elastomeric Combustible Insulation (9mm ≤ Ø ≤ 45mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Hilti Acrylic Sealant CFS-S ACR + Additional Protection: Mineral Wool / Rockwool Klimarock"	-/120/120	"Pipe wall thickness: 1.8mm ≤ Ø ≤ 14.2mm Additional protection thickness: 40mm Additional protection length: 250mm (LI) local interrupted Additional protection density: 40kg/m ³ Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
76mm ≤ Ø ≤ 159mm Steel Pipe with Elastomeric Combustible Insulation (9mm ≤ Ø ≤ 45mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX Additional Protection: Mineral Wool / Rockwool Klimarock"	-/120/120	"Pipe wall thickness: 1.8mm ≤ Ø ≤ 14.2mm Additional protection thickness: 40mm Additional protection length: 250mm (LI) local interrupted Additional protection density: 40kg/m ³ Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
159mm ≤ Ø ≤ 323.9mm Steel Pipe with Elastomeric Combustible Insulation (9mm ≤ Ø ≤ 25mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Hilti Acrylic Sealant CFS-S ACR + Additional Protection: Mineral Stone Wool / Rockwool Klimarock"	-/120/120	"Pipe wall thickness: 1.8mm ≤ Ø ≤ 14.2mm Additional protection thickness: 40mm Additional protection length: 500mm (LI) local interrupted Additional protection density: 40kg/m ³ Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Full Depth Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
76mm ≤ Ø ≤ 159mm Steel Pipe with Elastomeric Combustible Insulation (9.5mm ≤ Ø ≤ 45mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/60/60	"Pipe wall thickness: 2mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
76mm ≤ Ø ≤ 159mm Steel Pipe with Elastomeric Combustible Insulation (9.5mm ≤ Ø ≤ 45mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/60/60	"Pipe wall thickness: 2mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
76mm ≤ Ø ≤ 159mm Steel Pipe with Elastomeric Combustible Insulation (9.5mm ≤ Ø ≤ 45mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: Mineral Stone Wool / Rockwool Klimarock"	-/120/120	"Pipe wall thickness: 2mm ≤ Ø ≤ 14.2mm Additional protection thickness: 40mm Additional protection length: 250mm (L) local interrupted Additional protection density: 40kg/m ³ Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
76mm ≤ Ø ≤ 159mm Steel Pipe with Elastomeric Combustible Insulation (9.5mm ≤ Ø ≤ 45mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: Mineral Wool / Rockwool Klimarock"	-/120/120	"Pipe wall thickness: 2mm ≤ Ø ≤ 14.2mm Additional protection thickness: 40mm Additional protection length: 250mm (L) local interrupted Additional protection density: 40kg/m ³ Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 22mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Plasetr Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 22mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Plasetr Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Plasetr Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/60/60	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
18mm ≤ Ø ≤ 42mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Plasetr Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/60/60	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Plasetr Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Additional protection thickness: 19mm Additional protection length: 250mm (LI) local interrupted Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Plasetr Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Additional protection thickness: 19mm Additional protection length: 250mm (LI) local interrupted Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Plasetr Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Min. additional protection width: 50mm Min. final penetration seal thickness: 150mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Plasetr Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Min. additional protection width: 50mm Min. final penetration seal thickness: 150mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
22mm ≤ Ø ≤ 42mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Plasetr Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
22mm ≤ Ø ≤ 42mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Plasetr Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 35mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Plasetr Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: Beading of 2 x 13mm or 16mm Fire Rated Plasterboard"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Min. additional protection width: 50mm Min. final penetration seal thickness: 150mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 35mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Plasetr Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: Beading of 2 x 13mm or 16mm Fire Rated Plasterboard"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Min. additional protection width: 50mm Min. final penetration seal thickness: 150mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 22mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 22mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/60/60	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
18mm ≤ Ø ≤ 42mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/60/60	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Additional protection thickness: 19mm Additional protection length: 250mm (LI) local interrupted Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Additional protection thickness: 19mm Additional protection length: 250mm (LI) local interrupted Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Min. additional protection width: 50mm Min. final penetration seal thickness: 150mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Min. additional protection width: 50mm Min. final penetration seal thickness: 150mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
22mm ≤ Ø ≤ 42mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal 0mm to 15mm: Hilti Firestop Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
22mm ≤ Ø ≤ 42mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal 15mm to 50mm: Hilti Firestop Foam CFS-F FX for full depth of wall Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 35mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Min. additional protection width: 50mm Min. final penetration seal thickness: 150mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 35mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Min. additional protection width: 50mm Min. final penetration seal thickness: 150mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 22mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal 0mm to 15mm: Hilti Firestop Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 22mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/60/60	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
18mm ≤ Ø ≤ 42mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/60/60	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Additional protection thickness: 19mm Additional protection length: 250mm (LI) local interrupted Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Additional protection thickness: 19mm Additional protection length: 250mm (LI) local interrupted Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
22mm ≤ Ø ≤ 42mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
22mm ≤ Ø ≤ 42mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
42.4mm ≤ Ø ≤ 76mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1.4mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
42.4mm ≤ Ø ≤ 76mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/90/90	"Pipe wall thickness: 1.4mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10.2mm ≤ Ø ≤ 76mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Additional protection thickness: 19mm Additional protection length: 250mm (LI) local interrupted Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10.2mm ≤ Ø ≤ 76mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Additional protection thickness: 19mm Additional protection length: 250mm (LI) local interrupted Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10.2mm ≤ Ø ≤ 60mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: Beading of 2 x 13mm or 16mm Fire Rated Plasterboard"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Min. additional protection width: 50mm Min. final penetration seal thickness: 150mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10.2mm ≤ Ø ≤ 60mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: Beading of 2 x 13mm or 16mm Fire Rated Plasterboard"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Min. additional protection width: 50mm Min. final penetration seal thickness: 150mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 22mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
10mm ≤ Ø ≤ 22mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: Annular gap seal: 0mm to 15mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/60/60	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/60/60	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Additional protection thickness: 19mm Additional protection length: 250mm (LI) local interrupted Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
18mm ≤ Ø ≤ 42mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Additional protection thickness: 19mm Additional protection length: 250mm (LI) local interrupted Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
22mm ≤ Ø ≤ 42mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
22mm ≤ Ø ≤ 42mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
42.4mm ≤ Ø ≤ 76mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1.4mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
42.4mm ≤ Ø ≤ 76mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/90/90	"Pipe wall thickness: 1.4mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10.2mm ≤ Ø ≤ 76mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Additional protection thickness: 19mm Additional protection length: 250mm (LI) local interrupted Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10.2mm ≤ Ø ≤ 76mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: 19mm Armaflex AF elastomeric material for thermal insulation"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Additional protection thickness: 19mm Additional protection length: 250mm (LI) local interrupted Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10.2mm ≤ Ø ≤ 60mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: Beading of 2 x 13mm or 16mm Fire Rated Plasterboard"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Min. additional protection width: 50mm Min. final penetration seal thickness: 150mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10.2mm ≤ Ø ≤ 60mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: Beading of 2 x 13mm or 16mm Fire Rated Plasterboard"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Min. additional protection width: 50mm Min. final penetration seal thickness: 150mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 42mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 200mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
10mm ≤ Ø ≤ 42mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 200mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 35mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 200mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 35mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 200mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 60mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 200mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 60mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 200mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
76mm ≤ Ø ≤ 159mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 200mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1.8mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
76mm ≤ Ø ≤ 159mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 200mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/90/90	"Pipe wall thickness: 1.8mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
76mm ≤ Ø ≤ 159mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 200mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: Mineral Stone Wool / Rockwool Klimarock"	-/90/90	"Pipe wall thickness: 1.8mm ≤ Ø ≤ 14.2mm Additional protection thickness: 40mm Additional protection length: 250mm (LI) local interrupted Additional protection density: 40kg/m ³ Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
76mm ≤ Ø ≤ 159mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 200mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: Mineral Stone Wool / Rockwool Klimarock"	-/90/90	"Pipe wall thickness: 1.8mm ≤ Ø ≤ 14.2mm Additional protection thickness: 40mm Additional protection length: 250mm (LI) local interrupted Additional protection density: 40kg/m ³ Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
Ø 159mm Steel Pipe with Elastomeric Combustible Insulation (14.5mm ≤ Ø ≤ 36.5mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 200mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/120/120	"Pipe wall thickness: 4mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
Ø 159mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 200mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/120/120	"Pipe wall thickness: 4mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
159mm ≤ Ø ≤ 813mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 200mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: Mineral Stone Wool / Rockwool Klimarock"	-/120/120	"Pipe wall thickness: 2mm ≤ Ø ≤ 14.2mm Additional protection thickness: 40mm Additional protection length: 500mm (LI) local interrupted Additional protection density: 40kg/m ³ Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
159mm ≤ Ø ≤ 813mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 200mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: Mineral Stone Wool / Rockwool Klimarock"	-/120/120	"Pipe wall thickness: 2mm ≤ Ø ≤ 14.2mm Additional protection thickness: 40mm Additional protection length: 500mm (LI) local interrupted Additional protection density: 40kg/m ³ Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 450mm (See Report Ref. for full installation details)"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
10mm ≤ Ø ≤ 35mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + "	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10mm ≤ Ø ≤ 35mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + "	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
35mm ≤ Ø ≤ 42mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/60/60	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
35mm ≤ Ø ≤ 42mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/60/60	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
35mm ≤ Ø ≤ 42mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: Mineral Stone Wool / Rockwool Klimarock"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Additional protection thickness: 40mm Additional protection length: 250mm (L) local interrupted Additional protection density: 40kg/m ³ Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
35mm ≤ Ø ≤ 42mm Copper Pipe with Mineral Wool Insulation (Ø 40mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: Mineral Stone Wool / Rockwool Klimarock"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Additional protection thickness: 40mm Additional protection length: 250mm (L) local interrupted Additional protection density: 40kg/m ³ Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10.2mm ≤ Ø ≤ 60mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
10.2mm ≤ Ø ≤ 60mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal 15mm to 50mm: Hilti Firestop Foam CFS-F FX for full depth of floor Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
60mm ≤ Ø ≤ 76mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
60mm ≤ Ø ≤ 76mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/90/90	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
60mm ≤ Ø ≤ 76mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: Mineral Stone Wool / Rockwool Klimarock"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Additional protection thickness: 40mm Additional protection length: 250mm (LI) local interrupted Additional protection density: 40kg/m ³ Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
60mm ≤ Ø ≤ 76mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: Mineral Stone Wool / Rockwool Klimarock"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Additional protection thickness: 40mm Additional protection length: 250mm (LI) local interrupted Additional protection density: 40kg/m ³ Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
76mm ≤ Ø ≤ 108mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/90/90	"Pipe wall thickness: 1.8mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
76mm ≤ Ø ≤ 108mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/90/90	"Pipe wall thickness: 1.8mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10.2mm ≤ Ø ≤ 114.3mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
10.2mm ≤ Ø ≤ 114.3mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/120/120	"Pipe wall thickness: 1mm ≤ Ø ≤ 14.2mm Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
76mm ≤ Ø ≤ 323.9mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: Mineral Stone Wool / Rockwool Klimarock"	-/120/120	"Pipe wall thickness: 1.8mm ≤ Ø ≤ 14.2mm Additional protection thickness: 40mm Additional protection length: 250mm (LI) local interrupted Additional protection density: 40kg/m ³ Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
76mm ≤ Ø ≤ 323.9mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: Mineral Stone Wool / Rockwool Klimarock"	-/120/120	"Pipe wall thickness: 1.8mm ≤ Ø ≤ 14.2mm Additional protection thickness: 40mm Additional protection length: 250mm (LI) local interrupted Additional protection density: 40kg/m ³ Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
Ø 323.9mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: Mineral Wool / Rockwool Klimarock"	-/120/120	"Pipe wall thickness: 1.8mm ≤ Ø ≤ 14.2mm Additional protection thickness: 40mm Additional protection length: 500mm (LI) local interrupted Additional protection density: 40kg/m ³ Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
Ø 323.9mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: Mineral Stone Wool / Rockwool Klimarock"	-/120/120	"Pipe wall thickness: $1.8\text{mm} \leq \varnothing \leq 14.2\text{mm}$ Additional protection thickness: 40mm Additional protection length: 500mm (L) local interrupted Additional protection density: 40kg/m ³ Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
76mm ≤ Ø ≤ 159mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606"	-/60/60	"Pipe wall thickness: $2\text{mm} \leq \varnothing \leq 14.2\text{mm}$ Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
76mm ≤ Ø ≤ 159mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX"	-/60/60	"Pipe wall thickness: $2\text{mm} \leq \varnothing \leq 14.2\text{mm}$ Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
76mm ≤ Ø ≤ 159mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Firestop Acrylic Sealant CFS-S ACR / CP606 + Additional Protection: Mineral Stone Wool / Rockwool Klimarock"	-/120/120	"Pipe wall thickness: $2\text{mm} \leq \varnothing \leq 14.2\text{mm}$ Additional protection thickness: 40mm Additional protection length: 250mm (L) local interrupted Additional protection density: 40kg/m ³ Annular gap seal: 0mm to 15mm Hilti Sealant Depth: Thickness of wall lining Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700
76mm ≤ Ø ≤ 159mm Steel Pipe with Mineral Wool Insulation (Ø 40mm)	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Bandage CFS-B + Hilti Firestop Foam CFS-F FX + Additional Protection: Mineral Stone Wool / Rockwool Klimarock"	-/120/120	"Pipe wall thickness: $2\text{mm} \leq \varnothing \leq 14.2\text{mm}$ Additional protection thickness: 40mm Additional protection length: 250mm (L) local interrupted Additional protection density: 40kg/m ³ Annular gap seal: 15mm to 50mm Hilti Firestop Foam CFS-F FX installed to full depth of wall, additional aperture lining may be required Pipe support distance: 330mm (See Report Ref. for full installation details)"	EWFA RIR 30726700

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
Ø16mm x 1.2-2.4mm PE-X Pipe	Wall	Plaster Board Wall; lined with min. 1 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	" Hilti Firestop Intumescent Sealant CP 611A on both sides + Additional Protection 1: Hilti Firestop Collar CP 644/ CSF-C P-50/1.5 on both sides"	-/60/60	"Min. aperture diameter: Ø26mm Max. aperture diameter: Ø36mm Min. seal depth: 25mm Min. gap between edge of penetration and outside collar edge: 5mm (See Report Ref. for full installation details)"	EWFA RIR 33136700.6
Ø16mm x 1.2-2.4mm PE-X Pipe	Wall	Plaster Board Wall; lined with min. 1 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	" Hilti Firestop Intumescent Sealant CP 611A on both sides + Additional Protection 2: 1 layer of 13mm or 16mm Fire Rated Plasterboard both sides of wall"	-/60/60	"Min. aperture diameter: Ø26mm Max. aperture diameter: Ø36mm Min. seal depth: 25mm (See Report Ref. for full installation details)"	EWFA RIR 33136700.6
Ø20mm x 2.3-3.4mm PE-X Pipe	Wall	Plaster Board Wall; lined with min. 1 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	" Hilti Firestop Intumescent Sealant CP 611A on both sides + Additional Protection 1: Hilti Firestop Collar CP 644/ CSF-C P-50/1.5 on both sides"	-/60/60	"Min. aperture diameter: Ø30mm Max. aperture diameter: Ø40mm Min. seal depth: 25mm Min. gap between edge of penetration and outside collar edge: 5mm (See Report Ref. for full installation details)"	EWFA RIR 33136700.6
Ø20mm x 2.3-3.4mm PE-X Pipe	Wall	Plaster Board Wall; lined with min. 1 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	" Hilti Firestop Intumescent Sealant CP 611A on both sides + Additional Protection 2: 1 layer of 13mm or 16mm Fire Rated Plasterboard both sides of wall"	-/60/60	"Min. aperture diameter: Ø30mm Max. aperture diameter: Ø40mm Min. seal depth: 25mm (See Report Ref. for full installation details)"	EWFA RIR 33136700.6
Ø25mm x 2.8-3.9mm PE-X Pipe	Wall	Plaster Board Wall; lined with min. 1 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	" Hilti Firestop Intumescent Sealant CP 611A on both sides + Additional Protection 1: Hilti Firestop Collar CP 644/ CSF-C P-50/1.5 on both sides"	-/60/60	"Min. aperture diameter: Ø35mm Max. aperture diameter: Ø45mm Min. seal depth: 25mm Min. gap between edge of penetration and outside collar edge: 5mm (See Report Ref. for full installation details)"	EWFA RIR 33136700.6
Ø25mm x 2.8-3.9mm PE-X Pipe	Wall	Plaster Board Wall; lined with min. 1 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	" Hilti Firestop Intumescent Sealant CP 611A on both sides + Additional Protection 2: 1 layer of 13mm or 16mm Fire Rated Plasterboard both sides of wall"	-/60/60	"Min. aperture diameter: Ø35mm Max. aperture diameter: Ø45mm Min. seal depth: 25mm (See Report Ref. for full installation details)"	EWFA RIR 33136700.6
Ø16mm x 1.2-2.4mm PE-X Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm/16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	Hilti Firestop Intumescent Sealant CP 611A on both sides	-/120/120	"Min. aperture diameter: Ø26mm Max. aperture diameter: Ø36mm Min. seal depth: 25mm (See Report Ref. for full installation details)"	EWFA RIR 33136700.6
Ø16mm x 1.2-2.4mm PE-X Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm/16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Backfilling material: Mineral wool (Tightly compressed)"	-/120/120	"Min. aperture diameter: Ø36mm Max. aperture diameter: Ø150mm Min. seal depth: 25mm (See Report Ref. for full installation details)"	EWFA RIR 33136700.6
Ø20mm x 2.3-3.4mm PE-X Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm/16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	Hilti Firestop Intumescent Sealant CP 611A on both sides	-/120/120	"Min. aperture diameter: Ø30mm Max. aperture diameter: Ø40mm Min. seal depth: 25mm"	EWFA RIR 33136700.6

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
Ø20mm x 2.3-3.4mm PE-X Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm/16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Backfilling material: Mineral Stone Wool with minimum density of 100kg/m3 (Tightly compressed)"	-/120/120	"Min. aperture diameter: Ø40mm Max. aperture diameter: Ø150mm Min. seal depth: 25mm (See Report Ref. for full installation details)"	EWFA RIR 33136700.6
Ø25mm x 2.8-3.9mm PE-X Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm/16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	Hilti Firestop Intumescent Sealant CP 611A on both sides	-/120/120	"Min. aperture diameter: Ø35mm Max. aperture diameter: Ø45mm Min. seal depth: 25mm (See Report Ref. for full installation details)"	EWFA RIR 33136700.6
Ø25mm x 2.8-3.9mm PE-X Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm/16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Backfilling material: Mineral Stone Wool with minimum density of 100kg/m3 (Tightly compressed)"	-/120/120	"Min. aperture diameter: Ø45mm Max. aperture diameter: Ø150mm Min. seal depth: 25mm (See Report Ref. for full installation details)"	EWFA RIR 33136700.6
Ø16mm x 1.2-2.4mm PE-X Pipe	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Solid or Hollow Masonry (Min. Wall Thickness 75mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Additional Protection 1: Hilti Firestop Collar CP 644/ CSF-C P-50/1.5 on both sides + Additional Protection 2: 1 layer of 13mm or 16mm Fire Rated Plasterboard"	-/120/120	"Min. aperture diameter: Ø26mm Max. aperture diameter: Ø36mm Min. seal depth: 25mm Min. gap between edge of penetration and outside collar edge: 5mm (See Report Ref. for full installation details)"	EWFA RIR 33136700.6
Ø16mm x 1.2-2.4mm PE-X Pipe	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Solid or Hollow Masonry (Min. Wall Thickness 75mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + 2 x Additional Protection 2: 1 layer of 13mm or 16mm Fire Rated Plasterboard"	-/120/120	"Min. aperture diameter: Ø26mm Max. aperture diameter: Ø36mm Min. seal depth: 25mm (See Report Ref. for full installation details)"	EWFA RIR 33136700.6
Ø20mm x 2.3-3.4mm PE-X Pipe	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Solid or Hollow Masonry (Min. Wall Thickness 75mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Additional Protection 1: Hilti Firestop Collar CP 644/ CSF-C P-50/1.5 on both sides + Additional Protection 2: 1 layer of 13mm or 16mm Fire Rated Plasterboard"	-/120/120	"Min. aperture diameter: Ø30mm Max. aperture diameter: Ø40mm Min. seal depth: 25mm Min. gap between edge of penetration and outside collar edge: 5mm (See Report Ref. for full installation details)"	EWFA RIR 33136700.6
Ø20mm x 2.3-3.4mm PE-X Pipe	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Solid or Hollow Masonry (Min. Wall Thickness 75mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + 2 x Additional Protection 2: 1 layer of 13mm or 16mm Fire Rated Plasterboard"	-/120/120	"Min. aperture diameter: Ø30mm Max. aperture diameter: Ø40mm Min. seal depth: 25mm (See Report Ref. for full installation details)"	EWFA RIR 33136700.6
Ø25mm x 2.8-3.9mm PE-X Pipe	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Solid or Hollow Masonry (Min. Wall Thickness 75mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Additional Protection 1: Hilti Firestop Collar CP 644/ CSF-C P-50/1.5 on both sides + Additional Protection 2: 1 layer of 13mm or 16mm Fire Rated Plasterboard"	-/120/120	"Min. aperture diameter: Ø35mm Max. aperture diameter: Ø45mm Min. seal depth: 25mm Min. gap between edge of penetration and outside collar edge: 5mm (See Report Ref. for full installation details)"	EWFA RIR 33136700.6
Ø25mm x 2.8-3.9mm PE-X Pipe	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Solid or Hollow Masonry (Min. Wall Thickness 75mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + 2 x Additional Protection 2: 1 layer of 13mm or 16mm Fire Rated Plasterboard"	-/120/120	"Min. aperture diameter: Ø35mm Max. aperture diameter: Ø45mm Min. seal depth: 25mm (See Report Ref. for full installation details)"	EWFA RIR 33136700.6

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
Ø16mm x 1.2-2.4mm PE-X Pipe	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	Hilti Firestop Intumescent Sealant CP 611A on both sides	-/120/120	"Min. aperture diameter: Ø26mm Max. aperture diameter: Ø36mm Min. seal depth: 25mm (See Report Ref. for full installation details)"	EWFA RIR 33136700.6
Ø16mm x 1.2-2.4mm PE-X Pipe	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Backfilling material: Mineral Stone Wool with minimum density of 100kg/m3 (Tightly compressed)"	-/120/120	"Min. aperture diameter: Ø36mm Max. aperture diameter: Ø150mm Min. seal depth: 25mm (See Report Ref. for full installation details)"	EWFA RIR 33136700.6
Ø20mm x 2.3-3.4mm PE-X Pipe	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	Hilti Firestop Intumescent Sealant CP 611A on both sides	-/120/120	"Min. aperture diameter: Ø30mm Max. aperture diameter: Ø40mm Min. seal depth: 25mm (See Report Ref. for full installation details)"	EWFA RIR 33136700.6
Ø20mm x 2.3-3.4mm PE-X Pipe	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Backfilling material: Mineral Stone Wool with minimum density of 100kg/m3 (Tightly compressed)"	-/120/120	"Min. aperture diameter: Ø40mm Max. aperture diameter: Ø150mm Min. seal depth: 25mm (See Report Ref. for full installation details)"	EWFA RIR 33136700.6
Ø25mm x 2.8-3.9mm PE-X Pipe	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	Hilti Firestop Intumescent Sealant CP 611A on both sides	-/120/120	"Min. aperture diameter: Ø35mm Max. aperture diameter: Ø45mm Min. seal depth: 25mm (See Report Ref. for full installation details)"	EWFA RIR 33136700.6
Ø25mm x 2.8-3.9mm PE-X Pipe	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Backfilling material: Mineral Stone Wool with minimum density of 100kg/m3 (Tightly compressed)"	-/120/120	"Min. aperture diameter: Ø45mm Max. aperture diameter: Ø150mm Min. seal depth: 25mm (See Report Ref. for full installation details)"	EWFA RIR 33136700.6
Ø43 uPVC Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/90	"Collar Size: 50/1.5" Pipe Wall Thickness: 2mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø56 uPVC Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/120	"Collar Size: 63/2" Pipe Wall Thickness: 2.2mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
Ø69 uPVC Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/90	"Collar Size: 75/2.5" Pipe Wall Thickness: 2.7mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø85 uPVC Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/90	"Collar Size: 90/3" Pipe Wall Thickness: 2.9mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø110 uPVC Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/120	"Collar Size: 110/4" Pipe Wall Thickness: 3.2mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø160 uPVC Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/120	"Collar Size: 160/6" Pipe Wall Thickness: 4.5mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø40 PPR Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/120	"Collar Size: 50/1.5" Pipe Wall Thickness: 6mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø50 PPR Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/120	"Collar Size: 50/1.5" Pipe Wall Thickness: 6.9mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø65 PPR Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/90	"Collar Size: 75/2.5" Pipe Wall Thickness: 8.6mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø80 PPR Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/90	"Collar Size: 90/3" Pipe Wall Thickness: 10.3mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø100 PPR Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/120	"Collar Size: 110/4" Pipe Wall Thickness: 12.3mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
Ø110 PPR Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/120	"Collar Size: 110/4" Pipe Wall Thickness: 15mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø125 PPR Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/120	"Collar Size: 125/5" Pipe Wall Thickness: 19mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø40 PE-100 (HDPE) Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/120	"Collar Size: 50/1.5" Pipe Wall Thickness: 5mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø50 PE-100 (HDPE) Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/120	"Collar Size: 50/1.5" Pipe Wall Thickness: 4.6mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø65 PE-100 (HDPE) Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/90	"Collar Size: 75/2.5" Pipe Wall Thickness: 5.8mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø80 PE-100 (HDPE) Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/90	"Collar Size: 90/3" Pipe Wall Thickness: 6.8mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø100 PE-100 (HDPE) Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/120	"Collar Size: 110/4" Pipe Wall Thickness: 8.2mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø110 PE-100 (HDPE) Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/120	"Collar Size: 110/4" Pipe Wall Thickness: 12mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø125 PE-100 (HDPE) Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/120	"Collar Size: 125/5" Pipe Wall Thickness: 13mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
Ø200 PE-100 (HDPE) Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/60	"Collar Size: 200/8" Pipe Wall Thickness: 20mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø50 Raupiano Plus Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/120	"Collar Size: 50/1.5" Pipe Wall Thickness: 1.8mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø75 Raupiano Plus Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/120	"Collar Size: 75/2.5" Pipe Wall Thickness: 1.9mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø90 Raupiano Plus Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/120	"Collar Size: 90/3" Pipe Wall Thickness: 2.2mm Depth of annular gap seal: full depth of wall lining"	EWFA RIR 27006-03
Ø110 Raupiano Plus Pipe	Wall	Plaster Board Wall; lined with min. 2 x 13mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/120	"Collar Size: 110/4" Pipe Wall Thickness: 2.7mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø43 uPVC Pipe	Floor	Concrete Floor (Min. Floor Thickness 120mm)	"Hilti Firestop Collar CFS-C P fixed to one side of the floor + Annular Gap Seal: Mortar or Hilti Firestop Acrylic Selant CFS-S ACR / CP606"	-/240/240	"Collar Size: 50/1.5" Pipe Wall Thickness: 2mm Mortar Depth: Full depth of floor Sealant Depth: 20mm on underside of floor + PEF backing rod (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø56 uPVC Pipe	Floor	Concrete Floor (Min. Floor Thickness 120mm)	"Hilti Firestop Collar CFS-C P fixed to one side of the floor + Annular Gap Seal: Mortar or Hilti Firestop Acrylic Selant CFS-S ACR / CP606"	-/240/240	"Collar Size: 63/2" Pipe Wall Thickness: 2.2mm Mortar Depth: Full depth of floor Sealant Depth: 20mm on underside of floor + PEF backing rod (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø69 uPVC Pipe	Floor	Concrete Floor (Min. Floor Thickness 120mm)	"Hilti Firestop Collar CFS-C P fixed to one side of the floor + Annular Gap Seal: Mortar or Hilti Firestop Acrylic Selant CFS-S ACR / CP606"	-/240/240	"Collar Size: 75/2.5" Pipe Wall Thickness: 2.7mm Mortar Depth: Full depth of floor Sealant Depth: 20mm on underside of floor + PEF backing rod (See Report Ref. for full installation details)"	EWFA RIR 27006-03

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
Ø85 uPVC Pipe	Floor	Concrete Floor (Min. Floor Thickness 120mm)	"Hilti Firestop Collar CFS-C P fixed to one side of the floor + Annular Gap Seal: Mortar or Hilti Firestop Acrylic Selant CFS-S ACR / CP606"	-/240/240	"Collar Size: 90/3" Pipe Wall Thickness: 2.9mm Mortar Depth: Full depth of floor Sealant Depth: 20mm on underside of floor + PEF backing rod (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø110 uPVC Pipe	Floor	Concrete Floor (Min. Floor Thickness 120mm)	"Hilti Firestop Collar CFS-C P fixed to one side of the floor + Annular Gap Seal: Mortar or Hilti Firestop Acrylic Selant CFS-S ACR / CP606"	-/240/240	"Collar Size: 110/4" Pipe Wall Thickness: 3.2mm Mortar Depth: Full depth of floor Sealant Depth: 20mm on underside of floor + PEF backing rod (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø160 uPVC Pipe	Floor	Concrete Floor (Min. Floor Thickness 120mm)	"Hilti Firestop Collar CFS-C P fixed to one side of the floor + Annular Gap Seal: Mortar or Hilti Firestop Acrylic Selant CFS-S ACR / CP606"	-/240/240	"Collar Size: 160/6" Pipe Wall Thickness: 4.5mm Mortar Depth: Full depth of floor Sealant Depth: 20mm on underside of floor + PEF backing rod (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø40 PPR Pipe	Floor	Concrete Floor (Min. Floor Thickness 120mm)	"Hilti Firestop Collar CFS-C P fixed to one side of the floor + Annular Gap Seal: Mortar or Hilti Firestop Acrylic Selant CFS-S ACR / CP606"	-/180/120	"Collar Size: 50/1.5" Pipe Wall Thickness: 6mm Mortar Depth: Full depth of floor Sealant Depth: 20mm on underside of floor + PEF backing rod (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø50 PPR Pipe	Floor	Concrete Floor (Min. Floor Thickness 120mm)	"Hilti Firestop Collar CFS-C P fixed to one side of the floor + Annular Gap Seal: Mortar or Hilti Firestop Acrylic Selant CFS-S ACR / CP606"	-/120/120	"Collar Size: 50/1.5" Pipe Wall Thickness: 6.9mm Mortar Depth: Full depth of floor Sealant Depth: 20mm on underside of floor + PEF backing rod (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø65 PPR Pipe	Floor	Concrete Floor (Min. Floor Thickness 120mm)	"Hilti Firestop Collar CFS-C P fixed to one side of the floor + Annular Gap Seal: Mortar or Hilti Firestop Acrylic Selant CFS-S ACR / CP606"	-/120/120	"Collar Size: 75/2.5" Pipe Wall Thickness: 8.6mm Mortar Depth: Full depth of floor Sealant Depth: 20mm on underside of floor + PEF backing rod (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø80 PPR Pipe	Floor	Concrete Floor (Min. Floor Thickness 120mm)	"Hilti Firestop Collar CFS-C P fixed to one side of the floor + Annular Gap Seal: Mortar or Hilti Firestop Acrylic Selant CFS-S ACR / CP606"	-/120/120	"Collar Size: 90/3" Pipe Wall Thickness: 10.3mm Depth of annular gap seal: full depth of concrete slab"	EWFA RIR 27006-03
Ø100 PPR Pipe	Floor	Concrete Floor (Min. Floor Thickness 120mm)	"Hilti Firestop Collar CFS-C P fixed to one side of the floor + Annular Gap Seal: Mortar or Hilti Firestop Acrylic Selant CFS-S ACR / CP606"	-/120/120	"Collar Size: 110/4" Pipe Wall Thickness: 12.3mm Mortar Depth: Full depth of floor Sealant Depth: 20mm on underside of floor + PEF backing rod (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø110 PPR Pipe	Floor	Concrete Floor (Min. Floor Thickness 120mm)	"Hilti Firestop Collar CFS-C P fixed to one side of the floor + Annular Gap Seal: Mortar or Hilti Firestop Acrylic Selant CFS-S ACR / CP606"	-/120/120	"Collar Size: 110/4" Pipe Wall Thickness: 15mm Mortar Depth: Full depth of floor Sealant Depth: 20mm on underside of floor + PEF backing rod (See Report Ref. for full installation details)"	EWFA RIR 27006-03

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
Ø125 PPR Pipe	Floor	Concrete Floor (Min. Floor Thickness 120mm)	"Hilti Firestop Collar CFS-C P fixed to one side of the floor + Annular Gap Seal: Mortar or Hilti Firestop Acrylic Selant CFS-S ACR / CP606"	-/240/120	"Collar Size: 125/5" Pipe Wall Thickness: 19mm Depth of annular gap seal: full depth of concrete slab (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø40 PE-100 (HDPE) Pipe	Floor	Concrete Floor (Min. Floor Thickness 120mm)	"Hilti Firestop Collar CFS-C P fixed to one side of the floor + Annular Gap Seal: Mortar or Hilti Firestop Acrylic Selant CFS-S ACR / CP606"	-/180/120	"Collar Size: 50/1.5" Pipe Wall Thickness: 5mm Mortar Depth: Full depth of floor Sealant Depth: 20mm on underside of floor + PEF backing rod (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø50 PE-100 (HDPE) Pipe	Floor	Concrete Floor (Min. Floor Thickness 120mm)	"Hilti Firestop Collar CFS-C P fixed to one side of the floor + Annular Gap Seal: Mortar or Hilti Firestop Acrylic Selant CFS-S ACR / CP606"	-/90/90	"Collar Size: 50/1.5" Pipe Wall Thickness: 4.6mm Mortar Depth: Full depth of floor Sealant Depth: 20mm on underside of floor + PEF backing rod (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø65 PE-100 (HDPE) Pipe	Floor	Concrete Floor (Min. Floor Thickness 120mm)	"Hilti Firestop Collar CFS-C P fixed to one side of the floor + Annular Gap Seal: Mortar or Hilti Firestop Acrylic Selant CFS-S ACR / CP606"	-/90/90	"Collar Size: 75/2.5" Pipe Wall Thickness: 5.8mm Depth of annular gap seal: full depth of concrete slab (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø80 PE-100 (HDPE) Pipe	Floor	Concrete Floor (Min. Floor Thickness 120mm)	"Hilti Firestop Collar CFS-C P fixed to one side of the floor + Annular Gap Seal: Mortar or Hilti Firestop Acrylic Selant CFS-S ACR / CP606"	-/90/90	"Collar Size: 90/3" Pipe Wall Thickness: 6.8mm Mortar Depth: Full depth of floor Sealant Depth: 20mm on underside of floor + PEF backing rod (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø100 PE-100 (HDPE) Pipe	Floor	Concrete Floor (Min. Floor Thickness 120mm)	"Hilti Firestop Collar CFS-C P fixed to one side of the floor + Annular Gap Seal: Mortar or Hilti Firestop Acrylic Selant CFS-S ACR / CP606"	-/90/90	"Collar Size: 110/4" Pipe Wall Thickness: 8.2mm Mortar Depth: Full depth of floor Sealant Depth: 20mm on underside of floor + PEF backing rod (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø110 PE-100 (HDPE) Pipe	Floor	Concrete Floor (Min. Floor Thickness 120mm)	"Hilti Firestop Collar CFS-C P fixed to one side of the floor + Annular Gap Seal: Mortar or Hilti Firestop Acrylic Selant CFS-S ACR / CP606"	-/90/90	"Collar Size: 110/4" Pipe Wall Thickness: 12mm Mortar Depth: Full depth of floor Sealant Depth: 20mm on underside of floor + PEF backing rod (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø125 PE-100 (HDPE) Pipe	Floor	Concrete Floor (Min. Floor Thickness 120mm)	"Hilti Firestop Collar CFS-C P fixed to one side of the floor + Annular Gap Seal: Mortar or Hilti Firestop Acrylic Selant CFS-S ACR / CP606"	-/60/60	"Collar Size: 125/5" Pipe Wall Thickness: 13mm Mortar Depth: Full depth of floor Sealant Depth: 20mm on underside of floor + PEF backing rod (See Report Ref. for full installation details)"	EWFA RIR 27006-03

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
Ø200 PE-100 (HDPE) Pipe	Floor	Concrete Floor (Min. Floor Thickness 120mm)	"Hilti Firestop Collar CFS-C P fixed to one side of the floor + Annular Gap Seal: Mortar or Hilti Firestop Acrylic Selant CFS-S ACR / CP606"	-/30/30	"Collar Size: 200/8" Pipe Wall Thickness: 20mm Mortar Depth: Full depth of floor Sealant Depth: 20mm on underside of floor + PEF backing rod (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø50 Raupiano Plus Pipe	Floor	Concrete Floor (Min. Floor Thickness 120mm)	"Hilti Firestop Collar CFS-C P fixed to one side of the floor + Annular Gap Seal: Mortar or Hilti Firestop Acrylic Selant CFS-S ACR / CP606"	-/120/120	"Collar Size: 50/1.5" Pipe Wall Thickness: 1.8mm Mortar Depth: Full depth of floor Sealant Depth: 20mm on underside of floor + PEF backing rod (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø75 Raupiano Plus Pipe	Floor	Concrete Floor (Min. Floor Thickness 120mm)	"Hilti Firestop Collar CFS-C P fixed to one side of the floor + Annular Gap Seal: Mortar or Hilti Firestop Acrylic Selant CFS-S ACR / CP606"	-/120/120	"Collar Size: 75/2.5" Pipe Wall Thickness: 1.9mm Mortar Depth: Full depth of floor Sealant Depth: 20mm on underside of floor + PEF backing rod (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø90 Raupiano Plus Pipe	Floor	Concrete Floor (Min. Floor Thickness 120mm)	"Hilti Firestop Collar CFS-C P fixed to one side of the floor + Annular Gap Seal: Mortar or Hilti Firestop Acrylic Selant CFS-S ACR / CP606"	-/120/120	"Collar Size: 90/3" Pipe Wall Thickness: 2.2mm Mortar Depth: Full depth of floor Sealant Depth: 20mm on underside of floor + PEF backing rod (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø110 Raupiano Plus Pipe	Floor	Concrete Floor (Min. Floor Thickness 120mm)	"Hilti Firestop Collar CFS-C P fixed to one side of the floor + Annular Gap Seal: Mortar or Hilti Firestop Acrylic Selant CFS-S ACR / CP606"	-/120/120	"Collar Size: 110/4" Pipe Wall Thickness: 2.7mm Mortar Depth: Full depth of floor Sealant Depth: 20mm on underside of floor + PEF backing rod (See Report Ref. for full installation details)"	EWFA RIR 27006-03

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED COMBUSTIBLE PIPES						
Ø26.7mm CPVC Pipe	Wall	Plaster Board Wall; lined with min. 2 x min. 13mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/120	"Collar Size: 50/1.5" Pipe Wall Thickness: 1.9 - 2.1mm Armaflex AF Insulation Thickness: 9mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø33.4mm CPVC Pipe	Wall	Plaster Board Wall; lined with min. 2 x min. 13mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/120	"Collar Size: 50/1.5" Pipe Wall Thickness: 2.4 - 2.6mm Armaflex AF Insulation Thickness: 9mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø42.2mm CPVC Pipe	Wall	Plaster Board Wall; lined with min. 2 x min. 13mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/120	"Collar Size: 63/2" Pipe Wall Thickness: 3.1 - 3.3mm Armaflex AF Insulation Thickness: 9mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03
Ø48.3mm CPVC Pipe	Wall	Plaster Board Wall; lined with min. 2 x min. 13mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/120	"Collar Size: 75/2.5" Pipe Wall Thickness: 3.5 - 3.8mm Armaflex AF Insulation Thickness: 9mm Depth of annular gap seal: full depth of wall lining"	EWFA RIR 27006-03
Ø60.3mm CPVC Pipe	Wall	Plaster Board Wall; lined with min. 2 x min. 13mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti Firestop Collar CFS-C P fixed to each side of wall + Hilti Firestop Acrylic Selant CFS-S ACR / CP606 in annular gap each side of wall"	-/120/120	"Collar Size: 75/2.5" Pipe Wall Thickness: 4.4 - 4.7mm Armaflex AF Insulation Thickness: 13mm Depth of annular gap seal: full depth of wall lining (See Report Ref. for full installation details)"	EWFA RIR 27006-03

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
All sheathed cable types <20mm OD, bundles of cables up to 100% full	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard on each side of stud	"Hilti CFS-SL S Speed Sleeve + Hilti CFS-S ACR sealant around sleeve on each side of wall"	-/120/60	"Opening / Core Hole Size: 63 -76mm Annular Seal Depth min. 20mm Each cable not exceeding 20mm diameter (See Report Ref. for full installation details)"	Branz Appraisal No. 813 (2013)
All sheathed cable types <20mm OD, bundles of cables up to 100% full	Wall	Plaster Board Wall;with min. 2 x 13mm / 16mm Fire Rated Plasterboard on each side of stud	"Hilti CFS-SL M Speed Sleeve + Hilti CFS-S ACR sealant around sleeve on each side of wall"	-/120/60	"Opening / Core Hole Size: 113 -122mm Annular Seal Depth min. 20mm Each cable not exceeding 20mm diameter (See Report Ref. for full installation details)"	Branz Appraisal No. 813 (2013)
All sheathed cable types <2mm in diameter (not bundles)	Wall	Rigid Wall; Concrete / Masonry Wall (Min. Thickness 100mm)	"Hilti CFS-SL S Speed Sleeve + Hilti CFS-S ACR sealant around sleeve on each side of wall"	-/120/120	"Opening / Core Hole Size: 63 -76mm Annular Seal Depth min. 20mm Max. wall thickness: 200mm (See Report Ref. for full installation details)"	Branz Appraisal No. 813 (2013)
All sheathed cable types, bundles up to 36 mm diameter	Wall	Rigid Wall; Concrete / Masonry Wall (Min. Thickness 100mm)	"Hilti CFS-SL S Speed Sleeve + Hilti CFS-S ACR sealant around sleeve on each side of wall"	-/120/120	"Opening / Core Hole Size: 63 -76mm Annular Seal Depth min. 20mm Each cable not exceeding 21 mm Max. wall thickness: 200mm (See Report Ref. for full installation details)"	Branz Appraisal No. 813 (2013)
All sheathed cable types up to 21 mm diameter (not bundles)	Wall	Rigid Wall; Concrete / Masonry Wall (Min. Thickness 100mm)	"Hilti CFS-SL M Speed Sleeve + Hilti CFS-S ACR sealant around sleeve on each side of wall"	-/120/120	"Opening / Core Hole Size: 113 -122mm Annular Seal Depth min. 20mm Max. wall thickness: 200mm (See Report Ref. for full installation details)"	Branz Appraisal No. 813 (2013)
All sheathed cable types up to 50 mm diameter (not bundles)	Wall	Rigid Wall; Concrete / Masonry Wall (Min. Thickness 100mm)	"Hilti CFS-SL M Speed Sleeve + Hilti CFS-S ACR sealant around sleeve on each side of wall"	-/120/90	"Opening / Core Hole Size:113 -122mm Annular Seal Depth min. 20mm Max. wall thickness: 200mm (See Report Ref. for full installation details)"	Branz Appraisal No. 813 (2013)
All sheathed cable types up to 80 mm diameter (not bundles)	Wall	Rigid Wall; Concrete / Masonry Wall (Min. Thickness 100mm)	"Hilti CFS-SL M Speed Sleeve + Hilti CFS-S ACR sealant around sleeve on each side of wall"	-/120/60	"Opening / Core Hole Size:113 -122mm Annular Seal Depth min. 20mm Max. wall thickness: 200mm (See Report Ref. for full installation details)"	Branz Appraisal No. 813 (2013)

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
All sheathed cable types, bundles up to 86 mm diameter	Wall	Rigid Wall; Concrete / Masonry Wall (Min. Thickness 100mm)	"Hilti CFS-SL M Speed Sleeve + Hilti CFS-S ACR sealant around sleeve on each side of wall"	-/120/120	"Opening / Core Hole Size:113 -122mm Annular Seal Depth min. 20mm Each cable not exceeding 21 mm Max. wall thickness: 200mm (See Report Ref. for full installation details)"	Brnz Appraisal No. 813 (2013)
All sheathed cable types up to 21mm diameter (not bundles)	Floor	Rigid Floor; Concrete Floor (Min. Floor Thickness 150mm)	"Hilti CFS-SL S Speed Sleeve + Hilti CFS-S ACR sealant around sleeve on each side of wall"	-/120/120	"Opening / Core Hole Size:63 -76mm Annular Seal Depth min. 20mm Max. wall thickness: 200mm (See Report Ref. for full installation details)"	Brnz Appraisal No. 813 (2013)
All sheathed cable types, bundles up to 36 mm diameter	Floor	Rigid Floor; Concrete Floor (Min. Floor Thickness 150mm)	"Hilti CFS-SL S Speed Sleeve + Hilti CFS-S ACR sealant around sleeve on each side of wall"	-/120/120	"Opening / Core Hole Size: 63 -76mm Annular Seal Depth min. 20mm Each cable not exceeding 21 mm Max. wall thickness: 200mm (See Report Ref. for full installation details)"	Brnz Appraisal No. 813 (2013)
All sheathed cable types up to 50 mm diameter (not bundles)	Floor	Rigid Floor; Concrete Floor (Min. Floor Thickness 150mm)	"Hilti CFS-SL M Speed Sleeve + Hilti CFS-S ACR sealant around sleeve on each side of wall"	-/120/120	"Opening / Core Hole Size: 113 -122mm Annular Seal Depth min. 20mm Max. wall thickness: 200mm (See Report Ref. for full installation details)"	Brnz Appraisal No. 813 (2013)
All sheathed cable types up to 80 mm diameter (not bundles)	Floor	Rigid Floor; Concrete Floor (Min. Floor Thickness 150mm)	"Hilti CFS-SL M Speed Sleeve + Hilti CFS-S ACR sealant around sleeve on each side of wall"	-/120/60	"Opening / Core Hole Size:113 -122mm Annular Seal Depth min. 20mm Max. wall thickness: 200mm (See Report Ref. for full installation details)"	Brnz Appraisal No. 813 (2013)
All sheathed cable types, bundles up to 86 mm diameter	Floor	Rigid Floor; Concrete Floor (Min. Floor Thickness 150mm)	"Hilti CFS-SL M Speed Sleeve + Hilti CFS-S ACR sealant around sleeve on each side of wall"	-/120/120	"Opening / Core Hole Size:113 -122mm Annular Seal Depth min. 20mm Each cable not exceeding 21 mm Max. wall thickness: 200mm (See Report Ref. for full installation details)"	Brnz Appraisal No. 813 (2013)
Single cable up to 16mm OD	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides Backfilling material (Optional): Mineral Stone Wool with minimum density of 100kg/m ³ "	-/120/120	"Blank opening: max. 40mm x 40mm or circular opening of equivalent size Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Single cable up to 16mm OD	Wall	Rigid Wall; Concrete / Solid or Hollow Masonry (Min. Wall Thickness 75mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides, Backfilling material (Optional): Mineral Stone Wool with minimum density of 100kg/m ³ "	-/120/120	"Blank opening: max. 40mm x 40mm or circular opening of equivalent size Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Cables bundles up to a bundle size of 20mm	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides, Backfilling material (Optional): Mineral Stone Wool with minimum density of 100kg/m ³ "	-/120/120	"Blank opening: max. 40mm x 40mm or circular opening of equivalent size Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Cables bundles up to a bundle size of 20mm	Wall	Rigid Wall; Concrete / Solid or Hollow Masonry (Min. Wall Thickness 75mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides, Backfilling material (Optional): Mineral Stone Wool with minimum density of 100kg/m ³ "	-/120/120	"Blank opening: max. 40mm x 40mm or circular opening of equivalent size Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
PVC Insulated Power Cables with Cable Tray	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Backfilling material: Mineral Stone Wool with minimum density of 100kg/m ³ . (Tightly compressed, Min. Thickness 50mm)"	-/120/60	"Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
PVC Insulated Power Cables with Cable Tray	Wall	Rigid Wall; Concrete / Solid or Hollow Masonry (Min. Wall Thickness 75mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Backfilling material: Mineral Stone Wool with density of 100kg/m ³ (Tightly compressed, Min. Thickness 50mm)"	-/120/60	"Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
PVC Insulated Power Cables with Cable Tray	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Two layers of 10mm wide Hilti Firestop Bandage CFS-P BA each side + Mineral Stone Wool with minimum density of 100kg/m ³ (Tightly compressed, Min. Thickness 50mm)"	-/120/120	"Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
PVC Insulated Power Cables with Cable Tray	Wall	Rigid Wall; Concrete / Solid or Hollow Masonry (Min. Wall Thickness 75mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Two layers of 10mm wide Hilti Firestop Bandage CFS-P BA each side + Backfilling material: Mineral Stone Wool with density of 100kg/m ³ (Tightly compressed, Min. Thickness 50mm)"	-/120/120	"Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
PVC Insulated Communication Cables with Cable Tray	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Backfilling material: Mineral Stone Wool with minimum density of 100kg/m ³ (Tightly compressed, Min. Thickness 50mm)"	-/120/60	"Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
PVC Insulated Communication Cables with Cable Tray	Wall	Rigid Wall; Concrete / Solid or Hollow Masonry (Min. Wall Thickness 75mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Backfilling material: Mineral Stone Wool with minimum density of 100kg/m ³ (Tightly compressed, Min. Thickness 50mm)"	-/120/60	"Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
PVC Insulated Communication Cables with Cable Tray	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Two layers of 10mm wide Hilti Firestop Bandage CFS-P BA each side + Mineral Stone Wool with minimum density of 100kg/m3 (Tightly compressed, Min. Thickness 50mm)"	-/120/120	"Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
PVC Insulated Communication Cables with Cable Tray	Wall	Rigid Wall; Concrete / Solid or Hollow Masonry (Min. Wall Thickness 75mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Two layers of 10mm wide Hilti Firestop Bandage CFS-P BA each side + Mineral Stone Wool with minimum density of 100kg/m3 (Tightly compressed, Min. Thickness 50mm,)"	-/120/120	"Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Single PVC conduits and tubes up to 16mm with or without cables or optic fibre cables	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides Backfilling material optional"	-/120/120	"Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Single PVC conduits and tubes up to 16mm with or without cables or optic fibre cables	Wall	Rigid Wall; Concrete / Solid or Hollow Masonry (Min. Wall Thickness 75mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides Backfilling material optional"	-/120/120	"Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Single PVC conduits with diameter 16mm ≤ Ø ≤ 32mm, wall thickness 1-3mm with or without cables or optic fibre cables	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Backfilling material: Mineral Stone Wool with minimum density of 100kg/m3 (Tightly compressed, Min. Thickness 50mm)"	-/120/120	"Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Single PVC conduits with diameter 16mm ≤ Ø ≤ 32mm, wall thickness 1-3mm with or without cables or optic fibre cables	Wall	Plaster Board Wall; Concrete / Solid or Hollow Masonry (Min. Wall Thickness 75mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Backfilling material: Mineral Stone Wool with minimum density of 100kg/m3 (Tightly compressed, Min. Thickness 50mm,)"	-/120/120	"Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Single Steel conduits and tubes up to 16mm and min. 1.5mm wall thickness with or without cables or optic fibre cables	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides, Backfilling material (Optional): Mineral Stone Wool with minimum density of 100kg/m3"	-/120/90	"Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Single Steel conduits and tubes up to 16mm and min. 1.5mm wall thickness with or without cables or optic fibre cables	Wall	Plaster Board Wall; Concrete / Solid or Hollow Masonry (Min. Wall Thickness 75mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides, Backfilling material optional"	-/120/90	"Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Single Steel conduits and tubes up to 16mm and min. 1.5mm wall thickness with or without cables or optic fibre cables	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Additional sealant in front of wall on both sides Backfilling material optional"	-/120/120	"Min. depth of seal: 25mm Annular seal width: 10mm Additional sealant min. thickness: 10mm Additional sealant min. length: 25mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Single Steel conduits and tubes up to 16mm and min. 1.5mm wall thickness with or without cables or optic fibre cables	Wall	Rigid Wall; Concrete / Solid or Hollow Masonry (Min. Wall Thickness 75mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Additional sealant in front of wall on both sides, Backfilling material (Optional): Mineral Stone Wool with minimum density of 100kg/m ³ "	-/120/120	"Min. depth of seal: 25mm Annular seal width: 10mm Additional sealant min. thickness: 10mm Additional sealant min. length: 25mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Small cable up to 16mm and for bundles up to a bundle size of 20mm	Wall	Rigid Wall; Concrete / Solid or Hollow Masonry (Min. Wall Thickness 150mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides Backfilling material (Optional): Mineral Stone Wool with minimum density of 100kg/m ³ "	-/120/120	"Blank opening: max. 40mm x 40mm or circular opening of equivalent size Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
PVC Insulated Power Cables with Cable Tray	Wall	Rigid Wall; Concrete / Solid or Hollow Masonry (Min. Wall Thickness 150mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Additional sealant in front of wall on both sides + Backfilling material: Mineral Stone Wool with minimum density of 100kg/m ³ (Tightly compressed, Min. Thickness 100mm)"	-/120/90	"Min. depth of seal: 25mm Annular seal width: 10mm Additional sealant min. thickness: 10mm Additional sealant min. length: 50mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
PVC Insulated Power Cables with Cable Tray	Wall	Rigid Wall; Concrete / Solid or Hollow Masonry (Min. Wall Thickness 150mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Additional sealant in front of wall on both sides + Backfilling material: Mineral Stone Wool with minimum density of 100kg/m ³ (Tightly compressed, Min. Thickness 100mm)"	-/120/120	"Min. depth of seal: 25mm Annular seal width: 10mm Additional sealant min. thickness: 10mm Additional sealant min. length: 100mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
PVC Insulated Communication Cables with Cable Tray	Wall	Rigid Wall; Concrete / Solid or Hollow Masonry (Min. Wall Thickness 150mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Additional sealant in front of wall on both sides + Backfilling material: Mineral Stone Wool with minimum density of 100kg/m ³ (Tightly compressed, Min. Thickness 100mm)"	-/120/90	"Min. depth of seal: 25mm Annular seal width: 10mm Additional sealant min. thickness: 10mm Additional sealant min. length: 50mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
PVC Insulated Communication Cables with Cable Tray	Wall	Rigid Wall; Concrete / Solid or Hollow Masonry (Min. Wall Thickness 150mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Additional sealant in front of wall on both sides + Backfilling material: Mineral Stone Wool with minimum density of 100kg/m ³ (Tightly compressed, Min. Thickness 100mm)"	-/120/120	"Min. depth of seal: 25mm Annular seal width: 10mm Additional sealant min. thickness: 10mm Additional sealant min. length: 100mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Single PVC conduits and tubes up to 16mm with or without cables or optic fibre cables	Wall	Rigid Wall; Concrete / Solid or Hollow Masonry (Min. Wall Thickness 150mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides Backfilling material optional"	-/120/120	"Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Single PVC conduits with diameter 16mm ≤ Ø ≤ 32mm, wall thickness 1-3mm with or without cables or optic fibre cables	Wall	Rigid Wall; Concrete / Solid or Hollow Masonry (Min. Wall Thickness 150mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Backfilling material: Mineral Stone Wool with minimum density of 100kg/m3 (Tightly compressed, Min. Thickness 100mm)"	-/120/120	"Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Single Steel conduits and tubes up to 16mm and min. 1.5mm wall thickness with or without cables or optic fibre cables	Wall	Rigid Wall; Concrete / Solid or Hollow Masonry (Min. Wall Thickness 150mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides Backfilling material (Optional): Mineral Stone Wool with minimum density of 100kg/m3"	-/120/120	"Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
150mm x 150mm Square Blank Opening, no services	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Intumescent Sealant CP 611A on top side + Backfilling material: Mineral Stone Wool with minimum density of 100kg/m3 (Tightly compressed, Min. Thickness 95mm,)"	-/120/120	"Blank opening: max. 150mm x 150mm or circular opening of equivalent size Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Small cable up to 16mm and for bundles up to a bundle size of 20mm	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides, Backfilling material (Optional): Mineral Stone Wool with minimum density of 100kg/m3"	-/120/120	"Blank opening: max. 40mm x 40mm or circular opening of equivalent size Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
PVC Insulated Power Cables with Cable Tray	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Intumescent Sealant CP 611A on top side + Additional sealant on top side + Backfilling material: Mineral Stone Wool with density of 100kg/m3 (Tightly compressed, Min. Thickness 95mm)"	-/120/90	"Min. depth of seal: 25mm Annular seal width: 10mm Additional sealant min. thickness: 10mm Additional sealant min. length: 30mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
PVC Insulated Power Cables with Cable Tray	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Intumescent Sealant CP 611A on top side + Additional sealant on top side + Backfilling material: Mineral Stone Wool with minimum density of 100kg/m3 (Tightly compressed, Min. Thickness 95mm)"	-/120/120	"Min. depth of seal: 25mm Annular seal width: 10mm Additional sealant min. thickness: 10mm Additional sealant min. length: 130mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
PVC Insulated Communication Cables with Cable Tray	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Intumescent Sealant CP 611A on top side + Additional sealant on top side + Backfilling material: Mineral Stone Wool with density of 100kg/m3 (Tightly compressed, Min. Thickness 95mm)"	-/120/90	"Min. depth of seal: 25mm Annular seal width: 10mm Additional sealant min. thickness: 10mm Additional sealant min. length: 30mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
PVC Insulated Communication Cables with Cable Tray	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Intumescent Sealant CP 611A on top side + Additional sealant on top side + Backfilling material: Mineral Stone Wool with density of 100kg/m3 (Tightly compressed, Min. Thickness 95mm)"	-/120/120	"Min. depth of seal: 25mm Annular seal width: 10mm Additional sealant min. thickness: 10mm Additional sealant min. length: 130mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Single PVC conduits and tubes up to 16mm with or without cables or optic fibre cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Intumescent Sealant CP 611A on topside + Additional sealant on topside Backfilling material (Optional): Mineral Stone Wool with minimum density of 100kg/m ³ "	-/120/90	"Min. depth of seal: 25mm Annular seal width: 10mm Additional sealant min. thickness: 10mm Additional sealant min. length: 30mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Single PVC conduits and tubes up to 16mm with or without cables or optic fibre cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Intumescent Sealant CP 611A on topside + Additional sealant on topside Backfilling material (Optional): Mineral Stone Wool with minimum density of 100kg/m ³ "	-/120/120	"Min. depth of seal: 25mm Annular seal width: 10mm Additional sealant min. thickness: 10mm Additional sealant min. length: 80mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Single Steel conduits and tubes up to 16mm and min. 1.5mm wall thickness with or without cables or optic fibre cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Intumescent Sealant CP 611A on topside + Additional sealant on topside Backfilling material (Optional): Mineral Stone Wool with minimum density of 100kg/m ³ "	-/120/90	"Min. depth of seal: 25mm Annular seal width: 10mm Additional sealant min. thickness: 10mm Additional sealant min. length: 30mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Single Steel conduits and tubes up to 16mm and min. 1.5mm wall thickness with or without cables or optic fibre cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Intumescent Sealant CP 611A on topside + Additional sealant on topside Backfilling material (Optional): Mineral Stone Wool with minimum density of 100kg/m ³ "	-/120/120	"Min. depth of seal: 25mm Annular seal width: 10mm Additional sealant min. thickness: 10mm Additional sealant min. length: 80mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Single PVC conduits with diameter 16mm ≤ Ø ≤ 32mm, wall thickness 1-3mm with or without cables or optic fibre cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Additional sealant on both sides + Backfilling material: Mineral Stone Wool with minimum density of 100kg/m ³ (Tightly compressed, Min. Thickness 95mm.)"	-/120/120	"Min. depth of seal: 25mm Annular seal width: 10mm Additional sealant min. thickness: 10mm Additional sealant min. length: 80mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Small cable up to 16mm and for bundles up to a bundle size of 20mm	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Intumescent Sealant CP 611A on topside Backfilling material (Optional): Mineral Stone Wool with minimum density of 100kg/m ³ "	-/120/120	"Blank opening: max. 40mm x 40mm or circular opening of equivalent size Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
PVC Insulated Power Cables with Cable Tray	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Intumescent Sealant CP 611A on topside + Backfilling material: Mineral Stone Wool with density of 100kg/m ³ (Tightly compressed, Min. Thickness 125mm)"	-/120/90	"Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
PVC Insulated Power Cables with Cable Tray	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Intumescent Sealant CP 611A on topside + Additional sealant on topside + Backfilling material: Mineral Stone Wool with minimum density of 100kg/m ³ (Tightly compressed, Min. Thickness 125mm)"	-/120/120	"Min. depth of seal: 25mm Annular seal width: 10mm Additional sealant min. thickness: 10mm Additional sealant min. length: 100mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
PVC Insulated Communication Cables with Cable Tray	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Intumescent Sealant CP 611A on topside + Backfilling material: Mineral Stone Wool with minimum density of 100kg/m3 (Tightly compressed, Min. Thickness 125mm)"	-/120/90	"Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
PVC Insulated Communication Cables with Cable Tray	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Intumescent Sealant CP 611A on topside + Additional sealant on topside + Backfilling material: Mineral Stone Wool with minimum density of 100kg/m3 (Tightly compressed, Min. Thickness 125mm)"	-/120/120	"Min. depth of seal: 25mm Annular seal width: 10mm Additional sealant min. thickness: 10mm Additional sealant min. length: 100mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Single PVC conduits and tubes up to 16mm with or without cables or optic fibre cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides, Backfilling material (Optional): Mineral Stone Wool with minimum density of 100kg/m3"	-/120/90	"Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Single PVC conduits and tubes up to 16mm with or without cables or optic fibre cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Intumescent Sealant CP 611A on topside + Additional sealant on topside Backfilling material (Optional): Mineral Stone Wool with minimum density of 100kg/m3"	-/120/120	"Min. depth of seal: 25mm Annular seal width: 10mm Additional sealant min. thickness: 10mm Additional sealant min. length: 50mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Single Steel conduits and tubes up to 16mm and min. 1.5mm wall thickness with or without cables or optic fibre cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides, Backfilling material (Optional): Mineral Stone Wool with minimum density of 100kg/m3"	-/120/90	"Min. depth of seal: 25mm Annular seal width: 10mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Single Steel conduits and tubes up to 16mm and min. 1.5mm wall thickness with or without cables or optic fibre cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Intumescent Sealant CP 611A on topside + Additional sealant on topside Backfilling material (Optional): Mineral Stone Wool with minimum density of 100kg/m3"	-/120/120	"Min. depth of seal: 25mm Annular seal width: 10mm Additional sealant min. thickness: 10mm Additional sealant min. length: 50mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Single PVC conduits with diameter 16mm ≤ Ø ≤ 32mm, wall thickness 1-3mm with or without cables or optic fibre cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Additional sealant on both sides + Backfilling material: Mineral wool (Tightly compressed, Min. Thickness 125mm)"	-/120/120	"Min. depth of seal: 25mm Annular seal width: 10mm Additional sealant min. thickness: 10mm Additional sealant min. length: 50mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Ø16mm x 1.75mm PVC conduit with optic fibre cables or empty	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Hilti Firestop Collar CP 644/ CSF-C P-50/1.5 on both sides"	-/120/120	"Hole diameter up to 50mm Thickness of penetration seal: 23mm Min. annular gap between conduit and collar edge: 5mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Ø16mm x 1.75mm PVC conduit with optic fibre cables or empty	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 75mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Hilti Firestop Collar CP 644/ CSF-C P-50/1.5 on both sides"	-/120/60	"Hole diameter up to 50mm Thickness of penetration seal: 23mm Min. annular gap between conduit and collar edge: 5mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Ø16mm x 1.75mm PVC conduit with optic fibre cables or empty	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 128mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Hilti Firestop Collar CP 644/ CSF-C P-50/1.5 on both sides"	-/120/120	"Hole diameter up to 50mm Thickness of penetration seal: 23mm Min. annular gap between conduit and collar edge: 5mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Ø20mm x 1.95mm PVC conduit with optic fibre cables or empty	Wall	Plaster Board Wall; lined with min. 2 x 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 128mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Hilti Firestop Collar CP 644/ CSF-C P-50/1.5 on both sides"	-/120/120	"Hole diameter up to 50mm Thickness of penetration seal: 23mm Min. annular gap between conduit and collar edge: 5mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Ø20mm x 1.95mm PVC conduit with optic fibre cables or empty	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 75mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Hilti Firestop Collar CP 644/ CSF-C P-50/1.5 on both sides"	-/120/60	"Hole diameter up to 50mm Thickness of penetration seal: 23mm Min. annular gap between conduit and collar edge: 5mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Ø20mm x 1.95mm PVC conduit with optic fibre cables or empty	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 128mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Hilti Firestop Collar CP 644/ CSF-C P-50/1.5 on both sides"	-/120/120	"Hole diameter up to 50mm Thickness of penetration seal: 23mm Min. annular gap between conduit and collar edge: 5mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Ø25mm x 1.95mm PVC conduit with optic fibre cables or empty	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Hilti Firestop Collar CP 644/ CSF-C P-50/1.5 on both sides"	-/120/120	"Hole diameter up to 50mm Thickness of penetration seal: 23mm Min. annular gap between conduit and collar edge: 5mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Ø25mm x 1.95mm PVC conduit with optic fibre cables or empty	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 75mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Hilti Firestop Collar CP 644/ CSF-C P-50/1.5 on both sides"	-/120/60	"Hole diameter up to 50mm Thickness of penetration seal: 23mm Min. annular gap between conduit and collar edge: 5mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Ø25mm x 1.95mm PVC conduit with optic fibre cables or empty	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 128mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Hilti Firestop Collar CP 644/ CSF-C P-50/1.5 on both sides"	-/120/120	"Hole diameter up to 50mm Thickness of penetration seal: 23mm Min. annular gap between conduit and collar edge: 5mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Ø32mm x 2.25mm PVC conduit with optic fibre cables or empty	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Hilti Firestop Collar CP 644/ CSF-C P-50/1.5 on both sides"	-/120/120	"Hole diameter up to 50mm Thickness of penetration seal: 23mm Min. annular gap between conduit and collar edge: 5mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Ø32mm x 2.25mm PVC conduit with optic fibre cables or empty	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 75mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Hilti Firestop Collar CP 644/ CSF-C P-50/1.5 on both sides"	-/120/60	"Hole diameter up to 50mm Thickness of penetration seal: 23mm Min. annular gap between conduit and collar edge: 5mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Ø32mm x 2.25mm PVC conduit with optic fibre cables or empty	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 128mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Hilti Firestop Collar CP 644/ CSF-C P-50/1.5 on both sides"	-/120/120	"Hole diameter up to 50mm Thickness of penetration seal: 23mm Min. annular gap between conduit and collar edge: 5mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Ø40mm x 2.55mm PVC conduit with optic fibre cables or empty	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Hilti Firestop Collar CP 644/ CSF-C P-50/1.5 on both sides"	-/120/120	"Hole diameter up to 50mm Thickness of penetration seal: 23mm Min. annular gap between conduit and collar edge: 5mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Ø40mm x 2.55mm PVC conduit with optic fibre cables or empty	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 75mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Hilti Firestop Collar CP 644/ CSF-C P-50/1.5 on both sides"	-/120/60	"Hole diameter up to 50mm Thickness of penetration seal: 23mm Min. annular gap between conduit and collar edge: 5mm"	EWFA RIR 27912900.5
Ø40mm x 2.55mm PVC conduit with optic fibre cables or empty	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Solid or Hollow Masonry (Min. Wall Thickness 128mm)	"Hilti Firestop Intumescent Sealant CP 611A on both sides + Hilti Firestop Collar CP 644/ CSF-C P-50/1.5 on both sides"	-/120/120	"Hole diameter up to 50mm Thickness of penetration seal: 23mm Min. annular gap between conduit and collar edge: 5mm (See Report Ref. for full installation details)"	EWFA RIR 27912900.5
Single Cables 4mm ≤ Ø ≤ 25mm	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 75mm)	Hilti Firestop Intumescent Sealant CP 611A	-/60/60	"Min. sealant depth: full depth of wall Aperture diameter: 6mm ≤ Ø ≤ 40mm, refer to RIR for more details (See Report Ref. for full installation details)"	EWFA RIR 32796900
Single Cables 4mm ≤ Ø ≤ 25mm	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 75mm)	"Hilti Firestop Intumescent Sealant CP 611A + Additional Protection: Hilti Firestop Intumescent Sealant CP 611A"	-/90/90	"Min. sealant depth: 25mm Aperture diameter: 6mm ≤ Ø ≤ 40mm, refer to RIR for more details Min. depth of additional protection: 50mm (See Report Ref. for full installation details)"	EWFA RIR 32796900

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Single Cables 4mm ≤ Ø ≤ 25mm	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Speedwall Panel / Solid or Hollow Masonry (Min. Wall Thickness 100mm)	"Hilti Firestop Intumescent Sealant CP 611A + Additional Protection: Hilti Firestop Intumescent Sealant CP 611A"	-/120/120	"Min. sealant depth: 25mm Aperture diameter: 6mm ≤ Ø ≤ 40mm, refer to RIR for more details Min. depth of additional protection: 50mm (See Report Ref. for full installation details)"	EWFA RIR 32796900
Single Cables 4mm ≤ Ø ≤ 25mm	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Intumescent Sealant CP 611A + Additional Protection: Hilti Firestop Intumescent Sealant CP 611A"	-/120/120	"Min. sealant depth: 25mm Aperture diameter: 6mm ≤ Ø ≤ 40mm, refer to RIR for more details Min. depth of additional protection: 50mm (See Report Ref. for full installation details)"	EWFA RIR 32796900
Up to 60% full of PVC insulated Power Cables with or without cable tray	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX for full seal depth	-/120/60	"Min. seal thickness: 150mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Up to 60% full of PVC insulated Power Cables with or without cable tray	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Flexible Firestop Foam CFS-F FX for full seal depth + Hilti Firestop Putty Bandage CFS-P BA each side"	-/120/120	"Min. seal thickness: 150mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Up to 60% full of PVC insulated Communication Cables with or without cable tray	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX for full seal depth	-/120/60	"Min. seal thickness: 150mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Up to 60% full of PVC insulated Communication Cables with or without cable tray	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Flexible Firestop Foam CFS-F FX for full seal depth + Hilti Firestop Putty Bandage CFS-P BA each side"	-/120/120	"Min. seal thickness: 150mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Single Plastic Conduit up to 16mm filled with cables, optic fibres or empty	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX for full seal depth	-/120/120	"Min. seal thickness: 150mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Up to 60% full of PVC insulated Power Cables with or without cable tray	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX for full seal depth	-/120/90	"Min. seal thickness: 200mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Up to 60% full of PVC insulated Power Cables with or without cable tray	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Flexible Firestop Foam CFS-F FX for full seal depth + Hilti Firestop Putty Bandage CFS-P BA each side"	-/120/120	"Min. seal thickness: 200mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Up to 60% full of PVC insulated Communication Cables with or without cable tray	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX for full seal depth	-/120/90	"Min. seal thickness: 200mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Up to 60% full of PVC insulated Communication Cables with or without cable tray	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Flexible Firestop Foam CFS-F FX for full seal depth + Hilti Firestop Putty Bandage CFS-P BA each side"	-/120/120	"Min. seal thickness: 200mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Up to 60% full of Steel Conduits and Tubes up to 16mm filled with cables, optic fibres or empty	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX for full seal depth	-/120/120	"Min. seal thickness: 200mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Single Plastic Conduit up to 32mm filled with cables, optic fibres or empty	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX for full seal depth	-/120/120	"Min. seal thickness: 200mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Bundle Plastic Conduits up to 32mm filled with cables, optic fibres or empty.	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX for full seal depth	-/120/120	"Max. diameter of conduit: 100mm Min. seal thickness: 200mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Up to 60% full of PVC insulated Power Cables with or without cable tray	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Solid or Hollow Masonry (Min. Wall Thickness 75mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX for full seal depth	-/120/60	"Min. seal thickness: 150mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Up to 60% full of PVC insulated Power Cables with or without cable tray	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Solid or Hollow Masonry (Min. Wall Thickness 75mm (+ Aperture Beading))	"Hilti Flexible Firestop Foam CFS-F FX for full seal depth + Hilti Firestop Putty Bandage CFS-P BA each side"	-/120/120	"Min. seal thickness: 150mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
Up to 60% full of PVC insulated Communication Cables with or without cable tray	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Solid or Hollow Masonry (Min. Wall Thickness 75mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX for full seal depth	-/120/60	"Min. seal thickness: 150mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Up to 60% full of PVC insulated Communication Cables with or without cable tray	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Solid or Hollow Masonry (Min. Wall Thickness 75mm (+ Aperture Beading))	"Hilti Flexible Firestop Foam CFS-F FX for full seal depth + Hilti Firestop Putty Bandage CFS-P BA each side"	-/120/120	"Min. seal thickness: 150mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Single Plastic Conduit up to 16mm filled with cables, optic fibres or empty	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Solid or Hollow Masonry (Min. Wall Thickness 75mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX for full seal depth	-/120/120	"Min. seal thickness: 150mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Up to 60% full of PVC insulated Power Cables with or without cable tray	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX for full seal depth	-/120/60	"Min. seal thickness: 150mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Up to 60% full of PVC insulated Power Cables with or without cable tray	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Flexible Firestop Foam CFS-F FX for full seal depth + Hilti Firestop Putty Bandage CFS-P BA top side only"	-/120/120	"Min. seal thickness: 150mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Up to 60% full of PVC insulated Communication Cables with or without cable tray	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX for full seal depth	-/120/60	"Min. seal thickness: 150mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Up to 60% full of PVC insulated Communication Cables with or without cable tray	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Flexible Firestop Foam CFS-F FX for full seal depth + Hilti Firestop Putty Bandage CFS-P BA top side only"	-/120/120	"Min. seal thickness: 150mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Up to 60% full of Steel Conduits and Tubes up to 16mm filled with cables, optic fibres or empty	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX for full seal depth	-/120/120	"Min. seal thickness: 150mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Single Plastic Conduit up to 16mm filled with cables, optic fibres or empty	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX for full seal depth	-/120/120	"Min. seal thickness: 150mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Up to 60% full of PVC insulated Power Cables with or without cable tray	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Solid or Hollow Masonry (Min. Wall Thickness 75mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX for full seal depth	-/120/90	"Min. seal thickness: 200mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Up to 60% full of PVC insulated Power Cables with or without cable tray	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Solid or Hollow Masonry (Min. Wall Thickness 75mm (+ Aperture Beading))	"Hilti Flexible Firestop Foam CFS-F FX for full seal depth + Hilti Firestop Putty Bandage CFS-P BA each side"	-/120/120	"Min. seal thickness: 200mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Up to 60% full of PVC insulated Communication Cables with or without cable tray	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Solid or Hollow Masonry (Min. Wall Thickness 75mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX for full seal depth	-/120/90	"Min. seal thickness: 200mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Up to 60% full of PVC insulated Communication Cables with or without cable tray	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Solid or Hollow Masonry (Min. Wall Thickness 75mm (+ Aperture Beading))	"Hilti Flexible Firestop Foam CFS-F FX for full seal depth + Hilti Firestop Putty Bandage CFS-P BA each side"	-/120/120	"Min. seal thickness: 200mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Up to 60% full of Steel Conduits and Tubes up to 16mm filled with cables, optic fibres or empty	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Solid or Hollow Masonry (Min. Wall Thickness 75mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX for full seal depth	-/120/120	"Min. seal thickness: 200mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Single Plastic Conduit up to 32mm filled with cables, optic fibres or empty	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Solid or Hollow Masonry (Min. Wall Thickness 75mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX for full seal depth	-/120/120	"Min. seal thickness: 200mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm (See Report Ref. for full installation details)"	EWFA RIR 37571100.1

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Bundle Plastic Conduits up to 32mm filled with cables, optic fibres or empty.	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Speedpanel Panel / Solid or Hollow Masonry (Min. Wall Thickness 75mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX for full seal depth	-/120/120	"Max. diameter of conduit: 100mm Min. seal thickness: 200mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Up to 60% full of PVC insulated Power Cables with or without cable tray	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX for full seal depth	-/120/90	"Min. seal thickness: 200mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Up to 60% full of PVC insulated Power Cables with or without cable tray	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Flexible Firestop Foam CFS-F FX for full seal depth + Hilti Firestop Putty Bandage CFS-P BA top side only"	-/120/120	"Min. seal thickness: 200mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Up to 60% full of PVC insulated Communication Cables with or without cable tray	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX for full seal depth	-/120/90	"Min. seal thickness: 200mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Up to 60% full of PVC insulated Communication Cables with or without cable tray	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Flexible Firestop Foam CFS-F FX for full seal depth + Hilti Firestop Putty Bandage CFS-P BA top side only"	-/120/120	"Min. seal thickness: 200mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Up to 60% full of Steel Conduits and Tubes up to 16mm filled with cables, optic fibres or empty	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX for full seal depth	-/120/120	"Min. seal thickness: 200mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm Max. 60% of seal area to be penetrated (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
Single Plastic Conduit up to 32mm filled with cables, optic fibres or empty	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX for full seal depth	-/120/120	"Min. seal thickness: 200mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm (See Report Ref. for full installation details)"	EWFA RIR 37571100.1

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Bundle Plastic Conduits up to 32mm filled with cables, optic fibres or empty.	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	Hilti Flexible Firestop Foam CFS-F FX for full seal depth	-/120/120	"Max. diameter of conduit: 100mm Min. seal thickness: 200mm Max. opening area: 0.16m ² or max. diameter ≤ 400mm (See Report Ref. for full installation details)"	EWFA RIR 37571100.1
PVC Insulated Power Cables	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Firestop Plug CFS-PL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/60	"Min. seal thickness: 150mm Opening size: 52mm ≤ Ø ≤ 202mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm Wall cavity insulation: Mineral Stone Wool with Min. thickness: 50mm, Min. density: 100kg/m ³ (See Report Ref. for full installation details)"	EWFA RIR 27937400.1
PVC Insulated Power Cables	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Firestop Plug CFS-PL + Hilti Firestop Intumescent Sealant CP 611A + Hilti Firestop Putty Bandage CFS-P BA"	-/120/120	"Min. seal thickness: 150mm Opening size: 52mm ≤ Ø ≤ 202mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm Wall cavity insulation: Mineral Stone Wool with Min. thickness: 50mm, Min. density: 100kg/m ³ (See Report Ref. for full installation details)"	EWFA RIR 27937400.1
PVC Insulated Communication Cables	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Firestop Plug CFS-PL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/60	"Min. seal thickness: 150mm Opening size: 52mm ≤ Ø ≤ 202mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm Wall cavity insulation: Mineral Stone Wool with Min. thickness: 50mm, Min. density: 100kg/m ³ (See Report Ref. for full installation details)"	EWFA RIR 27937400.1
PVC Insulated Communication Cables	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Firestop Plug CFS-PL + Hilti Firestop Intumescent Sealant CP 611A + Hilti Firestop Putty Bandage CFS-P BA"	-/120/120	"Min. seal thickness: 150mm Opening size: 52mm ≤ Ø ≤ 202mm Max. 60% of seal area can be penetrated Wall cavity insulation: Mineral Stone Wool with Min. thickness: 50mm, Min. density: 100kg/m ³ (See Report Ref. for full installation details)"	EWFA RIR 27937400.1

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Single Plastic Conduit up to 40mm filled with cables, optic fibres or empty	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Firestop Plug CFS-PL + Hilti Firestop Intumescent Sealant CP 611A "	-/120/120	"Min. seal thickness: 150mm Opening size: 52mm ≤ Ø ≤ 202mm Max. 60% of seal area can be penetrated Wall cavity insulation: Mineral Stone Wool Min. mineral wool thickness: 50mm Min. mineral wool density: 100kg/m3 (See Report Ref. for full installation details)"	EWFA RIR 27937400.1
Conduits up to 20mm filled with cables, optic fibres or empty.	Wall	Plaster Board Wall; lined with min. 2 x 13mm / 16mm Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Firestop Plug CFS-PL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/120	"Max. bundle diameter: 100mm Min. seal thickness: 150mm Opening size: 52mm ≤ Ø ≤ 202mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm Wall cavity insulation: Mineral Stone Wool Min. mineral wool thickness: 50mm Min. mineral wool density: 100kg/m3 (See Report Ref. for full installation details)"	EWFA RIR 27937400.1
PVC Insulated Power Cables	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 75mm (+ Aperture Beading))	"Hilti Firestop Plug CFS-PL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/60	"Min. seal thickness: 150mm Opening size: 52mm ≤ Ø ≤ 202mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 27937400.1
PVC Insulated Power Cables	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 75mm (+ Aperture Beading))	"Hilti Firestop Plug CFS-PL + Hilti Firestop Intumescent Sealant CP 611A + Hilti Firestop Putty Bandage CFS-P BA"	-/120/120	"Min. seal thickness: 150mm Opening size: 52mm ≤ Ø ≤ 202mm Max. 60% of seal area can be penetrated (See Report Ref. for full installation details)"	EWFA RIR 27937400.1
PVC Insulated Communication Cables	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 75mm (+ Aperture Beading))	"Hilti Firestop Plug CFS-PL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/60	"Min. seal thickness: 150mm Opening size: 52mm ≤ Ø ≤ 202mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 27937400.1

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
PVC Insulated Communication Cables	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 75mm (+ Aperture Beading))	"Hilti Firestop Plug CFS-PL + Hilti Firestop Intumescent Sealant CP 611A + Hilti Firestop Putty Bandage CFS-P BA"	-/120/120	"Min. seal thickness: 150mm Opening size: 52mm ≤ Ø ≤ 202mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 27937400.1
Single Plastic Conduit up to 40mm filled with cables, optic fibres or empty	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 75mm (+ Aperture Beading))	"Hilti Firestop Plug CFS-PL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/120	"Min. seal thickness: 150mm Opening size: 52mm ≤ Ø ≤ 202mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 27937400.1
Conduits up to 20mm filled with cables, optic fibres or empty.	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 75mm (+ Aperture Beading))	"Hilti Firestop Plug CFS-PL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/120	"Max. bundle diameter: 100mm Min. seal thickness: 150mm Opening size: 52mm ≤ Ø ≤ 202mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 27937400.1
PVC Insulated Power Cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Plug CFS-PL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/90	"Min. seal thickness: 150mm Opening size: 52mm ≤ Ø ≤ 202mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 27937400.1
PVC Insulated Communication Cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Plug CFS-PL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/90	"Min. seal thickness: 150mm Opening size: 52mm ≤ Ø ≤ 202mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 27937400.1
Steel Conduits and Tubes up to 16mm filled with cables, optic fibres or empty	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Plug CFS-PL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/120	"Min. seal thickness: 150mm Opening size: 52mm ≤ Ø ≤ 202mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 27937400.1

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Non-Standard PVC Insulated Power Cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Plug CFS-PL + Hilti Firestop Intumescent Sealant CP 611A + Hilti Firestop Putty Bandage CFS-P BA"	-/120/120	"Cables up to Ø48mm may be bundled up to 90mm in diameter Min. seal thickness: 150mm Opening size: 52mm ≤ Ø ≤ 202mm Max. 60% of seal area can be penetrated (See Report Ref. for full installation details)"	EWFA RIR 27937400.1
Non-Standard PVC Insulated Communication Cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Plug CFS-PL + Hilti Firestop Intumescent Sealant CP 611A + Hilti Firestop Putty Bandage CFS-P BA"	-/120/120	"Cables up to Ø48mm may be bundled up to 90mm in diameter Min. seal thickness: 150mm Opening size: 52mm ≤ Ø ≤ 202mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 27937400.1
Single Plastic Conduit up to 40mm filled with cables, optic fibres or empty	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Plug CFS-PL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/120	"Min. seal thickness: 150mm Opening size: 52mm ≤ Ø ≤ 202mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 27937400.1
Conduits up to 20mm filled with cables, optic fibres or empty.	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Plug CFS-PL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/120	"Max. bundle diameter: 100mm Min. seal thickness: 150mm Opening size: 52mm ≤ Ø ≤ 202mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 27937400.1
PVC Insulated Power Cables with or without cable tray	Wall	Plaster Board Wall; lined with min. 2 x 12.5mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/90	"Min. seal thickness: 200mm Max. opening size: 1000mm x 1000mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm Wall cavity filled with Mineral Stone Wool (Min. thickness 50mm, Density 100kg/m ³) OR Aperture lined with Fire Rated Plasterboard each side of stud as required (See Report Ref. for full installation details)"	EWFA RIR 28870-02
PVC Insulated Power Cables with or without cable tray	Wall	Plaster Board Wall; lined with min. 2 x 12.5mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A + 1 layer of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Min. seal thickness: 200mm Max. opening size: 1000mm x 1000mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm Wall cavity filled with Mineral Stone Wool (Min. thickness 50mm, Density 100kg/m ³) OR Aperture lined with Fire Rated Plasterboard each side of stud as required (See Report Ref. for full installation details)"	EWFA RIR 28870-02

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
PVC Insulated Communication Cables with or without cable tray	Wall	Plaster Board Wall; lined with min. 2 x 12.5mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/90	"Min. seal thickness: 200mm Max. opening size: 1000mm x 1000mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm Wall cavity filled with Mineral Stone Wool (Min. thickness 50mm, Density 100kg/m ³) OR Aperture lined with Fire Rated Plasterboard each side of stud as required (See Report Ref. for full installation details)"	EWFA RIR 28870-02
PVC Insulated Communication Cables with or without cable tray	Wall	Plaster Board Wall; lined with min. 2 x 12.5mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A + 1 layer of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Min. seal thickness: 200mm Max. opening size: 1000mm x 1000mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm Wall cavity filled with Mineral Stone Wool (Min. thickness 50mm, Density 100kg/m ³) OR Aperture lined with Fire Rated Plasterboard each side of stud as required (See Report Ref. for full installation details)"	EWFA RIR 28870-02
Single Plastic Conduit up to 40mm filled with cables, optic fibres or empty	Wall	Plaster Board Wall; lined with min. 2 x 12.5mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/120	"Min. seal thickness: 200mm Max. opening size: 1000mm x 1000mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm Wall cavity filled with Mineral Wool (Min. thickness 50mm, Density 100kg/m ³) OR Aperture lined with Fire Rated Plasterboard each side of stud as required (See Report Ref. for full installation details)"	EWFA RIR 28870-02
Conduits up to 20mm filled with cables, optic fibres or empty.	Wall	Plaster Board Wall; lined with min. 2 x 12.5mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/120	"Max. bundle diameter: 100mm Min. seal thickness: 200mm Max. opening size: 1000mm x 1000mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm Wall cavity filled with Mineral Stone Wool (Min. thickness 50mm, Density 100kg/m ³) OR Aperture lined with Fire Rated Plasterboard each side of stud as required. (See Report Ref. for full installation details)"	EWFA RIR 28870-02
Coaxial cable RFS Cellflex: 27.8mm ≤ Ø ≤ 59.9mm	Wall	Plaster Board Wall; lined with min. 2 x 12.5mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A + 1 layer of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Min. seal thickness: 200mm Max. opening size: 1000mm x 1000mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm Wall cavity filled with Mineral Stone Wool (Min. thickness 50mm, Density 100kg/m ³) OR Aperture lined with Fire Rated Plasterboard each side of stud as required. (See Report Ref. for full installation details)"	EWFA RIR 28870-02

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Coaxial cable RFS Heliflex: $28\text{mm} \leq \text{Ø} \leq 59.9\text{mm}$	Wall	Plaster Board Wall; lined with min. 2 x 12.5mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A + 1 layer of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Min. seal thickness: 200mm Max. opening size: 1000mm x 1000mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm Wall cavity filled with Mineral Stone Wool (Min. thickness 50mm, Density 100kg/m ³) OR Aperture lined with Fire Rated Plasterboard each side of stud as required. (See Report Ref. for full installation details)"	EWFA RIR 28870-02
Coaxial cable RFS Radiaflex: $28.5\text{mm} \leq \text{Ø} \leq 48.2\text{mm}$	Wall	Plaster Board Wall; lined with min. 2 x 12.5mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A + 1 layer of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Min. seal thickness: 200mm Max. opening size: 1000mm x 1000mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm Wall cavity filled with Mineral Stone Wool (Min. thickness 50mm, Density 100kg/m ³) OR Aperture lined with Fire Rated Plasterboard each side of stud as required (See Report Ref. for full installation details)"	EWFA RIR 28870-02
PVC Insulated Power Cables with or without cable tray	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/90	"Min. seal thickness: 200mm Max. opening size: 1000mm x 1000mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm Aperture lined with Fire Rated Plasterboard each side of stud as required. (See Report Ref. for full installation details)"	EWFA RIR 28870-02
PVC Insulated Power Cables with or without cable tray	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A + 1 layer of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Min. seal thickness: 200mm Max. opening size: 1000mm x 1000mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm Aperture lined with Fire Rated Plasterboard each side of stud as required (See Report Ref. for full installation details)"	EWFA RIR 28870-02
PVC Insulated Communication Cables with or without cable tray	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/90	"Min. seal thickness: 200mm Max. opening size: 1000mm x 1000mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm Aperture lined with Fire Rated Plasterboard each side of stud as required (See Report Ref. for full installation details)"	EWFA RIR 28870-02

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
PVC Insulated Communication Cables with or without cable tray	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A + 1 layer of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Min. seal thickness: 200mm Max. opening size: 1000mm x 1000mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm Aperture lined with Fire Rated Plasterboard each side of stud as required (See Report Ref. for full installation details)"	EWFA RIR 28870-02
Steel Conduits and Tubes up to 16mm filled with cables, optic fibres or empty	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/120	"Min. seal thickness: 200mm Max. opening size: 1000mm x 1000mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm Aperture lined with Fire Rated Plasterboard each side of stud as required (See Report Ref. for full installation details)"	EWFA RIR 28870-02
Single Plastic Conduit up to 40mm filled with cables, optic fibres or empty	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/120	"Min. seal thickness: 200mm Max. opening size: 1000mm x 1000mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm Aperture lined with Fire Rated Plasterboard each side of stud as required (See Report Ref. for full installation details)"	EWFA RIR 28870-02
Conduits up to 20mm filled with cables, optic fibres or empty.	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/120	"Max. bundle diameter: 100mm Min. seal thickness: 200mm Max. opening size: 1000mm x 1000mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm Aperture lined with Fire Rated Plasterboard each side of stud as required (See Report Ref. for full installation details)"	EWFA RIR 28870-02
Coaxial cable RFS Cellflex: 27.8mm ≤ Ø ≤ 59.9mm	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A + 1 layer of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Min. seal thickness: 200mm Max. opening size: 1000mm x 1000mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm Aperture lined with Fire Rated Plasterboard each side of stud as required (See Report Ref. for full installation details)"	EWFA RIR 28870-02

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Coaxial cable RFS Heliflex: $28\text{mm} \leq \text{Ø} \leq 59.9\text{mm}$	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A + 1 layer of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Min. seal thickness: 200mm Max. opening size: 1000mm x 1000mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm Aperture lined with Fire Rated Plasterboard each side of stud as required (See Report Ref. for full installation details)"	EWFA RIR 28870-02
Coaxial cable RFS Radiaflex: $28.5\text{mm} \leq \text{Ø} \leq 48.2\text{mm}$	Wall	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 100mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A + 1 layer of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Min. seal thickness: 200mm Max. opening size: 1000mm x 1000mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm Aperture lined with Fire Rated Plasterboard each side of stud as required (See Report Ref. for full installation details)"	EWFA RIR 28870-02
PVC Insulated Power Cables with or without cable tray	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/90	"Max. opening size: 1000mm x 1000mm Min. seal thickness: 200mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28870-02
PVC Insulated Power Cables with or without cable tray	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A + 1 layer of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on top side"	-/120/120	"Max. opening size: 1000mm x 1000mm Min. seal thickness: 200mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28870-02
PVC Insulated Communication Cables with or without cable tray	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/90	"Max. opening size: 1000mm x 1000mm Min. seal thickness: 200mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28870-02

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
PVC Insulated Communication Cables with or without cable tray	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A + 1 layer of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on top side"	-/120/120	"Max. opening size: 1000mm x 1000mm Min. seal thickness: 200mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28870-02
Steel Conduits and Tubes up to 16mm filled with cables, optic fibres or empty	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/120	"Max. opening size: 1000mm x 1000mm Min. seal thickness: 200mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28870-02
Single Plastic Conduit up to 40mm filled with cables, optic fibres or empty	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/120	"Max. opening size: 1000mm x 1000mm Min. seal thickness: 200mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28870-02
Conduits up to 20mm filled with cables, optic fibres or empty.	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/120	"Max. bundle diameter: 100mm Max. opening size: 1000mm x 1000mm Min. seal thickness: 200mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28870-02
Coaxial cable RFS Cellflex: $27.8\text{mm} \leq \varnothing \leq 59.9\text{mm}$	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/120	"Max. bundle diameter: 100mm Max. opening size: 1000mm x 1000mm Min. seal thickness: 200mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28870-02
Coaxial cable RFS Helliflex: $28\text{mm} \leq \varnothing \leq 59.9\text{mm}$	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/120	"Max. bundle diameter: 100mm Max. opening size: 1000mm x 1000mm Min. seal thickness: 200mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28870-02

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Coaxial cable RFS Radiaflex: $28.5\text{mm} \leq \text{Ø} \leq 48.2\text{mm}$	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Block CFS-BL + Hilti Firestop Intumescent Sealant CP 611A"	-/120/120	"Max. bundle diameter: 100mm Max. opening size: 1000mm x 1000mm Min. seal thickness: 200mm Max. 60% of seal area can be penetrated Min. depth of CP 611A sealant: 20mm (See Report Ref. for full installation details)"	EWFA RIR 28870-02
PVC Insulated Power Cables	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/120/60	"Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100
PVC Insulated Power Cables	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/90	"Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Stone Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100
PVC Insulated Communication Cables	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/120/60	"Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Stone Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100
PVC Insulated Communication Cables	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/90	"Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Stone Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Bundles of PVC Insulated Power Cables up to Ø50mm	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/120/60	"Max. bundle diameter: 90mm Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundles of PVC Insulated Power Cables up to Ø50mm	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/90	"Max. bundle diameter: 90mm Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundles of PVC Insulated Communication Cables up to Ø50mm	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/120/60	"Max. bundle diameter: 90mm Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Stone Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundle of PVC Insulated Communication Cables up to Ø50mm	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/90	"Max. bundle diameter: 90mm Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Single Plastic Conduit up to 32mm filled with cables, optic fibres or empty	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/120/120	"Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundle of Plastic Conduits up to 16mm without cables	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/120/90	"Max. bundle diameter: 80mm Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Stone Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundle of Plastic Conduits up to 16mm filled with cables or optic fibres	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/120/120	"Max. bundle diameter: 80mm Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100
Coaxial cable RFS Radiaflex: $28.5\text{mm} \leq \varnothing \leq 48.2\text{mm}$	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/120/120	"Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Wool (Min. thickness 50mm, Density 100kg/m3)"	EWFA RIR 38022100

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Coaxial cable RFS Cellflex: 27.8mm ≤ Ø ≤ 59.9mm	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/120/90	"Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100
Coaxial cable RFS Heliflex: 28mm ≤ Ø ≤ 59.9mm	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/120/90	"Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100
Blank Opening, no services	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	Hilti Firestop Cable Collar CFS-CC	-/120/120	"Min. seal thickness: 200mm Max. blank opening size: 108mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
PVC Insulated Power Cables	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/120/60	"Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
PVC Insulated Power Cables	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/90	"Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
PVC Insulated Communication Cables	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/120/60	"Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
PVC Insulated Communication Cables	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/90	"Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundles of PVC Insulated Power Cables up to Ø50mm	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/120/60	"Max. bundle diameter: 90mm Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundles of PVC Insulated Power Cables up to Ø50mm	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/90	"Max. bundle diameter: 90mm Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundles of PVC Insulated Communication Cables up to Ø50mm	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/120/60	"Max. bundle diameter: 90mm Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundle of PVC Insulated Communication Cables up to Ø50mm	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/90	"Max. bundle diameter: 90mm Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Single Plastic Conduit up to 32mm filled with cables, optic fibres or empty	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/120/120	"Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Bundle of Plastic Conduits up to 16mm without cables	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/120/90	"Max. bundle diameter: 80mm Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundle of Plastic Conduits up to 16mm filled with cables or optic fibres	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/120/120	"Max. bundle diameter: 80mm Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Coaxial cable RFS Radiaflex: $28.5\text{mm} \leq \varnothing \leq 48.2\text{mm}$	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/120/120	"Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Coaxial cable RFS Cellflex: $27.8\text{mm} \leq \varnothing \leq 59.9\text{mm}$	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/120/90	"Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Coaxial cable RFS Hellifex: $28\text{mm} \leq \varnothing \leq 59.9\text{mm}$	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/120/90	"Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Blank Opening, no services	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	Hilti Firestop Cable Collar CFS-CC	-/60/60	"Min. seal thickness: 200mm Max. blank opening size: 108mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Wool (Min. thickness 50mm, Density 100kg/m ³) v"	EWFA RIR 38022100

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
PVC Insulated Power Cables	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/60/60	"Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Stone Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100
PVC Insulated Power Cables	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/60/60	"Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100
PVC Insulated Communication Cables	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/60/60	"Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Stone Wool (Min. thickness 50mm, Density 100kg/m3)"	EWFA RIR 38022100
PVC Insulated Communication Cables	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/60/60	"Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Stone Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundles of PVC Insulated Power Cables up to Ø50mm	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/60/60	"Max. bundle diameter: 90mm Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Bundles of PVC Insulated Power Cables up to Ø50mm	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/60/60	"Max. bundle diameter: 90mm Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Wool (Min. thickness 50mm, Density 100kg/m3)"	EWFA RIR 38022100
Bundles of PVC Insulated Communication Cables up to Ø50mm	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/60/60	"Max. bundle diameter: 90mm Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Stone Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundle of PVC Insulated Communication Cables up to Ø50mm	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/60/60	"Max. bundle diameter: 90mm Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100
Single Plastic Conduit up to 32mm filled with cables, optic fibres or empty	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/60/60	"Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Bundle of Plastic Conduits up to 16mm filled with cables, optic fibres, or empty	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/60/60	"Max. bundle diameter: 80mm Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100
Coaxial cable RFS Radiaflex: 28.5mm ≤ Ø ≤ 48.2mm	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/60/60	"Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100
Coaxial cable RFS Cellflex: 27.8mm ≤ Ø ≤ 59.9mm	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/60/60	"Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Stone Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100
Coaxial cable RFS Helifex: 28mm ≤ Ø ≤ 59.9mm	Wall	Plaster Board Wall: lined with min. 2 x 13mm / 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti Firestop Cable Collar CFS-CC + Hilti Firestop Intumescent Sealant CP 611A"	-/60/60	"Min. seal thickness: 200mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side For timber stud wall: Wall cavity filled with Mineral Stone Wool (Min. thickness 50mm, Density 100kg/m3) (See Report Ref. for full installation details)"	EWFA RIR 38022100
PVC Insulated Power Cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC on each side + Hilti Firestop Intumescent Sealant CP 611A on each side"	-/120/90	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
PVC Insulated Power Cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC on each side + Hilti Firestop Intumescent Sealant CP 611A on each side + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
PVC Insulated Communication Cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC on each side + Hilti Firestop Intumescent Sealant CP 611A on each side"	-/120/90	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
PVC Insulated Communication Cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC on each side + Hilti Firestop Intumescent Sealant CP 611A on each side + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundles of PVC Insulated Power Cables up to Ø50mm	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC on each side + Hilti Firestop Intumescent Sealant CP 611A on each side"	-/120/90	"Max. bundle diameter: 90mm Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundles of PVC Insulated Power Cables up to Ø50mm	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC on each side + Hilti Firestop Intumescent Sealant CP 611A on each side + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Max. bundle diameter: 90mm Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundles of PVC Insulated Communication Cables up to Ø50mm	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC on each side + Hilti Firestop Intumescent Sealant CP 611A on each side"	-/120/90	"Max. bundle diameter: 90mm Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Bundle of PVC Insulated Communication Cables up to Ø50mm	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC on each side + Hilti Firestop Intumescent Sealant CP 611A on each side + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Max. bundle diameter: 90mm Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Single Plastic Conduit up to 32mm filled with cables, optic fibres or empty	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC on each side + Hilti Firestop Intumescent Sealant CP 611A on each side"	-/120/120	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundle of Plastic Conduits up to 16mm filled with cables, optic fibres, or empty	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC on each side + Hilti Firestop Intumescent Sealant CP 611A on each side"	-/120/120	"Max. bundle diameter: 80mm Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Coaxial cable RFS Radiaflex: 28.5mm ≤ Ø ≤ 48.2mm	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC on each side + Hilti Firestop Intumescent Sealant CP 611A on each side"	-/120/120	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Coaxial cable RFS Cellflex: 27.8mm ≤ Ø ≤ 59.9mm	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC on each side + Hilti Firestop Intumescent Sealant CP 611A on each side"	-/120/120	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Coaxial cable RFS Helifex: 28mm ≤ Ø ≤ 59.9mm	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC on each side + Hilti Firestop Intumescent Sealant CP 611A on each side"	-/120/90	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
PVC Insulated Power Cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Cable Collar CFS-CC on each side + Hilti Firestop Intumescent Sealant CP 611A on each side"	-/120/60	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
PVC Insulated Power Cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Cable Collar CFS-CC on each side + Hilti Firestop Intumescent Sealant CP 611A on each side + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
PVC Insulated Communication Cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Cable Collar CFS-CC on each side + Hilti Firestop Intumescent Sealant CP 611A on each side"	-/120/60	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
PVC Insulated Communication Cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Cable Collar CFS-CC on each side + Hilti Firestop Intumescent Sealant CP 611A on each side + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Bundles of PVC Insulated Power Cables up to Ø50mm	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Cable Collar CFS-CC on each side + Hilti Firestop Intumescent Sealant CP 611A on each side"	-/120/60	"Max. bundle diameter: 90mm Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundles of PVC Insulated Power Cables up to Ø50mm	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Cable Collar CFS-CC on each side + Hilti Firestop Intumescent Sealant CP 611A on each side + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Max. bundle diameter: 90mm Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundles of PVC Insulated Communication Cables up to Ø50mm	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Cable Collar CFS-CC on each side + Hilti Firestop Intumescent Sealant CP 611A on each side"	-/120/60	"Max. bundle diameter: 90mm Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundle of PVC Insulated Communication Cables up to Ø50mm	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Cable Collar CFS-CC on each side + Hilti Firestop Intumescent Sealant CP 611A on each side + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Max. bundle diameter: 90mm Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundle of PVC Insulated Power or Communication Cables up to Ø21mm, phased out in a perpendicular manner through cable collar along topside of floor	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Cable Collar CFS-CC on each side + Hilti Firestop Intumescent Sealant CP 611A on each side"	-/120/120	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Bundle of PVC Insulated Power or Communication Cables up to Ø21mm, phased out in a perpendicular manner though cable collar along topside of floor	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Cable Collar CFS-CC on each side + Hilti Firestop Intumescent Sealant CP 611A on each side + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
PVC Insulated Power Cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC on underside only + Hilti Firestop Intumescent Sealant CP 611A on underside only"	-/120/90	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
PVC Insulated Power Cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC on underside only + Hilti Firestop Intumescent Sealant CP 611A on underside only + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
PVC Insulated Communication Cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC on underside only + Hilti Firestop Intumescent Sealant CP 611A on underside only"	-/120/90	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
PVC Insulated Communication Cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC on underside only + Hilti Firestop Intumescent Sealant CP 611A on underside only + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Bundles of PVC Insulated Power Cables up to Ø50mm	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC on underside only + Hilti Firestop Intumescent Sealant CP 611A on underside only"	-/120/90	"Max. bundle diameter: 90mm Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundles of PVC Insulated Power Cables up to Ø50mm	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC on underside only + Hilti Firestop Intumescent Sealant CP 611A on underside only + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Max. bundle diameter: 90mm Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundles of PVC Insulated Communication Cables up to Ø50mm	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC on underside only + Hilti Firestop Intumescent Sealant CP 611A on underside only"	-/120/90	"Max. bundle diameter: 90mm Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundle of PVC Insulated Communication Cables up to Ø50mm	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC on underside only + Hilti Firestop Intumescent Sealant CP 611A on underside only + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Max. bundle diameter: 90mm Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Single Plastic Conduit up to 32mm filled with cables, optic fibres or empty	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC on underside only + Hilti Firestop Intumescent Sealant CP 611A on underside only"	-/120/120	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Bundle of Plastic Conduits up to 16mm filled with cables, optic fibres, or empty	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC on underside only + Hilti Firestop Intumescent Sealant CP 611A on underside only"	-/120/120	"Max. bundle diameter: 80mm Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Coaxial cable RFS Radiaflex: 28.5mm ≤ Ø ≤ 48.2mm	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC on underside only + Hilti Firestop Intumescent Sealant CP 611A on underside only"	-/120/120	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Coaxial cable RFS Cellflex: 27.8mm ≤ Ø ≤ 59.9mm	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC on underside only + Hilti Firestop Intumescent Sealant CP 611A on underside only"	-/120/120	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Coaxial cable RFS Heliflex: 28mm ≤ Ø ≤ 59.9mm	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 120mm (+ Aperture Beading))	"Hilti Firestop Cable Collar CFS-CC on underside only + Hilti Firestop Intumescent Sealant CP 611A on underside only"	-/120/90	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
PVC Insulated Power Cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Cable Collar CFS-CC on underside only + Hilti Firestop Intumescent Sealant CP 611A on underside only"	-/120/60	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
PVC Insulated Power Cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Cable Collar CFS-CC on underside only + Hilti Firestop Intumescent Sealant CP 611A on underside only + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
PVC Insulated Communication Cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Cable Collar CFS-CC on underside only + Hilti Firestop Intumescent Sealant CP 611A on underside only"	-/120/60	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
PVC Insulated Communication Cables	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Cable Collar CFS-CC on underside only + Hilti Firestop Intumescent Sealant CP 611A on underside only + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundles of PVC Insulated Power Cables up to Ø50mm	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Cable Collar CFS-CC on underside only + Hilti Firestop Intumescent Sealant CP 611A on underside only"	-/120/60	"Max. bundle diameter: 90mm Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundles of PVC Insulated Power Cables up to Ø50mm	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Cable Collar CFS-CC on underside only + Hilti Firestop Intumescent Sealant CP 611A on underside only + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Max. bundle diameter: 90mm Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL SERVICE PENETRATIONS						
Bundles of PVC Insulated Communication Cables up to Ø50mm	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Cable Collar CFS-CC on underside only + Hilti Firestop Intumescent Sealant CP 611A on underside only"	-/120/60	"Max. bundle diameter: 90mm Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundle of PVC Insulated Communication Cables up to Ø50mm	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Cable Collar CFS-CC on underside only + Hilti Firestop Intumescent Sealant CP 611A on underside only + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Max. bundle diameter: 90mm Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundle of PVC Insulated Power or Communication Cables up to Ø21mm, phased out in a perpendicular manner though cable collar along topside of floor	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Cable Collar CFS-CC on underside only + Hilti Firestop Intumescent Sealant CP 611A on underside only"	-/120/120	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100
Bundle of PVC Insulated Power or Communication Cables up to Ø21mm, phased out in a perpendicular manner though cable collar along topside of floor	Floor	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti Firestop Cable Collar CFS-CC on underside only + Hilti Firestop Intumescent Sealant CP 611A on underside only + 2 layers of 100mm wide Hilti Firestop Putty Bandage CFS-P BA on each side"	-/120/120	"Min. seal thickness: 250mm Max. opening size: 108mm Max. 60% of seal area can be penetrated Min. depth of intumescent sealant: 20mm Aperture beading: min. 1x 13mm or 16mm Fire Grade Plasterboard each side (See Report Ref. for full installation details)"	EWFA RIR 38022100

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
CONSTRUCTION JOINTS						
Control Joints and Gap Seals in Plaster Board	"Horizontal Deflection Head or Top-of-wall, Fire Rated Plasterboard to Concrete"	Plaster Board Wall; lined with min. 1 x 13mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Backfilling material: PE rod or Mineral Stone wool"	-/60/60	"Max. joint width: 20mm Min. depth of sealant: depth of wall lining (13mm) Min. Mineral Stone Wool density: 100kg/m3 (See Report Ref. for full installation details)"	EWFA RIR 29226700.1
Control Joints and Gap Seals in Plaster Board	"Horizontal Deflection Head or Top-of-wall, Fire Rated Plasterboard to Concrete"	Plaster Board Wall; lined with min. 1 x 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 96mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Backfilling material: PE rod or Mineral Stone wool"	-/90/90	"Max. joint width: 20mm Min. depth of sealant: depth of wall lining (16mm) Min. Mineral Stone Wool density: 100kg/m3 (See Report Ref. for full installation details)"	EWFA RIR 29226700.1
Control Joints and Gap Seals in Plaster Board	"Horizontal Deflection Head"	Plaster Board Wall; lined with min. 2 x min. 13mm /16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Backfilling material: PE rod or Mineral Stone wool"	-/120/120	"Max. joint width: 30mm Min. depth of sealant: 20mm Min. Mineral Stone Wool density: 100kg/m3 (See Report Ref. for full installation details)"	EWFA RIR 29226700.1
Control Joints and Gap Seals in Plaster Board	"Horizontal Deflection Head"	Plaster Board Wall; lined with min. 2 x min. 13mm /16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Backfilling material: PE rod or Mineral Stone wool"	-/120/120	"Max. joint width: 30mm Min. depth of sealant: depth of wall linings (26mm or 32mm) Min. Mineral Stone Wool density: 100kg/m3 (See Report Ref. for full installation details)"	EWFA RIR 29226700.1
Control Joints and Gap Seals in Plaster Board	"Horizontal Wall, Fire Rated Plasterboard to Floor"	Plaster Board Wall; lined with min. 2 x min. 13mm /16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Backfilling material: PE rod or Mineral Stone wool"	-/120/120	"Max. joint width: 30mm Min. depth of sealant: 20mm Min. Mineral Stone Wool density: 100kg/m3 (See Report Ref. for full installation details)"	EWFA RIR 29226700.1
Control Joints and Gap Seals in Plaster Board	"Horizontal Wall, Fire Rated Plasterboard to Floor"	Plaster Board Wall; lined with min. 2 x min. 13mm /16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Backfilling material: PE rod or Mineral Stone wool"	-/120/120	"Max. joint width: 30mm Min. depth of sealant: depth of wall linings (26mm or 32mm) Min. mineral wool density: 100kg/m3 (See Report Ref. for full installation details)"	EWFA RIR 29226700.1
Control Joints and Gap Seals in Plaster Board	"Horizontal Deflection Head"	Plaster Board Wall; lined with min. 2x min. 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	Hilti CP 606 Acrylic Fire Rated Sealant	-/180/180	"Max. joint width: 27mm Min. depth of sealant: 32mm (See Report Ref. for full installation details)"	EWFA RIR 29226700.1
Control Joints and Gap Seals in Plaster Board	"Vertical Wall to Wall and Control Joints"	Plaster Board Wall; lined with min. 1 x min. 13mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Mineral Stone wool "	-/60/60	"Max. joint width: 30mm Min. depth of sealant: depth of wall lining (13mm) Min. Mineral Stone Wool density: 100kg/m3 (See Report Ref. for full installation details)"	EWFA RIR 29226700.1
Control Joints and Gap Seals in Plaster Board	"Vertical Wall to Wall and Control Joints"	Plaster Board Wall; lined with min. 1 x 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 96mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Mineral Stone wool "	-/90/90	"Max. joint width: 30mm Min. depth of sealant: depth of wall lining (16mm) Min. Mineral Stone Wool density: 100kg/m3 (See Report Ref. for full installation details)"	EWFA RIR 29226700.1

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
CONSTRUCTION JOINTS						
Control Joints and Gap Seals in Plaster Board	"Vertical Wall to Wall and Control Joints"	Plaster Board Wall; lined with min. 2 x min. 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Backfilling material: PE rod or Mineral Stone wool"	-/120/120	"Max. joint width: 30mm Min. depth of sealant: 20mm Min. Mineral Stone Wool density: 100kg/m3 (See Report Ref. for full installation details)"	EWFA RIR 29226700.1
Control Joints and Gap Seals in Plaster Board	"Vertical Wall to Wall and Control Joints"	Plaster Board Wall; lined with min. 2 x min. 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Backfilling material: PE rod or Mineral Stone wool"	-/120/120	"Max. joint width: 30mm Min. depth of sealant: 40mm Min. Mineral Stone Wool density: 100kg/m3 (See Report Ref. for full installation details)"	EWFA RIR 29226700.1
Linear Joints and Gap Seals in Rigid Walls	"Horizontal Deflection Head"	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 100mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Backfilling material: PE rod or Mineral Stone wool"	-/120/120	"Max. joint width: 30mm Min. depth of sealant: 20mm Min. Mineral Stone Wool density: 100kg/m3 (See Report Ref. for full installation details)"	EWFA RIR 29226700.1
Linear Joints and Gap Seals in Rigid Walls	"Horizontal Deflection Head"	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 100mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Backfilling material: PE rod or Mineral Stone wool"	-/120/120	"Max. joint width: 30mm Min. depth of sealant: 40mm Min. Mineral Stone Wool density: 100kg/m3 (See Report Ref. for full installation details)"	EWFA RIR 29226700.1
Linear Joints and Gap Seals in Rigid Walls	"Horizontal Wall to Ceiling"	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 100mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Backfilling material: PE rod or Mineral Stone wool"	-/120/120	"Max. joint width: 30mm Min. depth of sealant: 20mm Min. Mineral Stone Wool density: 100kg/m3 (See Report Ref. for full installation details)"	EWFA RIR 29226700.1
Linear Joints and Gap Seals in Rigid Walls	"Horizontal Wall to Ceiling"	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 100mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Backfilling material: PE rod or Mineral Stone wool"	-/120/120	"Max. joint width: 30mm Min. depth of sealant: 40mm Min. Mineral Stone Wool density: 100kg/m3 (See Report Ref. for full installation details)"	EWFA RIR 29226700.1
Linear Joints and Gap Seals in Rigid Walls	"Vertical Wall to Wall and Control Joints"	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 100mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Backfilling material: PE rod or Mineral Stone wool"	-/120/120	"Max. joint width: 30mm Min. depth of sealant: 20mm Min. Mineral Stone Wool density: 100kg/m3 (See Report Ref. for full installation details)"	EWFA RIR 29226700.1
Linear Joints and Gap Seals in Rigid Walls	"Vertical Wall to Wall and Control Joints"	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 100mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Backfilling material: PE rod or Mineral Stone wool"	-/120/120	"Max. joint width: 30mm Min. depth of sealant: 40mm Min. Mineral Stone Wool density: 100kg/m3 (See Report Ref. for full installation details)"	EWFA RIR 29226700.1
Linear Joints and Gap Seals in Rigid Walls	"Horizontal Deflection Head"	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 230mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Backfilling material: PE rod or Mineral Stone wool"	-/240/240	"Max. joint width: 30mm Min. depth of sealant: 20mm Min. Mineral Stone Wool density: 100kg/m3 (See Report Ref. for full installation details)"	EWFA RIR 29226700.1

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
CONSTRUCTION JOINTS						
Linear Joints and Gap Seals in Rigid Walls	"Horizontal Deflection Head"	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 230mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Backfilling material: PE rod or Mineral Stone wool"	-/240/180	"Max. joint width: 30mm Min. depth of sealant: 40mm Min. Mineral Stone Wool density: 100kg/m3 (See Report Ref. for full installation details)"	EWFA RIR 29226700.1
Linear Joints and Gap Seals in Rigid Walls	"Horizontal Wall to Ceiling"	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 230mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Backfilling material: PE rod or Mineral Stone wool"	-/240/240	"Max. joint width: 30mm Min. depth of sealant: 20mm Min. Mineral Stone Wool density: 100kg/m3 (See Report Ref. for full installation details)"	EWFA RIR 29226700.1
Linear Joints and Gap Seals in Rigid Walls	"Horizontal Wall to Ceiling"	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 230mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Backfilling material: PE rod or Mineral Stone wool"	-/240/180	"Max. joint width: 30mm Min. depth of sealant: 40mm Min. Mineral Stone Wool density: 100kg/m3 (See Report Ref. for full installation details)"	EWFA RIR 29226700.1
Linear Joints and Gap Seals in Rigid Walls	"Vertical Wall to Wall and Control Joints"	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 230mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Backfilling material: PE rod or Mineral Stone wool "	-/240/240	"Max. joint width: 30mm Min. depth of sealant: 20mm Min. mineral wool density: 100kg/m3 (See Report Ref. for full installation details)"	EWFA RIR 29226700.1
Linear Joints and Gap Seals in Rigid Walls	"Vertical Wall to Wall and Control Joints"	Rigid Wall; Solid Concrete / Aerated Concrete / Masonry (Min. Wall Thickness 230mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Backfilling material: PE rod or Mineral Stone wool"	-/240/180	"Max. joint width: 30mm Min. depth of sealant: 40mm Min. Mineral Stone Wool density: 100kg/m3 (See Report Ref. for full installation details)"	EWFA RIR 29226700.1
Gap Seals between Walls and Floors with Metal Decks	"Horizontal Fire Rated Plasterboard Wall Parallel with deck profile or Fire Rated Plasterboard Wall Across the deck profile"	Plaster Board Wall; lined with min. 1 x min. 13mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 90mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Backfilling material: PE rod or Mineral Stone wool"	-/60/60	"Max. joint width: 65mm Min. depth of sealant: 5mm Min. Mineral Stone Wool density: 100kg/m3 (See Report Ref. for full installation details)"	EWFA RIR 29226700.1
Gap Seals between Walls and Floors with Metal Decks	"Horizontal Fire Rated Plasterboard Wall Parallel with deck profile or Fire Rated Plasterboard Wall Across the deck profile"	Plaster Board Wall; lined with min. 1 x min. 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 96mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Backfilling material: Mineral Stone wool "	-/90/90	"Max. joint width: 65mm Min. depth of sealant: 5mm Min. Mineral Stone Wool density: 100kg/m3 (See Report Ref. for full installation details)"	EWFA RIR 29226700.1
Gap Seals between Walls and Floors with Metal Decks	"Horizontal Fire Rated Plasterboard Wall Parallel with deck profile or Fire Rated Plasterboard Wall Across the deck profile"	Plaster Board Wall; lined with min. 2 x min. 13mm or 16mm Fire Rated Plasterboard each side of stud (Min. Wall Thickness 100mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Backfilling material: Mineral Stone wool "	-/120/120	"Max. joint width: 65mm Min. depth of sealant: 5mm Min. Mineral Stone Wool density: 100kg/m3 (See Report Ref. for full installation details)"	EWFA RIR 29226700.1
Linear Joints and Gap Seals in Rigid Floors	Floor; Mid Slab Concrete Joint	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Backfilling material: PE Rod"	-/240/240	"Max. joint width: 20mm Min. depth of sealant: 10mm (See Report Ref. for full installation details)"	EWFA RIR 29226700.1

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
CONSTRUCTION JOINTS						
Linear Joints and Gap Seals in Rigid Floors	Floor; Mid Slab Concrete Joint	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Backfilling material: CF 126 Foam"	-/240/180	"Max. joint width: 20mm Min. depth of sealant: 15mm Min. depth of backfilling material: 135mm"	EWFA RIR 29226700.1
Linear Joints and Gap Seals in Rigid Floors	Floor; Mid Slab Concrete Joint	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Backfilling material: Mineral Stone wool"	-/240/180	"Max. joint width: 30mm Min. depth of sealant: 15mm Min. Mineral Stone Wool density: 100kg/m3 Min. Mineral Stone wool depth: 70mm (See Report Ref. for full installation details)"	EWFA RIR 29226700.1
Linear Joints and Gap Seals in Rigid Floors	Floor; Mid Slab Concrete Joint	Rigid Floor; Solid Concrete / Aerated Concrete (Min. Floor Thickness 150mm)	"Hilti CP 606 Acrylic Fire Rated Sealant + Backfilling material: Mineral Stone wool"	-/240/240	"Max. joint width: 15mm Min. depth of sealant: 6mm Min. Mineral Stone wool density: 100kg/m3 Min. Mineral Stone wool depth: 144mm (See Report Ref. for full installation details)"	EWFA RIR 29226700.1

iPASSIVE

Manufacturer Code: IP

42 Tarndale Grove
Rosedale
Auckland 0630Ph: (09) 283 0300
Email: info@ipassivefire.com
Website: www.ipassivefire.com

The products listed in this register have all been tested to AS1530.4-2005 or Assessed to AS 4072.1-2005 as referenced within the New Zealand Building Code.

Service Penetration	Orientation	Substrate	System Description	FRR	Test Dims	Report Ref
BLANK SEALS						
Blank	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Acrylic either side or any position in between with stone wool backing min 35kg/m3 density	-/240/60	min seal depth 25mm, max seal size 300x300mm, min 48mm backing	FAS180387C.1
Blank	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Acrylic either side or any position in between with stone wool backing min 35kg/m3 density	-/240/120	min seal depth 25mm, max seal size 35x35mm/Ø36mm, min 48mm backing	FAS180387C.1
Blank	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Acrylic to both sides with stone wool backing min 35kg/m3 density, min annular 10mm	-/240/240	min seal depth 15mm, max seal size 300x300mm, min 25mm thick backing	FAS180387C.1
Blank	Wall	Plasterboard from 75mm, single layer 13mm board	iPASSIVE FR Acrylic to both sides with any backing material, min annular 10mm	-/60/60	min seal depth 12.5mm, max seal size 150x150mm / Ø344mm	FAS180387C.1
Blank	Wall	Plasterboard from 100mm	iPASSIVE FR Acrylic to both sides backed with 20mm deep stone wool 35-140kg/m3	-/120/120	min seal depth 12.5mm, max seal size 300x300mm	FAS180387C.1
Blank	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 15mm deep to top side backed with 20mm deep stone wool min 35kg/m3	-/90/60	min seal depth 15mm, max seal size 300x300mm	FAS180387C.1
Blank	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep to top side backed with 25mm deep stone wool min 35kg/m3	-120/120	min seal depth 25mm, max seal size 300x300mm	FAS180387C.1
Blank	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep to top side backed with 48mm AES mineral fibre	-240/240	min seal depth 15mm, max seal size 300x300mm	FAS180387C.1
Blank	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep to both sides backed with 25mm deep stone wool min 35kg/m3	-/240/240	min seal depth 15mm, max seal size 300x300mm	FAS180387C.1
Blank	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/240	max seal size 1200x1200mm	FAS180387A.1
Blank	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/180	max seal size 1200 x unlimited width	FAS180387A.1
Blank	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/90	max seal size 1200 x unlimited width	FAS180387A.1
Blank	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, protruding, boards separated by min 90mm , perimeter edges sealed with iPASSIVE FR Acrylic	-/240/180	max seal size 600x600mm	FAS180387A.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
BLANK SEALS						
Blank	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, pattress, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/180	max seal size 600x600mm, pattress fixed with 100mm steel screws & penny washers / 350mm centres, min 50mm overlap on opening	FAS180387A.1
Blank	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/180/180	max seal size 1200 x 600mm	FAS180387A.1
Blank	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/180/120	max seal size 2400 x 1200mm	FAS180387A.1
Blank	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/120	max seal size 1200 x 600mm	FAS180387A.1
Blank	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/120/90	max seal size 2400 x 1200mm	FAS180387A.1
Blank	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 1-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/120/120	max seal size 1200 x 2400mm wide	FAS180387A.1
Blank	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool 150kg /m3 backing	-/180/120	max seal size 1200 x 2400mm wide	FAS180387D.1
Blank	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 100mm to either side	-/240/240	max seal size 1200 x 2400mm wide	FAS180387D.1
Blank	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 50mm to both sides, 50mm stone wool 150kg /m3 backing	-/240/240	max seal size 1200 x 2400mm wide	FAS180387D.1
Blank	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm flush to top side, 50mm stone wool 150kg /m3 backing	-/180/180	max seal size 1200 x 2400mm, min 30mm separation	FAS180387D.1
Blank	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 100mm flush to top side	-/240/240	max seal size 1200 x 2400mm	FAS180387D.1
Blank	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 150mm	-/240/180	max seal size 1200 x 2400mm	FAS180387D.1
Blank	Wall	Plasterboard from 100mm	iPASSIVE EX Mortar 25mm both sides, 50mm stone wool 150kg /m3 backing	-/120/120	max seal size 1200 x 2400mm wide	FAS180387D.1
Blank	Wall	Flexible or Rigid walls ≥100mm	iPASSIVE FR Putty Cord 15mm both sides	-/120/120	max seal size 15mm	FAS180387E.1
Blank	Floor	Concrete, Aerated concrete, Masonry, from 150mm	iPASSIVE FR Putty Cord 15mm to bottom face	-/120/30	max seal size 15mm	FAS180387E.1
Blank	Floor	Concrete, Aerated concrete, Masonry, from 150mm	iPASSIVE FR Putty Cord 15mm both sides	-/120/120	max seal size 15mm	FAS180387E.1
NON-INSULATED NON-COMBUSTIBLE PIPES						
Mild/ Stainless Steel Ø4mm / 0.7 - 2 mm wall	Wall	Plasterboard from 75mm, single layer 13mm board	iPASSIVE FR Acrylic 12.5mm deep, to both sides, min annular 10mm	-/60/45	min seal depth 12.5mm, max seal size 150x150mm / Ø344mm	FAS180387C.1
Mild/ Stainless Steel Ø5 - Ø22mm / 0.7 - 11 mm wall	Wall	Plasterboard from 75mm, single layer 13mm board	iPASSIVE FR Acrylic 12.5mm deep, to both sides, min annular 10mm	-/60/30	min seal depth 12.5mm, max seal size 150x150mm / Ø344mm	FAS180387C.1
Mild/Stainless steel, Ø22mm / 3 - 10mm wall	Wall	Plasterboard from 100mm	iPASSIVE FR Acrylic 25mm deep, to both sides, backed with 25mm deep stone wool 35kg/m3, closed systems only*	-/120/120	min seal depth 25mm, max seal size 300x300mm	FAS180387C.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED NON-COMBUSTIBLE PIPES						
Pex Ø15mm x 2.5mm wall inner / Ø25mm outer	Wall	Plasterboard from 100mm	iPASSIVE FR Acrylic 12.5mm deep, to both sides, backed with 12.5mm deep stone wool 35kg/m3, pipes fitted at any position within aperture, closed systems only*	-/120/120	min seal depth 12.5mm, max seal size 300x300mm / Ø504mm, min 10mm annular	FAS180387C.1
Alupex Ø16- Ø20mm / 2mm wall	Wall	Plasterboard from 100mm	iPASSIVE FR Acrylic 12.5mm deep, to both sides, backed with 12.5mm deep stone wool 35kg/m3, pipes fitted at any position within aperture, closed systems only*	-/120/120	min seal depth 12.5mm, max seal size 300x300mm / Ø504mm, min 10mm annular	FAS180387C.1
Mild/Stainless Steel Ø4mm / 1 - 2mm wall	Wall	Plasterboard from 100mm	iPASSIVE FR Acrylic 12.5mm deep, to both sides, backed with 12.5mm deep stone wool 35kg/m3, pipes fitted at any position within aperture, closed systems only*	-/90/90	min seal depth 12.5mm, max seal size 300x300mm / Ø504mm, min 10mm annular	FAS180387C.1
Mild/Stainless Steel Ø5 - Ø30mm / 1 - 14.2mm wall	Wall	Plasterboard from 100mm	iPASSIVE FR Acrylic 12.5mm deep, to both sides, backed with 12.5mm deep stone wool 35kg/m3, pipes fitted at any position within aperture, closed systems only*	-/90/90	min seal depth 12.5mm, max seal size 300x300mm / Ø504mm, min 10mm annular	FAS180387C.1
Mild/Stainless Steel Ø30mm / 2 - 14.2mm wall	Wall	Plasterboard from 100mm	iPASSIVE FR Acrylic 12.5mm deep, to both sides, backed with 12.5mm deep stone wool 35kg/m3, pipes fitted at any position within aperture	-/120/120	min seal depth 12.5mm, max seal size 300x300mm / Ø504mm, min 10mm annular	FAS180387C.1
Copper/Steel Ø6mm / 0.7 - 3mm wall	Wall	Plasterboard from 100mm	iPASSIVE FR Acrylic 12.5mm deep, to both sides, backed with 12.5mm deep stone wool 35kg/m3, pipes fitted at any position within aperture	-/90/60	min seal depth 12.5mm, max seal size 300x300mm / Ø504mm, min 10mm annular	FAS180387C.1
Copper/Steel Ø7 - Ø22mm / 0.7 - 11mm wall	Wall	Plasterboard from 100mm	iPASSIVE FR Acrylic 12.5mm deep, to both sides, backed with 12.5mm deep stone wool 35kg/m3, pipes fitted at any position within aperture	-/90/30	min seal depth 12.5mm, max seal size 300x300mm / Ø504mm, min 10mm annular	FAS180387C.1
Mild/Stainless Steel Ø4 - Ø16mm / 1 - 8mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to top side, backed with 48mm deep stone wool 33kg/m3, pipes fitted at any position within aperture	-/120/120	min seal depth 25mm, max seal size 300x300mm / Ø300mm, min 10mm annular, min 30mm between penetration seals	FAS180387C.1
Copper/Steel Ø6mm / 0.7 - 3mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to top side, backed with 48mm deep stone wool 33kg/m3, pipes fitted at any position within aperture, closed systems only*	-/120/120	min seal depth 25mm, max seal size 300x300mm / Ø300mm, min 10mm annular, min 30mm between penetration seals	FAS180387C.1
Copper/Steel Ø6 - Ø15mm / 0.7 - 7.5mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to top side, backed with 48mm deep stone wool 33kg/m3, pipes fitted at any position within aperture, closed systems only*	-/120/60	min seal depth 25mm, max seal size 300x300mm / Ø300mm, min 10mm annular, min 30mm between penetration seals	FAS180387C.1
Pex Ø15mm x 2.5mm wall inner / Ø25mm outer	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to either side or any position in between, backed with 25mm deep AES mineral fibre, pipes fitted at any position within aperture, closed systems only*	-/90/90	min seal depth 25mm, max seal size 300x300mm / Ø504mm, min 10mm annular, min seal separation 30mm, 30-80mm thick stone wool insulation 80kg/m3	FAS180387C.1
Copper up to Ø54mm / 2 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to both sides, backed with 25mm deep stone wool 140kg/m3, (single) pipes fitted at any position within aperture	-/120/-	min seal depth 25mm, max seal size 300x300mm	FAS180387C.1
Mild Steel up to Ø16mm / 1.5 - 7.5mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to both sides, backed with 25mm deep stone wool 140kg/m3, (single) pipes fitted at any position within aperture	-240/240	min seal depth 25mm, max seal size 300x300mm	FAS180387C.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED NON-COMBUSTIBLE PIPES						
Mild Steel up to Ø16mm / 1.5 - 7.5mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to both sides, backed with 25mm deep AES mineral fibre (single) pipes fitted at any position within aperture	-/120/120	min seal depth 25mm, max seal size up to 100x1000mm	FAS180387C.1
Copper/Steel conduit up to Ø16mm	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/30/-	max seal size 2400 x 1200mm	FAS180387A.1
Steel conduit up to Ø16mm	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 1-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/60/60	max seal size 1200 x 2400mm wide	FAS180387A.1
Copper conduit up to Ø16mm	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 1-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/60/45	max seal size 1200 x 2400mm wide	FAS180387A.1
Steel conduit up to Ø16mm	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool 150kg /m3 backing	-/180/60	max seal size 1200 x 2400mm wide, min 25mm seal separation	FAS180387D.1
Copper conduit up to Ø16mm	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool 150kg /m3 backing	-/180/60	max seal size 1200 x 2400mm wide, min 25mm seal separation	FAS180387D.1
Steel conduit up to Ø16mm	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 100mm to either side	-/180/60	max seal size 1200 x 2400mm wide, min 25mm seal separation	FAS180387D.1
Copper conduit up to Ø16mm	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 100mm to either side	-/180/30	max seal size 1200 x 2400mm wide, min 25mm seal separation	FAS180387D.1
Steel conduit up to Ø16mm	Wall	Plasterboard from 100mm	iPASSIVE EX Mortar 25mm both sides, 50mm stone wool 150kg /m3 backing	-/120/60	max seal size 1200 x 2400mm wide, min 25mm separation	FAS180387D.1
Copper conduit up to Ø16mm	Wall	Plasterboard from 100mm	iPASSIVE EX Mortar 25mm both sides, 50mm stone wool 150kg /m3 backing	-/120/45	max seal size 1200 x 2400mm wide, min 25mm separation	FAS180387D.1
INSULATED NON-COMBUSTIBLE PIPES						
Copper, interrupted, up to Ø54mm / 0.9 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Acrylic 15mm deep, to either side or any position in between, backed with 20mm deep 40kg/m3 stone wool,	-/240/180	8-9mm seal width around pipe, min 1000x20mm Stone wool insulation(80kg/m3)	FAS180387C.1
Copper, interrupted, up to Ø12mm / 0.9 - 5mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Acrylic 15mm deep, to either side or any position in between, backed with 20mm deep 40kg/m3 stone wool,	-/240/240	8mm seal width around pipe, min 1000x20mm Stone wool insulation(80kg/m3)	FAS180387C.1
Alupex, interrupted, up to Ø75mm / 7.5mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Acrylic 15mm deep, to either side or any position in between, backed with 20mm deep 40kg/m3 stone wool,	-/120/120	30mm seal width around pipe, 600x25mm AES fibre insulation	FAS180387C.1
Steel, interrupted, Ø40 - Ø219mm / 1.5 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Acrylic 15mm deep, to either side or any position in between, backed with 20mm deep 40kg/m3 stone wool,	-/180/90	6-18mm seal width around pipe, 1000x30mm stone wool insulation(80kg/m3)	FAS180387C.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
Copper, interrupted, up to Ø54mm / 0.9 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to either side or any position in between, backed with 20mm deep 40kg/m3 stone wool,	-240/60	300x300mm max seal size min 1000x20mm Stone wool insulation(80kg/m3)	FAS180387C.1
Copper, interrupted, up to Ø12mm / 0.9 - 5mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to either side or any position in between, backed with 20mm deep 40kg/m3 stone wool,	-/240/60	300x300mm max seal size min 1000x20mm Stone wool insulation(80kg/m3)	FAS180387C.1
Alupex, interrupted , up to Ø75mm / 7.5mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to either side or any position in between, backed with 20mm deep 40kg/m3 stone wool,	-/240/60	300x300mm max seal size, 600x25mm AES fibre insulation	FAS180387C.1
Steel, interrupted, Ø40 - Ø219mm / 1.5 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to either side or any position in between, backed with 20mm deep 40kg/m3 stone wool,	-/240/60	300x300mm max seal size, 1000x30mm stone wool insulation(80kg/m3)	FAS180387C.1
Steel, continuous, Ø40mm /1-14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to either side or any position in between, backed with 48mm deep AES mineral fibre	-/240/240	300x300mm /Ø504mm max seal size, min 10mm annular, 20mm thick stone wool insulation(80kg/m3)	FAS180387C.1
Steel, continuous, Ø40 - Ø300mm / 1 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to either side or any position in between, backed with 48mm deep AES mineral fibre	-/180/180	300x300mm / Ø504mm max seal size, min 10mm annular, 30-80mm thick stone wool insulation(80kg/m3)	FAS180387C.1
Steel, interrupted, Ø40 / 1.5- 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Acrylic 15mm deep, to both sides, backed with 20/30mm deep 40kg/m3 stone wool	-/240/240	300x300mm max seal size, min 1000x20mm stone wool insulation(80kg/m3)	FAS180387C.1
Steel, interrupted, Ø40 - Ø219mm / 1.5- 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Acrylic 15mm deep, to both sides, backed with 20/30mm deep 40kg/m3 stone wool	-/240/120	300x300mm max seal size, min 1000x30mm stone wool insulation(80kg/m3)	FAS180387C.1
Steel, continuous, Ø40 - Ø324mm / 1.5- 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Acrylic 15mm deep, to both sides, backed with 25mm deep 35kg/m3 stone wool	-240/240	300x300mm / Ø504mm max seal size, min 10mm annular, 30-80mm thick stone wool insulation(80kg/m3)	FAS180387C.1
Steel, continuous, Ø22mm / 2 - 11mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to both sides, backed with 25mm deep 35kg/m3 stone wool,	-/240/180	300x300mm / Ø300mm max seal size, min 10mm annular, 13mm thick Elastomeric Insulation	FAS180387C.1
Steel, continuous, Ø22 - Ø114mm / 2 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to both sides, backed with 25mm deep 35kg/m3 stone wool,	-/120/90	300x300mm / Ø300mm max seal size, min 10mm annular, 13- 25mm thick Elastomeric Insulation	FAS180387C.1
Steel, continuous, Ø22 - Ø114mm / 2 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to both sides, backed with 25mm deep 35kg/m3 stone wool,	-/60/60	300x300mm / Ø300mm max seal size, min 10mm annular, 25 - 50mm thick Elastomeric Insulation	FAS180387C.1
Mild/Stainless steel, continuous, Ø40 - Ø324mm / 1 - 14.2mm wall	Wall	Plasterboard from 75mm, single layer 13mm board	iPASSIVE FR Acrylic 12.5mm deep, to both sides, 30mm thick stone wool insulation (80kg/m3)	-/60/45	min seal depth 12.5mm, max seal size 150x150mm / Ø344mm, min 10mm annular	FAS180387C.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
Mild/Stainless steel, continuous, Ø40mm / 1 - 14.2mm wall	Wall	Plasterboard from 100mm	iPASSIVE FR Acrylic 12.5mm deep, to both sides, backed with 20mm deep stone wool (40kg/m3), closed systems only*	-/120/120	min seal depth 12.5mm, max seal size 300x300mm, 13-19mm Elastomeric Insulation	FAS180387C.1
Mild/Stainless steel, continuous, Ø40 - Ø165mm / 1 - 14.2mm wall	Wall	Plasterboard from 100mm	iPASSIVE FR Acrylic 25mm deep, to both sides, backed with 20mm deep stone wool (40kg/m3), closed systems only*	-/120/60	min seal depth 25mm, max seal size 300x300mm, 13-19mm Elastomeric Insulation	FAS180387C.1
Copper, continuous, Ø12mm / 1mm wall	Wall	Plasterboard from 100mm	iPASSIVE FR Acrylic 25mm deep, to both sides, backed with 25mm deep AES mineral fibre, closed systems only*	-/120/120	min seal depth 25mm, max seal size 300x300mm, 9mm Elastomeric Insulation	FAS180387C.1
Copper, continuous, Ø12 - Ø54mm / 1 - 1.2mm wall	Wall	Plasterboard from 100mm	iPASSIVE FR Acrylic 25mm deep, to both sides, backed with 25mm deep AES mineral fibre, closed systems only*	-/120/60	min seal depth 25mm, max seal size 300x300mm, 9-13mm Elastomeric Insulation	FAS180387C.1
Copper, continuous, Ø12 - Ø54mm / 1 - 1.2mm wall	Wall	Plasterboard from 100mm	iPASSIVE FR Acrylic 25mm deep, to both sides, backed with 25mm deep AES mineral fibre, closed systems only*	-/60/60	min seal depth 25mm, max seal size 300x300mm, 13-25mm Elastomeric Insulation	FAS180387C.1
Alupex, continuous, Ø16mm / 2.25mm wall	Wall	Plasterboard from 100mm	iPASSIVE FR Acrylic 25mm deep, to both sides, backed with 25mm deep AES mineral fibre, closed systems only*	-/120/120	min seal depth 25mm, max seal size 300x300mm, 9mm Elastomeric Insulation	FAS180387C.1
Alupex, continuous, Ø16mm - Ø75mm / 2.25 - 4.7mm wall	Wall	Plasterboard from 100mm	iPASSIVE FR Acrylic 25mm deep, to both sides, backed with 25mm deep AES mineral fibre, closed systems only*	-/60/60	min seal depth 25mm, max seal size 300x300mm, 9-25mm Elastomeric Insulation	FAS180387C.1
Mild/Stainless steel, continuous, Ø40mm - Ø324mm / 1 - 14.2mm wall	Wall	Plasterboard from 100mm	iPASSIVE FR Acrylic 12.5mm deep, to both sides, backed with 12.5mm deep stone wool 35kg/m3, pipes fitted at any position within aperture	-/120/90	min seal depth 12.5mm, max seal size 300x300mm / Ø504mm, 30-80mm thick stone wool insulation (80kg/m3)	FAS180387C.1
Alupex, continuous or interrupted, Ø16 - Ø75mm / 2.25 - 4.7 mm wall	Wall	Plasterboard from 100mm	iPASSIVE FR Acrylic 12.5mm deep, to both sides, backed with 12.5mm deep stone wool 40kg/m3, pipes fitted at any position within aperture, closed systems only*	-/120/120	min seal depth 12.5mm, max seal size 300x300mm, min 10mm annular, 500x 20mm thick stone wool insulation 80kg/m3 (both sides)	FAS180387C.1
Copper, interrupted, up to Ø54mm / 1 - 14.2mm wall	Wall	Plasterboard from 100mm	iPASSIVE FR Acrylic 12.5mm deep, to both sides, backed with 20mm deep stone wool 40kg/m3, pipes fitted at any position within aperture	-/120/120	min seal depth 12.5mm, max seal size 300x300mm, min 10mm annular, 500x 20mm thick stone wool insulation 80kg/m3 (both sides)	FAS180387C.1
Alupex, interrupted, Ø75mm / 7.5 mm wall	Wall	Plasterboard from 100mm	iPASSIVE FR Acrylic 12.5mm deep, to both sides, backed with 20mm deep stone wool 140kg/m3, pipes fitted at any position within aperture	-/60/60	min seal depth 12.5mm, max seal size 300x300mm, min 10mm annular, 600x 20mm thick AES mineral fibre insulation	FAS180387C.1
Mild/Stainless steel, interrupted, Ø40mm / 1 - 14.2mm wall	Wall	Plasterboard from 100mm	iPASSIVE FR Acrylic 12.5mm deep, to both sides, backed with 20mm deep stone wool 40kg/m3, pipes fitted at any position within aperture	-/120/120	min seal depth 12.5mm, max seal size 300x300mm, min 10mm annular, 500x 20mm thick stone wool insulation 80kg/m3	FAS180387C.1
Mild/Stainless steel, interrupted, Ø40 - Ø219mm / 1 - 14.2mm wall	Wall	Plasterboard from 100mm	iPASSIVE FR Acrylic 12.5mm deep, to both sides, backed with 20mm deep stone wool 40kg/m3, pipes fitted at any position within aperture	-/120/90	min seal depth 12.5mm, max seal size 300x300mm, min 10mm annular, 500x 30mm thick stone wool insulation 80kg/m3	FAS180387C.1
Copper/Steel, continuous, Ø12mm / 0.9 - 6mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to top side, backed with 48mm deep stone wool 33kg/m3, pipes fitted at any position within aperture, closed systems only*	-/240/240	min seal depth 25mm, max seal size 300x300mm / Ø300mm, min 10mm annular, min 30mm between penetration seals, 20-80mm stone wool insulation 80kg/m3	FAS180387C.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
Copper/Steel, continuous, Ø13-Ø54mm / 0.9 - 14.2mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to top side, backed with 48mm deep stone wool 33kg/m ³ , pipes fitted at any position within aperture, closed systems only*	-/240/180	min seal depth 25mm, max seal size 300x300mm / Ø300mm, min 10mm annular, min 30mm between penetration seals, 20-80mm stone wool insulation 80kg/m ³	FAS180387C.1
Alupex, continuous, Ø16-Ø20mm / 2mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to top side, backed with 48mm deep stone wool 33kg/m ³ , pipes fitted at any position within aperture, closed systems only*	-/120/120	min seal depth 25mm, max seal size 300x300mm / Ø300mm, min 10mm annular, min 30mm between penetration seals, 20-80mm stone wool insulation 80kg/m ³	FAS180387C.1
Copper, interrupted, up to Ø54mm / 0.9 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 15mm deep, to either side or any position in between, backed with 20mm deep 40kg/m ³ stone wool, pipes fitted at any position within aperture	-/240/180	10mm seal width around pipe, min 1000x20mm Stone wool insulation(80kg/m ³)	FAS180387C.1
Copper, interrupted, up to Ø12mm / 0.9 - 5mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 15mm deep, to either side or any position in between, backed with 20mm deep 40kg/m ³ stone wool, pipes fitted at any position within aperture	-/240/240	10mm seal width around pipe, min 1000x20mm Stone wool insulation(80kg/m ³)	FAS180387C.1
Copper, interrupted, up to Ø54mm / 0.9 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to either side or any position in between, backed with 20mm deep 40kg/m ³ stone wool,	-/120/120	min seal depth 25mm, max seal size up to 100x1000mm, min 1000x20mm Stone wool insulation(80kg/m ³)	FAS180387C.1
Copper, interrupted, up to Ø54mm / 0.9 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 15mm deep, to either side or any position in between, backed with 20mm deep 40kg/m ³ stone wool, pipes fitted at any position within aperture	-/90/60	min seal depth 15mm, max seal size 300x300mm, min 1000x20mm thick stone wool insulation 80kg/m ³	FAS180387C.1
Copper, interrupted, up to Ø12mm / 0.9 - 5mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 15mm deep, to either side or any position in between, backed with 20mm deep 40kg/m ³ stone wool, pipes fitted at any position within aperture	-/90/60	min seal depth 15mm, max seal size 300x300mm, min 1000x20mm thick stone wool insulation 80kg/m ³	FAS180387C.1
Copper, interrupted, up to Ø54mm / 0.9 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to either side or any position in between, backed with 20mm deep 40kg/m ³ stone wool,	-/120/120	min seal depth 25mm, max seal size 300x300mm, min 1000x20mm thick stone wool insulation 80kg/m ³	FAS180387C.1
Mild/Stainless steel, interrupted, Ø40mm / 1 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 15mm deep, to either side or any position in between, backed with 20mm deep 40kg/m ³ stone wool, pipes fitted at any position within aperture	-/240/240	min seal depth 15mm, max seal size 10mm around pipe, min 1000x20mm thick stone wool insulation 80kg/m ³	FAS180387C.1
Mild/Stainless steel, interrupted, Ø40 - Ø219mm / 1 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 15mm deep, to either side or any position in between, backed with 20mm deep 40kg/m ³ stone wool, pipes fitted at any position within aperture	-/240/90	min seal depth 15mm, max seal size 10mm around pipe, min 1000x30mm thick stone wool insulation 80kg/m ³	FAS180387C.1
Mild/Stainless steel, interrupted, Ø40mm / 1 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to either side or any position in between, backed with 20mm deep 40kg/m ³ stone wool, pipes fitted at any position within aperture	-/120/90	min seal depth 25mm, max seal size up to 100x1000mm, min 1000x20mm thick stone wool insulation 80kg/m ³	FAS180387C.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
Mild/Stainless steel, interrupted, Ø40 - Ø219mm / 1 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to either side or any position in between, backed with 20mm deep 40kg/m ³ stone wool, pipes fitted at any position within aperture	-/120/90	min seal depth 25mm, max seal size up to 100x1000mm, min 1000x30mm thick stone wool insulation 80kg/m ³	FAS180387C.1
Mild/Stainless steel, interrupted, Ø40mm / 1 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 15mm deep, to either side or any position in between, backed with 20mm deep 40kg/m ³ stone wool, pipes fitted at any position within aperture	-/90/60	min seal depth 15mm, max seal size 300x300mm, min 1000x20mm thick stone wool insulation 80kg/m ³	FAS180387C.1
Mild/Stainless steel, interrupted, Ø40 - Ø219mm / 1 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 15mm deep, to either side or any position in between, backed with 20mm deep 40kg/m ³ stone wool, pipes fitted at any position within aperture	-/90/60	min seal depth 15mm, max seal size 300x300mm, min 1000x30mm thick stone wool insulation 80kg/m ³	FAS180387C.1
Mild/Stainless steel, interrupted, Ø40 - Ø219mm / 1 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to either side or any position in between, backed with 20mm deep 40kg/m ³ stone wool, pipes fitted at any position within aperture	-/120/90	min seal depth 25mm, max seal size 300x300mm, min 1000x30mm thick stone wool insulation 80kg/m ³	FAS180387C.1
Mild/Stainless steel, continuous, Ø40mm / 1 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to either side or any position in between, backed with 25mm deep AES mineral fibre, pipes fitted at any position within aperture	-/240/240	min seal depth 25mm, max seal size 300x300mm / Ø504mm, min 10mm annular, min seal separation 30mm, 20mm thick stone wool insulation 80kg/m ³	FAS180387C.1
Mild/Stainless steel, continuous, Ø40 - Ø324mm / 1 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to either side or any position in between, backed with 25mm deep AES mineral fibre, pipes fitted at any position within aperture	-/240/240	min seal depth 25mm, max seal size 300x300mm / Ø504mm, min 10mm annular, min seal separation 30mm, 30-80mm thick stone wool insulation 80kg/m ³	FAS180387C.1
Alupex, interrupted, Ø16 - Ø75mm / 2.25 - 4.7mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to either side or any position in between, backed with 48mm deep AES mineral fibre, pipes fitted at any position within aperture, closed systems only*	-/240/240	min seal depth 25mm, min 10mm around pipe, max seal size 300x300mm, 500x20mm thick stone wool insulation 80kg/m ³	FAS180387C.1
Mild/Stainless steel, continuous, Ø40mm / 1 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to both sides backed with 20mm deep stone wool 40kg/m ³ , (single) pipes fitted at any position within aperture	-/180/180	min seal depth 25mm, max seal size 300x300mm, 13-19mm Elastomeric Insulation	FAS180387C.1
Mild/Stainless steel, continuous, Ø40 - Ø165mm / 1 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to both sides backed with 25mm deep AES mineral fibre, (single) pipes fitted at any position within aperture	-/60/60	min seal depth 25mm, max seal size 300x300mm, 13-19mm Elastomeric Insulation	FAS180387C.1
Copper, continuous, Ø12mm / 1mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to both sides backed with 25mm deep AES mineral fibre, (single) pipes fitted at any position within aperture, closed systems only*	-/240/180	min seal depth 25mm, max seal size 300x300mm, 9mm Elastomeric Insulation	FAS180387C.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
Copper, continuous, Ø12-Ø54mm / 1 - 1.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to both sides backed with 25mm deep AES mineral fibre, (single) pipes fitted at any position within aperture, closed systems only*	-/180/120	min seal depth 25mm, max seal size 300x300mm, 9-13mm Elastomeric Insulation	FAS180387C.1
Copper, continuous, Ø12-Ø54mm / 1 - 1.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to both sides backed with 25mm deep AES mineral fibre, (single) pipes fitted at any position within aperture, closed systems only*	-/90/60	min seal depth 25mm, max seal size 300x300mm, 13-25mm Elastomeric Insulation	FAS180387C.1
Alupex, continuous, Ø16mm / 2.25mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to both sides backed with 25mm deep AES mineral fibre, (single) pipes fitted at any position within aperture, closed systems only*	-180/180	min seal depth 25mm, max seal size 300x300mm, 9mm Elastomeric Insulation	FAS180387C.1
Alupex, continuous, Ø16 - Ø75mm / 2.25 - 4.7mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to both sides backed with 25mm deep AES mineral fibre, (single) pipes fitted at any position within aperture, closed systems only*	-/120/60	min seal depth 25mm, max seal size 300x300mm, 9-13mm Elastomeric Insulation	FAS180387C.1
Alupex, continuous, Ø16 - Ø75mm / 2.25 - 4.7mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to both sides backed with 25mm deep AES mineral fibre, (single) pipes fitted at any position within aperture, closed systems only*	-/60/60	min seal depth 25mm, max seal size 300x300mm, 13-25mm Elastomeric Insulation	FAS180387C.1
Mild/Stainless steel, interrupted, Ø40mm / 1 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 15mm deep, to both sides backed with 25mm deep stone wool 80kg/m3, (single) pipes fitted at any position within aperture, closed systems only*	-/240/240	min seal depth 15mm, max seal size 300x300mm or 100x1000mm, 1000x30mm thick stone wool insulation 80kg/m3	FAS180387C.1
Mild/Stainless steel, interrupted, Ø40 - Ø219mm / 1 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Acrylic 15mm deep, to both sides backed with 20mm deep stone wool 80kg/m3, (single) pipes fitted at any position within aperture	-/240/120	min seal depth 15mm, max seal size 300x300mm or 100x1000mm, 1000x20mm thick stone wool insulation 80kg/m3	FAS180387C.1
Mild/Stainless steel, interrupted, Ø40mm / 1.5 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/180	max seal size 1200x1200mm, 1000x20mm thick stonewool insulation 80kg/m3	FAS180387A.1
Mild/Stainless steel, interrupted, Ø40 - Ø219mm / 1.5 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/90	max seal size 1200 x unlimited width, 1000x30mm stone wool 80kg/m3	FAS180387A.1
Mild/Stainless steel, interrupted, Ø40mm / 1 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/180	max seal size 1200 x unlimited width, 1000x20mm thick stone wool 80kg/m3, penetration seals min 30mm from edges	FAS180387A.1
Mild/Stainless steel, interrupted, Ø40 - Ø324mm / 1 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/180	max seal size 1200 x unlimited width, 1000x30mm thick stone wool 80kg/m3, penetration seals min 30mm from edges	FAS180387A.1
Copper, continuous or interrupted, up to Ø12mm / 0.9 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/240	max seal size 70x70mm, 1000x20mm thick stone wool insulation 80kg/m3	FAS180387A.1
Copper, continuous or interrupted, up to Ø54mm / 0.9 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/120	max seal size 115x115mm, 1000x20mm thick stone wool insulation 80kg/m3	FAS180387A.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
Alupex, continuous or interrupted, up to Ø75mm / 7.5mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic, closed systems only*	-/120/120	max seal size 200x200mm, 600x30mm thick stone wool insulation 80kg/m3	FAS180387A.1
Copper, continuous or interrupted, up to Ø54mm / 0.9 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/90	max seal size 1200 x unlimited width, 1000x20mm thick stone wool 80kg/m3	FAS180387A.1
Alupex, continuous or interrupted, up to Ø75mm / 7.5mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic, closed systems only*	-/120/90	max seal size 1200 x unlimited width, 1000x30mm thick stone wool 80kg/m3	FAS180387A.1
Steel, continuous or interrupted, Ø325mm / 6.35 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/120/90	max seal size 1200 x unlimited width, 1000x30mm thick stone wool 80kg/m3	FAS180387A.1
Mild/stainless steel, continuous or interrupted, Ø40mm / 1.5 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/240	max seal size 280x280mm, 1000x20mm thick stone wool 80kg/m3	FAS180387A.1
Mild/stainless steel, continuous or interrupted, Ø40 - Ø219mm / 1.5 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/240	max seal size 280x280mm, 1000x30mm thick stone wool 80kg/m3	FAS180387A.1
Mild/stainless steel, continuous or interrupted, Ø40 - Ø219mm / 1.5 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/90	max seal size 1200mm x unlimited width, 1000x20mm thick stone wool 80kg/m3	FAS180387A.1
Mild/stainless steel, continuous, Ø165mm / 4.5 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, iPASSIVE FR Wrap centrally fitted around insulation, perimeter edges sealed with iPASSIVE FR Acrylic	-/120/30	1.8mm x 50mm iPASSIVE FR Wrap, 9-25mm kflex elastomeric insulation	FAS180387A.1
Mild/stainless steel, continuous, Ø165mm / 4.5 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/60	30mm thick stone wool insulation 80kg/m3	FAS180387A.1
Mild/Stainless steel, interrupted, Ø40mm / 1.5 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided fitted together within the floor, perimeter edges sealed with iPASSIVE FR Acrylic	-/180/180	max seal size 600x1200mm, 20mm thick insulation	FAS180387A.1
Mild/Stainless steel, interrupted, Ø40mm / 1.5 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided fitted together within the floor, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/240	max seal size 280x280mm, 20mm thick insulation	FAS180387A.1
Mild/Stainless steel, interrupted, Ø40mm / 1.5 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided fitted together within the floor, perimeter edges sealed with iPASSIVE FR Acrylic	-/180/120	max seal size 2400x1200mm, 20mm thick insulation	FAS180387A.1
Mild/Stainless steel, interrupted, Ø40 - 219mm / 1.5 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided fitted together within the floor, perimeter edges sealed with iPASSIVE FR Acrylic	-/180/60	max seal size 2400x1200mm, 30mm thick insulation	FAS180387A.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
Copper, interrupted, up to Ø12mm / 0.9 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/30	max seal size 600x1200mm, 20mm thick stone wool insulation 80kg/m ³	FAS180387A.1
Copper, interrupted, up to Ø54mm / 0.9 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/240	max seal size 600x1200mm, 20mm thick stone wool insulation 80kg/m ³	FAS180387A.1
Copper, interrupted, up to Ø54mm / 0.9 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/120/120	max seal size 2400x1200mm, 20mm thick stone wool insulation 80kg/m ³	FAS180387A.1
Mild/Stainless steel, interrupted, Ø114mm / 11-14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic, closed systems only*	-/240/-	max seal size 600x1200mm	FAS180387A.1
Mild/Stainless steel, interrupted, Ø114mm / 11-14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic, closed systems only*	-/120/-	max seal size 2400x1200mm	FAS180387A.1
Mild/Stainless steel, interrupted, Ø40 - Ø219mm / 1.5 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/90	max seal size 600x1200mm, 30mm thick stone wool insulation 80kg/m ³	FAS180387A.1
Mild/Stainless steel, interrupted, Ø40 - Ø219mm / 1.5 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/120/90	max seal size 2400x1200mm, 30mm thick stone wool insulation 80kg/m ³	FAS180387A.1
Mild/Stainless steel, continuous, Ø165mm / 4.5 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, iPASSIVE FR Wrap fitted around pipe insulation, perimeter edges sealed with iPASSIVE FR Acrylic	-/90/30	max seal size 2400x1200mm, 3.6x50mm iPASSIVE FR Wrap around pipe, 13mm thick kflex Elastomeric insulation	FAS180387A.1
Mild/Stainless steel, continuous, Ø165mm / 4.5 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, iPASSIVE FR Wrap fitted around pipe insulation, perimeter edges sealed with iPASSIVE FR Acrylic	-/90/90	max seal size 2400x1200mm, 3.6x50mm iPASSIVE FR Wrap around pipe, 19mm thick kflex Elastomeric insulation	FAS180387A.1
Mild/Stainless steel, continuous, Ø165mm / 4.5 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/90/60	max seal size 2400x1200mm, 25-40mm thick stone wool insulation 80kg/m ³	FAS180387A.1
Mild/Stainless steel, continuous, Ø40mm / 1 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, iPASSIVE FR Wrap fitted around pipe at soffit, perimeter edges sealed with iPASSIVE FR Acrylic	-/180/120	max seal size 2400x1200mm, 1.8x50mm iPASSIVE FR Wrap around pipe, 13mm thick kflex Elastomeric insulation	FAS180387A.1
Copper, continuous, Ø12 - Ø54mm / 1 - 1.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided (2 layers) fitted together either side, iPASSIVE FR Wrap fitted around pipe insulation at bottom of seal, perimeter edges sealed with iPASSIVE FR Acrylic, closed systems only*	-/2404/60	max seal size 2400x1200mm, 3.6x50mm iPASSIVE FR Wrap around pipe, 9-13mm thick kflex Elastomeric insulation	FAS180387A.1
Copper, continuous, Ø12 - Ø54mm / 1 - 1.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided (2 layers) fitted together either side, iPASSIVE FR Wrap fitted around pipe insulation at bottom of seal, perimeter edges sealed with iPASSIVE FR Acrylic, closed systems only*	-/180/30	max seal size 2400x1200mm, 3.6x50mm iPASSIVE FR Wrap around pipe, 13-25mm thick kflex Elastomeric insulation	FAS180387A.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
Mild/Stainless steel, continuous, Ø4 - Ø324mm / 0.7 - 14.2mm wall	Wall	Plasterboard from 75mm, single layer 12.5mm board	iPASSIVE FR Board 30mm 1-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/30/30	max seal size 600x1200mm wide, 20-30mm thick stone wool insulation 80kg/m3	FAS180387A.1
Mild/Stainless steel, continuous, Ø40 - Ø324mm / 1 - 14.2mm wall	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 1-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/120/120	min seal/edge separation 30mm, 20-80mm thick stone wool insulation 80kg/m3	FAS180387A.1
Mild/Stainless steel, continuous, Ø40 - Ø324mm / 1 - 14.2mm wall	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 1-sided to both sides, iPASSIVE FR Wrap fitted around pipe insulation, perimeter edges sealed with iPASSIVE FR Acrylic	-/90/90	min seal/edge separation 30mm, 3 layers 1.8x50mm iPASSIVE FR Wrap around pipe, 32-50mm thick k-flex elastomeric insulation	FAS180387A.1
Mild/Stainless steel, continuous, Ø40 - Ø165mm / 1 - 14.2mm wall	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 1-sided to both sides, iPASSIVE FR Wrap fitted centrally around pipe insulation, perimeter edges sealed with iPASSIVE FR Acrylic	-/120/120	1.8x50mm iPASSIVE FR Wrap around pipe, 13mm thick kflex st insulation	FAS180387A.1
Mild/Stainless steel, continuous, Ø40 - Ø165mm / 1 - 14.2mm wall	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 1-sided to both sides, 2x iPASSIVE FR Wrap fitted flush to each face of seal around pipe insulation, perimeter edges sealed with iPASSIVE FR Acrylic	-/120/60	2x 1.8x50mm iPASSIVE FR Wrap around pipe, 13-32mm thick kflex insulation	FAS180387A.1
Copper, interrupted, up to Ø54mm / 1 - 14.2mm wall	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 1-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic, closed systems only*	-/120/120	500x20mm thick stone wool insulation 80kg/m3	FAS180387A.1
Alupex Ø75mm / 7.5mm wall	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 1-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/60/60	600x25mm thick AES mineral fibre insulation	FAS180387A.1
Mild/Stainless steel, interrupted, Ø114mm / 11mm wall	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 1-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/90/-	No insulation	FAS180387A.1
Mild/Stainless steel, interrupted, Ø40mm / 1 - 14.2mm wall	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 1-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/120/120	500x20mm thick stone wool insulation 80kg/m3	FAS180387A.1
Mild/Stainless steel, interrupted, Ø40 - Ø219mm / 1 - 14.2mm wall	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 1-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/120/90	500x30mm thick stone wool insulation 80kg/m3	FAS180387A.1
Copper, continuous, Ø12mm / 1 mm wall	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 1-sided to both sides, iPASSIVE FR Wraps fitted around pipes to both sides of seal, perimeter edges sealed with iPASSIVE FR Acrylic, closed systems only*	-/120/120	3.6x50mm iPASSIVE FR Wrap fitted to both sides of seal, 9mm Kflex Elastomeric insulation	FAS180387A.1
Copper, continuous, Ø12 - Ø54mm / 1 - 1.2 mm wall	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 1-sided to both sides, iPASSIVE FR Wraps fitted around pipes to both sides of seal, perimeter edges sealed with iPASSIVE FR Acrylic, closed systems only*	-/120/90	3.6x50mm iPASSIVE FR Wrap fitted to both sides of seal, 9-13mm Kflex Elastomeric insulation	FAS180387A.1
Copper, continuous, Ø12 - Ø54mm / 1 - 1.2 mm wall	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 1-sided to both sides, iPASSIVE FR Wraps fitted around pipes to both sides of seal, perimeter edges sealed with iPASSIVE FR Acrylic, closed systems only*	-/120/60	3.6x50mm iPASSIVE FR Wrap fitted to both sides of seal, 13-25mm Kflex Elastomeric insulation	FAS180387A.1
Mild/Stainless steel, continuous, Ø40 - Ø324mm / 1 - 14.2mm wall	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 2-sided to either side, iPASSIVE FR Collars fitted with penetrating threaded rod & nuts, Cables& trays coated 150mm each side, perimeter edges sealed with iPASSIVE FR Acrylic	-/90/60	max seal size 600x1200mm wide, 20-30mm thick stone wool insulation 80kg/m3	FAS180387A.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
Steel, single, continuous, Ø219mm / 5 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool 150kg /m3 backing	-/120/90	max seal size 1200x2400mm wide, 30mm stone wool insulation 80kg/m3, min 30mm seal separation	FAS180387D.1
Copper, interrupted, up to Ø12mm / 0.9 - 5mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool 150kg /m3 backing, closed systems only*	-/240/240	max seal size 70x70mm wide, 1000x20mm stone wool insulation 80kg/m3, min 30mm seal separation	FAS180387D.1
Copper, interrupted, up to Ø54mm / 1 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool 150kg /m3 backing, closed systems only*	-/240/120	max seal size 115x115mm wide, 1000x20mm stone wool insulation 80kg/m3, min 30mm seal separation	FAS180387D.1
Copper, interrupted, up to Ø54mm / 1 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool 150kg /m3 backing, closed systems only*	-/180/120	max seal size 1200x2400mm wide, 1000x20mm stone wool insulation 80kg/m3, min 30mm seal separation	FAS180387D.1
Alupex Ø75mm / 7.5mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool 150kg /m3 backing, closed systems only*	-/60/60	max seal size 1200x2400mm wide, 600x32mm elastomeric insulation 80kg/m3, min 30mm seal separation	FAS180387D.1
Mild/Stainless steel, continuous, Ø40mm / 1.5 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool 150kg /m3 backing	-/240/240	max seal size 100x100mm, 1000x20mm stone wool insulation 80kg/m3, min 30mm seal separation	FAS180387D.1
Mild/Stainless steel, continuous, Ø40 - Ø219mm / 1.5 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool 150kg /m3 backing,	-/120/90	max seal size 1200x2400mm wide, 1000x30mm stone wool insulation 80kg/m3, min 30mm seal separation	FAS180387D.1
Mild/Stainless steel, continuous, Ø40mm / 1.5 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 100mm to either side, iPASSIVE FR Wraps fitted centrally	-/240/240	max seal size 1200x2400mm wide, min 10mm seal separation, 3.6x50mm iPASSIVE FR Wrap fitted centrally, 13mm Elastomeric insulation	FAS180387D.1
Mild/Stainless steel, continuous, Ø165mm / 4.5 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 100mm to either side, iPASSIVE FR Wraps fitted centrally	-/240/240	max seal size 1200x2400mm wide, min 10mm seal separation, 3.6x50mm iPASSIVE FR Wrap fitted centrally, 13mm Elastomeric insulation	FAS180387D.1
Mild/Stainless steel, continuous, Ø40 - Ø165mm / 1.5 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 100mm to either side, iPASSIVE FR Wraps fitted centrally	-/240/60	max seal size 1200x2400mm wide, min 10mm seal separation, 1.8x50mm iPASSIVE FR Wrap fitted centrally, 13-19mm Elastomeric insulation	FAS180387D.1
Mild/Stainless steel, continuous, Ø40 - Ø165mm / 1.5 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 100mm to either side, iPASSIVE FR Wraps fitted centrally	-/180/60	max seal size 1200x2400mm wide, min 10mm seal separation, 3.6x50mm iPASSIVE FR Wrap fitted centrally, 13-25mm Elastomeric insulation	FAS180387D.1
Mild/Stainless steel, interrupted, Ø40 / 1.5 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 100mm to either side	-/240/240	max seal size 1200x2400mm wide, min 20mm seal separation, 1000x20mm stone wool insulation 80kg/m3	FAS180387D.1
Mild/Stainless steel, interrupted, Ø40 - Ø219mm / 1.5 - 14.2mm wall	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 100mm to either side	-/240/120	max seal size 1200x2400mm wide, min 20mm seal separation, 1000x30mm stone wool insulation 80kg/m3	FAS180387D.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
Copper, interrupted, up to Ø12mm / 1 - 5mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm flush to top side, 50mm stone wool 150kg /m3 backing, closed systems only*	-/2450/240	max seal size 70x70mm, 1000x20mm stone wool insulation 80kg/m3, min 30mm seal separation	FAS180387D.1
Copper, interrupted, up to Ø54mm / 1 - 14.2mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm flush to top side, 50mm stone wool 150kg /m3 backing, closed systems only*	-/240/180	max seal size 115x115mm, 1000x20mm stone wool insulation 80kg/m3, min 30mm seal separation	FAS180387D.1
Copper, interrupted, up to Ø54mm / 1 - 14.2mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm flush to top side, 50mm stone wool 150kg /m3 backing, closed systems only*	-/180/180	max seal size 1200x2400mm, 1000x20mm stone wool insulation 80kg/m3, min 30mm seal separation	FAS180387D.1
Mild/Stainless steel, interrupted, Ø40 / 1 - 14.2mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm flush to top side, 50mm stone wool 150kg/m3 backing	-/240/240	max seal size 280x280mm, min 30mm seal separation, 1000x20mm stone wool insulation 80kg/m3	FAS180387D.1
Mild/Stainless steel, interrupted, Ø40 - Ø219mm / 1.5 - 14.2mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm flush to top side, 50mm stone wool 150k /m3 backing	-/240/90	max seal size 280x280mm, min 30mm seal separation, 1000x30mm stone wool insulation 80kg/m3	FAS180387D.1
Mild/Stainless steel, interrupted, Ø40 / 1 - 14.2mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm flush to top side, 50mm stone wool 150kg/m3 backing	-/180/180	max seal size 1200x2400mm, min 30mm seal separation, 1000x20mm stone wool insulation 80kg/m3	FAS180387D.1
Mild/Stainless steel, interrupted, Ø40 - Ø219mm / 1.5 - 14.2mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm flush to top side, 50mm stone wool 150kg/m3 backing	-/180/90	max seal size 1200x2400mm, min 30mm seal separation, 1000x30mm stone wool insulation 80kg/m3	FAS180387D.1
Mild/Stainless steel, continuous, Ø40mm / 1 - 14.2mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool 140kg/m3 backing	-/240/240	max seal size 550x1100mm, min 30mm seal separation, 20mm thick stone wool insulation 80kg/m3	FAS180387D.1
Mild/Stainless steel, continuous, Ø40mm / 1 - 14.2mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool 140kg/m3 backing	-/180/180	max seal size 1200x2400mm, min 30mm seal separation, 20mm thick stone wool insulation 80kg/m3	FAS180387D.1
Mild/Stainless steel, continuous, Ø40 - Ø219mm / 1 - 14.2mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool 140kg/m3 backing	-/240/240	max seal size 550x1100mm, min 30mm seal separation, 30-80mm thick stone wool insulation 80kg/m3	FAS180387D.1
Mild/Stainless steel, continuous, Ø40 - Ø219mm / 1 - 14.2mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool 140kg/m3 backing	-/180/180	max seal size 1200x2400mm, min 30mm seal separation, 30-80mm thick stone wool insulation 80kg/m3	FAS180387D.1
Copper, continuous, Ø12mm / 1mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 100mm to either side, iPASSIVE FR Wrap fitted at soffit, closed systems only*	-/240/240	max seal size 1200x2400mm, min 25mm seal separation, 3.6x50mm iPASSIVE FR Wrap fitted to soffit, 9mm elastomeric insulation	FAS180387D.1
Copper, continuous, Ø12-Ø54mm / 1 - 1.2mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 100mm to either side, iPASSIVE FR Wrap fitted at soffit, closed systems only*	-/240/60	max seal size 1200x2400mm, min 25mm seal separation, 3.6x50mm iPASSIVE FR Wrap fitted to soffit, 13-25mm elastomeric insulation	FAS180387D.1
PEX, continuous, Ø16mm / 2.25mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 100mm to either side, iPASSIVE FR Wrap fitted at soffit, closed systems only*	-/240/240	max seal size 1200x2400mm, min 30mm seal separation, 3.6x50mm iPASSIVE FR Wrap fitted to soffit, 9mm elastomeric insulation	FAS180387D.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
PEX, continuous, Ø16 - Ø75mm / 2.25 - 4.7mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 100mm to either side, iPASSIVE FR Wrap fitted at soffit, closed systems only*	-/240/90	max seal size 1200x2400mm, min 30mm seal separation, 3.6x50mm iPASSIVE FR Wrap fitted to soffit, 9-13mm elastomeric insulation	FAS180387D.1
PEX, continuous, Ø16 - Ø75mm / 2.25 - 4.7mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 100mm to either side, iPASSIVE FR Wrap fitted at soffit, closed systems only*	-/180/90	max seal size 1200x2400mm, min 30mm seal separation, 3.6x50mm iPASSIVE FR Wrap fitted to soffit, 13-25mm elastomeric insulation	FAS180387D.1
Steel, interrupted, up to Ø16mm / 1.5 - 7mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 100mm flush to top side, closed systems only*	-/240/120	max seal size 1200x2400mm, min 30mm seal separation	FAS180387D.1
Copper, interrupted, up to Ø54mm / 1.5 - 14.2mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 100mm flush to top side, closed systems only*	-/120/120	max seal size 1200x2400mm, min 30mm seal separation	FAS180387D.1
Mild/Stainless steel, interrupted, Ø40mm / 1.5 - 14.2mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 100mm flush to top side	-/240/240	max seal size 1200x2400mm, min 30mm seal separation, 1000x20mm stone wool insulation 80kg/m ³	FAS180387D.1
Mild/Stainless steel, interrupted, Ø40 - Ø219mm / 1.5 - 14.2mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 100mm flush to top side	-/240/120	max seal size 1200x2400mm, min 30mm seal separation, 1000x30mm stone wool insulation 80kg/m ³	FAS180387D.1
Mild/Stainless steel, continuous, Ø40mm / 1.5 - 14.2mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 100mm flush to top side, iPASSIVE FR Wrap fitted at bottom of seal	-/180/180	max seal size 1200x2400mm, min 30mm seal separation, 1.8x50mm iPASSIVE FR Wrap, 13mm elastomeric insulation	FAS180387D.1
Mild/Stainless steel, continuous, Ø40 - Ø165mm / 1.5 - 14.2mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 100mm flush to top side, iPASSIVE FR Wrap fitted at bottom of seal	-/180/120	max seal size 1200x2400mm, min 30mm seal separation, 1.8x50mm iPASSIVE FR Wrap, 13-19mm elastomeric insulation	FAS180387D.1
Mild/Stainless steel, continuous, Ø40mm / 1 - 14.2mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 100mm flush to top side, iPASSIVE FR Wrap fitted either side	-/240/240	max seal size 1200x2400mm, min 30mm seal separation, 3.6x50mm iPASSIVE FR Wrap, 25mm elastomeric insulation	FAS180387D.1
Mild/Stainless steel, continuous, Ø40 - Ø324mm / 1 - 14.2mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 100mm flush to top side, iPASSIVE FR Wrap fitted either side	-/240/120	max seal size 1200x2400mm, min 30mm seal separation, 3.6x50mm iPASSIVE FR Wrap, 25mm elastomeric insulation	FAS180387D.1
Mild/Stainless steel, continuous, Ø40 - Ø324mm / 1 - 14.2mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 100mm flush to top side, iPASSIVE FR Wrap fitted either side	-/120/120	max seal size 1200x2400mm, min 30mm seal separation, 5.4x50mm iPASSIVE FR Wrap, 25-50mm elastomeric insulation	FAS180387D.1
PEX, interrupted, Ø16mm / 2.25mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm flush to bottom side, 50mm stone wool backing 150kg/m ³ , closed systems only*	-/240/240	max seal size 135x135mm, min 10mm seal separation from edges, 500x20mm stone wool insulation 80kg/m ³	FAS180387D.1
PEX, interrupted, Ø16 - Ø75mm / 2.25 - 4.7mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm flush to bottom side, 50mm stone wool backing 150kg/m ³ , closed systems only*	-/240/180	max seal size 135x135mm, min 10mm seal separation from edges, 500x20mm stone wool insulation 80kg/m ³	FAS180387D.1
PEX, interrupted, Ø16 - Ø75mm / 2.25 - 4.7mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm flush to bottom side, 50mm stone wool backing 150kg/m ³ , closed systems only*	-/180/180	max seal size 2400x1200mm, min 10mm seal separation from edges, 500x20mm stone wool insulation 80kg/m ³	FAS180387D.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
Copper/Steel, continuous, Ø6mm / 0.7 - 3mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool backing 150kg/m3	-/180/120	max seal size 2400x1200mm, min 30mm seal separation	FAS180387D.1
Copper/Steel, continuous, Ø7- Ø15mm / 0.9 - 7.5mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool backing 150kg/m3	-/180/30	max seal size 2400x1200mm, min 30mm seal separation	FAS180387D.1
Copper/Steel, continuous, Ø12- Ø54mm / 0.7 - 14.2mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool backing 150kg/m3, closed systems only*	-/180/120	max seal size 2400x1200mm, min 30mm seal separation, 20-80mm stone wool insulation 150kg/m3	FAS180387D.1
Steel, continuous, Ø4 - Ø16mm / 1 - 8mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool backing 150kg/m3	-/180/180	max seal size 2400x1200mm, min 30mm seal separation	FAS180387D.1
Alupex, Ø16 - Ø20mm / 2mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool backing 150kg/m3, closed systems only*	-/180/180	max seal size 2400x1200mm, min 30mm seal separation	FAS180387D.1
Mild/Stainless steel, continuous, Ø40mm / 1 - 14.2mm wall	Wall	Plasterboard from 100mm	iPASSIVE EX Mortar 25mm both sides, 50mm stone wool 150kg /m3 backing or iPASSIVE EX Mortar 50mm to both sides with no backing, iPASSIVE FR Wraps fitted flush to both sides	-/120/120	max seal size 2400x1200mm, min 30mm seal separation, 2x 1.8x50mm iPASSIVE FR Wrap, 13mm elastomeric insulation	FAS180387D.1
Mild/Stainless steel, continuous, Ø40 - Ø165mm / 1 - 14.2mm wall	Wall	Plasterboard from 100mm	iPASSIVE EX Mortar 25mm both sides, 50mm stone wool 150kg /m3 backing or iPASSIVE EX Mortar 50mm to both sides with no backing, iPASSIVE FR Wraps fitted flush to both sides	-/120/60	max seal size 2400x1200mm, min 30mm seal separation, 2x 1.8x50mm iPASSIVE FR Wrap, 13mm elastomeric insulation	FAS180387D.1
Copper, interrupted, up to Ø54mm / 1 - 14.2mm wall	Wall	Plasterboard from 100mm	iPASSIVE EX Mortar 25mm both sides, 50mm stone wool 150kg /m3 backing, closed systems only*	-/120/120	max seal size 2400x1200mm, min 30mm seal separation, min 500x20mm stone wool insulation 80kg/m3	FAS180387D.1
Alupex, interrupted, Ø75mm / 7.5mm wall	Wall	Plasterboard from 100mm	iPASSIVE EX Mortar 25mm both sides, 50mm stone wool 150kg /m3 backing	-/60/60	max seal size 2400x1200mm, min 30mm seal separation, min 600x25mm AES insulation	FAS180387D.1
Mild/Stainless steel, continuous, Ø40mm / 1 - 14.2mm wall	Wall	Plasterboard from 100mm	iPASSIVE EX Mortar 25mm both sides, 50mm stone wool 150kg /m3 backing	-/120/120	max seal size 2400x1200mm, min 30mm seal separation, min 500x20mm stone wool insulation 80kg/m3	FAS180387D.1
Mild/Stainless steel, continuous, Ø40 - Ø219mm / 1 - 14.2mm wall	Wall	Plasterboard from 100mm	iPASSIVE EX Mortar 25mm both sides, 50mm stone wool 150kg /m3 backing	-/120/90	max seal size 2400x1200mm, min 30mm seal separation, min 500x30mm stone wool insulation 80kg/m3	FAS180387D.1
PEX, interrupted, Ø16 - Ø75mm / 2.25 - 4.7mm wall	Wall	Plasterboard from 100mm	iPASSIVE EX Mortar 25mm both sides, 50mm stone wool 150kg /m3 backing, closed systems only*	-/120/120	max seal size 2400x1200mm, min 30mm seal separation, min 500x20mm stone wool insulation 80kg/m3	FAS180387D.1
Copper/Steel, continuous, Ø12- Ø54mm / 0.7 - 14.2mm wall	Wall	Plasterboard from 100mm	iPASSIVE EX Mortar 25mm both sides, 50mm stone wool 150kg /m3 backing, iPASSIVE FR Wrap fitted flush to both sides, closed systems only*	-/120/120	max seal size 2400x1200mm, min 30mm seal separation, 2x 3.6x50mm iPASSIVE FR Wrap, 9-25mm elastomeric insulation	FAS180387D.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
PEX, interrupted, Ø16 - Ø75mm / 2.25 - 4.7mm wall	Wall	Plasterboard from 100mm	iPASSIVE EX Mortar 25mm both sides, 50mm stone wool 150kg /m ³ backing, iPASSIVE FR Wrap fitted flush to both sides, closed systems only*	-/120/120	max seal size 2400x1200mm, min 30mm seal separation, 2x 3.6x50mm iPASSIVE FR Wrap, 9-25mm elastomeric insulation	FAS180387D.1
Mild/Stainless steel, continuous, Ø40 - Ø165mm / 1 - 14.2mm wall	Wall	Plasterboard from 100mm	iPASSIVE EX Mortar 50mm both sides, iPASSIVE FR Wrap fitted flush to both sides	-/120/60	max seal size 2400x1200mm, min 30mm seal separation, 2x 3.6x50mm iPASSIVE FR Wrap, 13-32mm elastomeric insulation	FAS180387D.1
Mild/Stainless steel, Ø4 - Ø22mm / 1 - 14.2mm wall	Wall	Flexible or Rigid walls ≥100mm	iPASSIVE FR Putty Cord 15mm to both sides	-/120/120	max annular 10mm, min 30mm seal separation	FAS180387E.1
Mild/Stainless steel, Ø23 - Ø30mm / 2 - 14.2mm wall	Wall	Flexible or Rigid walls ≥100mm	iPASSIVE FR Putty Cord 15mm to both sides	-/120/120	max annular 10mm, min 30mm seal separation	FAS180387E.1
Alupex, Ø16mm / 2mm wall	Wall	Flexible or Rigid walls ≥100mm	iPASSIVE FR Putty Cord 15mm to both sides, closed systems only*	-/120/120	max annular 10mm, min 30mm seal separation	FAS180387E.1
Alupex, Ø17-Ø20mm / 2 - 14.2mm wall	Wall	Flexible or Rigid walls ≥100mm	iPASSIVE FR Putty Cord 15mm to both sides, closed systems only*	-/120/90	max annular 10mm, min 30mm seal separation	FAS180387E.1
Copper/Steel, Ø7- Ø15mm	Wall	Flexible or Rigid walls ≥100mm	iPASSIVE FR Putty Cord 15mm to both sides, closed systems only*	-/120/120	max annular 10mm, min 30mm seal separation	FAS180387E.1
Copper/Steel, Ø6mm	Wall	Flexible or Rigid walls ≥100mm	iPASSIVE FR Putty Cord 15mm to both sides, closed systems only*	-/120/120	max annular 10mm, min 30mm seal separation	FAS180387E.1
Copper/Steel, Ø7 - Ø12mm / 0.6 - 14.2mm wall	Wall	Flexible or Rigid walls ≥100mm	iPASSIVE FR Putty Cord 15mm to both sides, closed systems only*	-/120/60	max annular 10mm, min 30mm seal separation	FAS180387E.1
Mild/Stainless steel, interrupted, up to Ø40mm / 1- 14.2mm wall	Wall	Flexible or Rigid walls ≥100mm	iPASSIVE FR Putty Cord 15mm to both sides	-/120/120	max annular 10mm, min 30mm seal separation, min 500x20mm stone wool insulation 80kg/m ³	FAS180387E.1
Mild/Stainless steel, interrupted, Ø40- Ø324mm / 1- 14.2mm wall	Wall	Flexible or Rigid walls ≥100mm	iPASSIVE FR Putty Cord 15mm to both sides	-/120/120	max annular 10mm, min 30mm seal separation, min 500x30mm stone wool insulation 80kg/m ³	FAS180387E.1
Copper/Steel, interrupted, up to Ø54mm / 1.2 - 14.2mm wall	Wall	Flexible or Rigid walls ≥100mm	iPASSIVE FR Putty Cord 15mm to both sides, closed systems only*	-/90/60	max annular 10mm, min 30mm seal separation, min 500x20mm stone wool insulation 80kg/m ³	FAS180387E.1
Mild/Stainless steel, continuous, up to Ø40mm / 1- 14.2mm wall	Wall	Flexible or Rigid walls ≥100mm	iPASSIVE FR Putty Cord 15mm to both sides	-/120/120	max annular 10mm, min 30mm seal separation, 20mm stone wool insulation 80kg/m ³	FAS180387E.1
Mild/Stainless steel, continuous, Ø40- Ø324mm / 1- 14.2mm wall	Wall	Flexible or Rigid walls ≥100mm	iPASSIVE FR Putty Cord 15mm to both sides	-/90/60	max annular 10mm, min 30mm seal separation, 30-80mm stone wool insulation 80kg/m ³	FAS180387E.1
Copper/Steel, continuous, up to Ø12mm / 0.7 - 6mm wall	Wall	Flexible or Rigid walls ≥100mm	iPASSIVE FR Putty Cord 15mm to both sides, closed systems only*	-/90/60	max annular 10mm, min 30mm seal separation, 20mm stone wool insulation 80kg/m ³	FAS180387E.1
Copper/Steel, continuous, up to Ø54mm / 1.2 - 14.2mm wall	Wall	Flexible or Rigid walls ≥100mm	iPASSIVE FR Putty Cord 15mm to both sides, closed systems only*	-/90/60	max annular 10mm, min 30mm seal separation, 30-80mm stone wool insulation 80kg/m ³	FAS180387E.1
Mild/Stainless steel, Ø4mm / 1mm wall	Floor	Concrete, Aerated Concrete, Masonry from 100mm, floor may be reduced to 100mm for derated FRL	iPASSIVE FR Putty Cord 15mm to bottom side	-/120/120	max annular 10mm, min 30mm seal separation	FAS180387E.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
INSULATED NON-COMBUSTIBLE PIPES						
Mild/Stainless steel, Ø5 - Ø30mm / 1- 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 100mm, floor may be reduced to 100mm for derated FRL	iPASSIVE FR Putty Cord 15mm to bottom side	-/120/45	max annular 10mm, min 30mm seal separation	FAS180387E.1
Copper/Steel, Ø6mm / 0.6mm wall	Floor	Concrete, Aerated Concrete, Masonry from 100mm, floor may be reduced to 100mm for derated FRL	iPASSIVE FR Putty Cord 15mm to bottom side, closed systems only*	-/120/90	max annular 10mm, min 30mm seal separation	FAS180387E.1
Copper/Steel, Ø7 - Ø12mm / 0.6 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 100mm, floor may be reduced to 100mm for derated FRL	iPASSIVE FR Putty Cord 15mm to bottom side, closed systems only*	-/120/30	max annular 10mm, min 30mm seal separation	FAS180387E.1
Mild/Stainless steel, up to Ø22mm / 1.2 - 11mm wall	Floor	Concrete, Aerated Concrete, Masonry from 100mm, floor may be reduced to 100mm for derated FRL	iPASSIVE FR Putty Cord 15mm to top side	-/120/120	max annular 10mm, min 30mm seal separation	FAS180387E.1
Copper/Steel, Ø6mm	Floor	Concrete, Aerated Concrete, Masonry from 100mm, floor may be reduced to 100mm for derated FRL	iPASSIVE FR Putty Cord 15mm to top side, closed systems only*	-/120/120	max annular 10mm, min 30mm seal separation	FAS180387E.1
Copper/Steel, Ø7 - Ø10mm / 0.6 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 100mm, floor may be reduced to 100mm for derated FRL	iPASSIVE FR Putty Cord 15mm to top side, closed systems only*	-/120/90	max annular 10mm, min 30mm seal separation	FAS180387E.1
Mild/Stainless steel, interrupted, up to Ø40mm / 1- 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 100mm, floor may be reduced to 100mm for derated FRL	iPASSIVE FR Putty Cord 15mm to top side	-/240/240	max annular 10mm, min 30mm seal separation, min 500x20mm stone wool insulation 80kg/m ³	FAS180387E.1
Mild/Stainless steel, interrupted, Ø41 - Ø324mm / 1- 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 100mm, floor may be reduced to 100mm for derated FRL	iPASSIVE FR Putty Cord 15mm to top side	-/240/60	max annular 10mm, min 30mm seal separation, min 500x30mm stone wool insulation 80kg/m ³	FAS180387E.1
Copper/Steel, interrupted, up to Ø12mm / 0.9mm wall	Floor	Concrete, Aerated Concrete, Masonry from 100mm, floor may be reduced to 100mm for derated FRL	iPASSIVE FR Putty Cord 15mm to top side, closed systems only*	-/240/240	max annular 10mm, min 30mm seal separation, min 500x20mm stone wool insulation 80kg/m ³	FAS180387E.1
Copper/Steel, interrupted, up to Ø13-Ø54mm / 0.9 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 100mm, floor may be reduced to 100mm for derated FRL	iPASSIVE FR Putty Cord 15mm to top side, closed systems only*	-/240/60	max annular 10mm, min 30mm seal separation, min 500x20mm stone wool insulation 80kg/m ³	FAS180387E.1
Mild/Stainless steel, continuous, up to Ø40mm / 1- 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 100mm, floor may be reduced to 100mm for derated FRL	iPASSIVE FR Putty Cord 15mm to top side	-/240/240	max annular 10mm, min 30mm seal separation, 20mm stone wool insulation 80kg/m ³	FAS180387E.1
Mild/Stainless steel, continuous, Ø40-Ø324mm / 1- 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 100mm, floor may be reduced to 100mm for derated FRL	iPASSIVE FR Putty Cord 15mm to top side	-/240/240	max annular 10mm, min 30mm seal separation, 30-80mm stone wool insulation 80kg/m ³	FAS180387E.1
Copper/Steel, continuous, up to Ø12mm / 0.7 - 6mm wall	Floor	Concrete, Aerated Concrete, Masonry from 100mm, floor may be reduced to 100mm for derated FRL	iPASSIVE FR Putty Cord 15mm to top side, closed systems only*	-/240/240	max annular 10mm, min 30mm seal separation, 20mm stone wool insulation 80kg/m ³	FAS180387E.1
Copper/Steel, continuous, up to Ø54mm / 1.2 - 14.2mm wall	Floor	Concrete, Aerated Concrete, Masonry from 100mm, floor may be reduced to 100mm for derated FRL	iPASSIVE FR Putty Cord 15mm to top side, closed systems only*	-/240/240	max annular 10mm, min 30mm seal separation, 30-80mm stone wool insulation 80kg/m ³	FAS180387E.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
PVC	Wall	Concrete, Aerated Concrete, Masonry from 100mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed	-/90/60	Ø32mm-Ø50mm with wall thickness 1.2 - 3.7mm	FAS180387B.1
PVC	Wall	Concrete, Aerated Concrete, Masonry from 100mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed	-/60/60	Ø55mm-Ø140mm with wall thickness 2.7 - 6.6mm	FAS180387B.1
PVC	Wall	Concrete, Aerated Concrete, Masonry from 100mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed	-/90/90	Ø160mm with wall thickness 3.2 - 9.5mm	FAS180387B.1
PVC	Wall	Concrete, Aerated Concrete, Masonry from 100mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed	-/60/60	Ø315mm with wall thickness 9.2mm	FAS180387B.1
PVC	Wall	Plasterboard from 100mm, wall may be reduced to 75mm & single layer 13mm board for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed, no lining of aperture required	-/90/60	Ø32mm-Ø50mm with wall thickness 1.2 - 3.7mm	FAS180387B.1
PVC	Wall	Plasterboard from 100mm, wall may be reduced to 75mm & single layer 13mm board for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed, no lining of aperture required	-/60/60	Ø55mm-Ø140mm with wall thickness 2.7 - 6.6mm	FAS180387B.1
PVC	Wall	Plasterboard from 100mm, wall may be reduced to 75mm & single layer 13mm board for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed, no lining of aperture required	-/90/90	Ø160mm with wall thickness 3.2 - 9.5mm	FAS180387B.1
PVC	Wall	Plasterboard from 100mm, wall may be reduced to 75mm & single layer 13mm board for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed, no lining of aperture required	-/60/60	Ø315mm with wall thickness 9.2mm	FAS180387B.1
PE	Wall	Concrete, Aerated Concrete, Masonry from 100mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed, closed systems only*	-/90/60	Ø32mm-Ø50mm with wall thickness 3 - 5.6mm	FAS180387B.1
PE	Wall	Concrete, Aerated Concrete, Masonry from 100mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed, closed systems only*	-/60/60	Ø55mm-Ø160mm with wall thickness 3.4 - 9.5mm	FAS180387B.1
PE	Wall	Concrete, Aerated Concrete, Masonry from 100mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed, closed systems only*	-/60/60	Ø200mm-Ø250mm with wall thickness 18.2 - 22.7mm	FAS180387B.1
PE	Wall	Concrete, Aerated Concrete, Masonry from 100mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed	-/90/30	Ø32mm-Ø90mm with wall thickness 3 - 10mm	FAS180387B.1
PE	Wall	Concrete, Aerated Concrete, Masonry from 100mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed	-/90/60	Ø110mm-Ø140mm with wall thickness 3.4 - 14.6mm	FAS180387B.1
PE	Wall	Concrete, Aerated Concrete, Masonry from 100mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed	-/90/90	Ø160mm with wall thickness 4.9 - 14.6mm	FAS180387B.1
PE	Wall	Plasterboard from 100mm, wall may be reduced to 75mm & single layer 13mm board for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed, no aperture lining required, closed systems only*	-/90/60	Ø32mm-Ø50mm with wall thickness 3 - 5.6mm	FAS180387B.1
PE	Wall	Plasterboard from 100mm, wall may be reduced to 75mm & single layer 13mm board for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed, no aperture lining required, closed systems only*	-/60/60	Ø55mm-Ø160mm with wall thickness 3.4 - 9.5mm	FAS180387B.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
PE	Wall	Plasterboard from 100mm, wall may be reduced to 75mm & single layer 13mm board for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed, no aperture lining required, closed systems only*	-/60/60	Ø200mm-Ø250mm with wall thickness 18.2 - 22.7mm	FAS180387B.1
PE	Wall	Plasterboard from 100mm, wall may be reduced to 75mm & single layer 13mm board for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed, no lining of aperture required	-/90/30	Ø32mm-Ø90mm with wall thickness 3 - 10mm	FAS180387B.1
PE	Wall	Plasterboard from 100mm, wall may be reduced to 75mm & single layer 13mm board for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed, no lining of aperture required	-/90/60	Ø110mm-Ø140mm with wall thickness 3.4 - 14.6mm	FAS180387B.1
PE	Wall	Plasterboard from 100mm, wall may be reduced to 75mm & single layer 13mm board for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed, no lining of aperture required	-/90/90	Ø160mm with wall thickness 4.9 - 14.6mm	FAS180387B.1
PP	Wall	Concrete, Aerated Concrete, Masonry from 100mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed, closed systems only*	-/90/60	Ø32mm-Ø110mm with wall thickness 3 - 6.3mm	FAS180387B.1
PP	Wall	Concrete, Aerated Concrete, Masonry from 100mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed, closed systems only*	-/60/60	Ø125mm-Ø160mm with wall thickness 4.9 - 14.6mm	FAS180387B.1
PP	Wall	Concrete, Aerated Concrete, Masonry from 100mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed	-/90/60	Ø32mm-Ø110mm with wall thickness 1.8 - 6.6mm	FAS180387B.1
PP	Wall	Concrete, Aerated Concrete, Masonry from 100mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed	-/60/60	Ø125mm-Ø160mm with wall thickness 4.9 - 14.6mm	FAS180387B.1
PP	Wall	Plasterboard from 100mm, wall may be reduced to 75mm & single layer 13mm board for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed, no aperture lining required, closed systems only*	-/90/60	Ø32mm-Ø110mm with wall thickness 3 - 6.3mm	FAS180387B.1
PP	Wall	Plasterboard from 100mm, wall may be reduced to 75mm & single layer 13mm board for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed, no aperture lining required, closed systems only*	-/60/60	Ø125mm-Ø160mm with wall thickness 4.9 - 14.6mm	FAS180387B.1
PP	Wall	Plasterboard from 100mm, wall may be reduced to 75mm & single layer 13mm board for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed, no lining of aperture required	-/90/60	Ø32mm-Ø110mm with wall thickness 1.8 - 6.6mm	FAS180387B.1
PP	Wall	Plasterboard from 100mm, wall may be reduced to 75mm & single layer 13mm board for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed, no lining of aperture required	-/60/60	Ø125mm-Ø160mm with wall thickness 4.9 - 14.6mm	FAS180387B.1
PVC	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed, no lining of aperture required	-/240/180	Ø32mm-Ø50mm with wall thickness 2 - 3.7mm	FAS180387B.1
PVC	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed	-/180/180	Ø55mm-Ø110mm with wall thickness 2.7 - 6.6mm	FAS180387B.1
PVC	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed	-/240/240	Ø125mm-Ø160mm with wall thickness 4 - 9.5mm	FAS180387B.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
PVC	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed, closed systems only*	-/120/120	Ø315mm with wall thickness 9.2mm	FAS180387B.1
PE	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed	-/240/240	Ø32mm-Ø50mm with wall thickness 3 - 4.6mm	FAS180387B.1
PE	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed	-/240/180	Ø55mm-Ø110mm with wall thickness 3.4mm	FAS180387B.1
PE	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed	-/180/180	Ø125mm-Ø160mm with wall thickness 4.9 - 9.5mm	FAS180387B.1
PE	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed, closed systems only*	-/60/60	Ø200mm with wall thickness 18.2mm	FAS180387B.1
PE	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed, closed systems only*	-/120/90	Ø250mm with wall thickness 22.7mm	FAS180387B.1
PP	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed, closed systems only*	-/240/240	Ø32mm-Ø110mm with wall thickness 1.6 - 10mm	FAS180387B.1
PP	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed, closed systems only*	-/240/180	Ø125mm-Ø160mm with wall thickness 4.9 - 14.6mm	FAS180387B.1
PP	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed	-/240/240	Ø32mm-Ø50mm with wall thickness 1.6 - 5.5mm	FAS180387B.1
PP	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed	-/240/60	Ø55mm-Ø140mm with wall thickness 2.7 - 10mm	FAS180387B.1
PP	Wall	Concrete, Aerated Concrete, Masonry from 150mm, wall may be reduced to 75mm for derated FRL	iPASSIVE FR Collar to both sides, tested oversize, angled penetrations allowed	-/240/180	Ø160mm with wall thickness 4.9 - 14.6mm	FAS180387B.1
PVC	Floor	Concrete, Aerated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Collar to soffit of floor, tested oversize, angled penetrations allowed, closed systems only*	-/120/120	Ø32mm-Ø160mm with wall thickness 2 - 9.5mm	FAS180387B.1
PVC	Floor	Concrete, Aerated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Collar to soffit of floor, tested oversize, angled penetrations allowed	-/90/60	Ø32mm-Ø50mm with wall thickness 1.9 - 3.7mm	FAS180387B.1
PVC	Floor	Concrete, Aerated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Collar to soffit of floor, tested oversize, angled penetrations allowed	-/60/60	Ø55mm-Ø160mm with wall thickness 3.2 - 9.5mm	FAS180387B.1
PE	Floor	Concrete, Aerated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Collar to soffit of floor, tested oversize, angled penetrations allowed, closed systems only*	-/120/120	Ø32mm-Ø140mm with wall thickness 3 - 14.7mm	FAS180387B.1
PE	Floor	Concrete, Aerated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Collar to soffit of floor, tested oversize, angled penetrations allowed, closed systems only*	-/180/120	Ø140mm with wall thickness 4.9 - 14.7mm	FAS180387B.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
PE	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Collar to soffit of floor, tested oversize, angled penetrations allowed	-/60/60	Ø32mm-Ø160mm with wall thickness 3 - 14.6mm	FAS180387B.1
PP	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Collar to soffit of floor, tested oversize, angled penetrations allowed, closed systems only*	-/120/120	Ø32mm-Ø110mm with wall thickness 1.9 - 6.6mm	FAS180387B.1
PP	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Collar to soffit of floor, tested oversize, angled penetrations allowed, closed systems only*	-/120/120	Ø125mm-Ø140mm with wall thickness 4.9 - 14.6mm	FAS180387B.1
PP	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Collar to soffit of floor, tested oversize, angled penetrations allowed, closed systems only*	-/180/180	Ø160mm with wall thickness 4.9 - 14.6mm	FAS180387B.1
PP	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Collar to soffit of floor, tested oversize, angled penetrations allowed	-/120/120	Ø32mm-Ø50mm with wall thickness 1.8 - 4.6mm	FAS180387B.1
PP	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Collar to soffit of floor, tested oversize, angled penetrations allowed	-/60/60	Ø55mm-Ø110mm with wall thickness 2.7 - 6.6mm	FAS180387B.1
PP	Wall	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 75mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to both sides, backed with 25mm deep stone wool 35 kg/m3	-/180/180	Ø32mm / 2 - 4.4mm wall thickness, 300x300mm / Ø300mm max seal size, min 10mm annular	FAS180387C.1
PE	Wall	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 75mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to both sides, backed with 25mm deep stone wool 35 kg/m3	-/240/240	Ø20- Ø32mm / 2 mm wall thickness, 300x300mm / Ø300mm max seal size, min 10mm annular	FAS180387C.1
PVC	Wall	Plasterboard from 100mm	iPASSIVE FR Acrylic 25mm deep, to both sides, single pipes, pipes fitted at any position within aperture, closed systems only*	-/90/90	min 10mm annular, Ø52mm max aperture	FAS180387C.1
PP	Wall	Plasterboard from 100mm	iPASSIVE FR Acrylic 25mm deep, to both sides, single pipes, pipes fitted at any position within aperture, closed systems only*	-/90/90	min 29mm annular, Ø90mm max aperture	FAS180387C.1
PP	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to both sides backed with 25mm deep AES mineral fibre, pipes fitted at any position within aperture, closed systems only*	-/120/120	Ø40mm / 3 mm wall, min seal depth 25mm, min 10mm annular,	FAS180387C.1
PP	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to both sides backed with 25mm deep stone wool 140kg/m3, pipes fitted at any position within aperture, closed systems only*	-/180/180	Ø75mm / 2.8mm wall, min seal depth 25mm, min 10mm annular,	FAS180387C.1
PE	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to both sides backed with 25mm deep stone wool 140kg/m3, pipes fitted at any position within aperture, closed systems only*	-/240/240	Ø40mm / 4 mm wall, min seal depth 25mm, min 10mm annular,	FAS180387C.1
PVC conduit up to Ø16mm	Wall	Concrete, Aertated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/180/180	max seal size 1200mm x unlimited width, penetration seal min 25mm from edges, min 30mm separation	FAS180387A.1
PVC conduit up to Ø16mm	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/120/90	max seal size 2400 x 1200mm	FAS180387A.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
PVC conduit up to Ø16mm	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/30/30	max seal size 2400 x 1200mm	FAS180387A.1
PVC-u, Ø110mm / 3.4mm wall	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Board 50mm 2-sided fitted mid depth, iPASSIVE FR Wraps fitted around pipes,perimeter edges sealed with iPASSIVE FR Acrylic, closed systems only*	-/90/90	max seal size 2400 x 1200mm, 3.6x50mm(2 layers) iPASSIVE FR Wrap,	FAS180387A.1
uPVC Ø6mm / 1mm wall	Wall	Plasterboard from 75mm, single layer 12.5mm board	iPASSIVE FR Board 30mm 1-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/30/30	max seal size 600x1200mm wide, min 30mm seal separation	FAS180387A.1
uPVC Ø32mm / 1.8mm wall	Wall	Plasterboard from 75mm, single layer 12.5mm board	iPASSIVE FR Board 30mm 1-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/30/30	max seal size 600x1200mm wide, min 30mm seal separation	FAS180387A.1
PVC conduit up to Ø16mm	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 1-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/60/60	max seal size 1200 x 2400mm wide	FAS180387A.1
PVC-U Ø315mm / 9.2mm wall	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 1-sided to both sides, iPASSIVE FR Wraps fitted around pipes, perimeter edges sealed with iPASSIVE FR Acrylic, closed systems only*	-/30/30	18x75mm iPASSIVE FR Wrap fitted centrally around pipe	FAS180387A.1
PVC conduit up to Ø16mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool 150kg /m3 backing	-/180/60	max seal size 1200 x 2400mm wide, min 25mm seal separation	FAS180387D.1
PVC conduit up to Ø16mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 100mm to either side	-/120/60	max seal size 1200 x 2400mm wide, min 25mm seal separation	FAS180387D.1
PVC-U, Ø315mm / 9.2mm wall	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 100mm to either side, iPASSIVE FR Wraps fitted centrally around pipes, closed systems only*	-/120/120	max seal size 1200 x 2400mm wide, min 10mm seal separation, 18x75mm iPASSIVE FR Wrap fitted centrally	FAS180387D.1
PVC-U, up to Ø32mm / 1.6 - 2.4mm wall	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 100mm to either side, closed systems only*	-/120/120	max seal size 1200 x 2400mm wide, min 30mm seal separation	FAS180387D.1
PE, up to Ø32mm / 1.8 - 3mm wall	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 100mm to either side, closed systems only*	-/120/120	max seal size 1200 x 2400mm wide, min 30mm seal separation	FAS180387D.1
PP, up to Ø32mm / 1.9 - 3.4mm wall	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 100mm to either side, closed systems only*	-/120/120	max seal size 1200 x 2400mm wide, min 30mm seal separation	FAS180387D.1
PVC conduit up to Ø16mm	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm flush to top side, 50mm stone wool 150kg /m3 backing	-/180/180	max seal size 1200 x 2400mm, min 30mm separation	FAS180387D.1
PVC conduit up to Ø16mm	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 100mm flush to top side	-/180/180	max seal size 1200 x 2400mm, min 30mm separation	FAS180387D.1
PVC-U, up to Ø40mm / 1.8 - 3.7mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 100mm to either side, iPASSIVE FR Wraps fitted to bottom of seal	-/180/120	max seal size 1200 x 2400mm, min 30mm separation, 1.8x50mm iPASSIVE FR Wrap	FAS180387D.1
PVC-U, up to Ø160mm / 4.5mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 100mm to either side, iPASSIVE FR Wraps fitted to bottom of seal, closed systems only*	-/240/240	max seal size 1200 x 2400mm, min 30mm separation, up to 10.8x50mm iPASSIVE FR Wrap	FAS180387D.1
PP, up to Ø50mm / 2.5 - 5.5mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 100mm to either side, iPASSIVE FR Wraps fitted to bottom of seal	-/240/240	max seal size 1200 x 2400mm, min 30mm separation, 3.6x50mm iPASSIVE FR Wrap	FAS180387D.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
PP, up to Ø75mm / 3.5 - 5.5mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 100mm to either side, iPASSIVE FR Wraps fitted to bottom of seal	-/240/240	max seal size 1200 x 2400mm, min 30mm separation, 3.6x50mm iPASSIVE FR Wrap	FAS180387D.1
PE, up to Ø250mm / 7.8mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 100mm to either side, iPASSIVE FR Wraps fitted to bottom of seal	-/180/180	max seal size 1200 x 2400mm, min 30mm separation, up to 12.6x75mm iPASSIVE FR Wrap	FAS180387D.1
PP, Ø40mm / 3mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm flush to top side, 50mm stone wool 150kg/m ³ backing, closed systems only*	-/120/120	max seal size 1200 x 2400mm, min 30mm separation	FAS180387D.1
PE, Ø40mm / 4mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm flush to top side, 50mm stone wool 150kg/m ³ backing, closed systems only*	-/120/120	max seal size 1200 x 2400mm, min 30mm separation	FAS180387D.1
PE, Ø110mm / 4.3mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm flush to top side, iPASSIVE FR Wrap, 50mm stone wool 150kg/m ³ backing, closed systems only*	-/60/60	max seal size 1200 x 2400mm, min 30mm separation, 2x50mm iPASSIVE FR Wrap	FAS180387D.1
PVC-U, Ø16 - Ø40mm / 1.6 - 3.4mm wall	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm flush to bottom side, 50mm stone wool 150kg/m ³ backing, closed systems only*	-/120/120	max seal size 1200 x 2400mm, min 30mm separation	FAS180387D.1
PVC conduit up to Ø16mm	Wall	Plasterboard from 100mm	iPASSIVE EX Mortar 25mm both sides, 50mm stone wool 150kg /m ³ backing	-/120/120	max seal size 1200 x 2400mm wide, min 25mm separation	FAS180387D.1
PVC-U, up to Ø32mm / 1.6 - 2.4mm wall	Wall	Plasterboard from 100mm	iPASSIVE EX Mortar 25mm both sides, 50mm stone wool 140kg /m ³ backing, closed systems only*	-/120/120	max seal size 1200 x 2400mm wide, min 30mm separation	FAS180387D.1
PE, up to Ø32mm / 1.8 - 3mm wall	Wall	Plasterboard from 100mm	iPASSIVE EX Mortar 25mm both sides, 50mm stone wool 140kg /m ³ backing, closed systems only*	-/120/120	max seal size 1200 x 2400mm wide, min 30mm separation	FAS180387D.1
PP, up to Ø32mm / 1.9 - 4.4mm wall	Wall	Plasterboard from 100mm	iPASSIVE EX Mortar 25mm both sides, 50mm stone wool 140kg /m ³ backing, closed systems only*	-/120/120	max seal size 1200 x 2400mm wide, min 30mm separation	FAS180387D.1
ELECTRICAL PENETRATION SERVICES						
Single cables up to Ø21mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Acrylic either side or any position in between with stone wool backing min 35kg/m ³ density, min annular 7mm, cables fitted at any position within aperture	-/240/90	min seal depth 25mm, max seal size Ø87mm, min 48mm backing	FAS180387C.1
Single cables up to Ø21mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Acrylic either side or any position in between with stone wool backing min 35kg/m ³ density, min annular 7mm, cables fitted at any position within aperture	-/240/60	min seal depth 25mm, max seal size 300x300mm, min 48mm backing	FAS180387C.1
Single cables up to Ø21mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Acrylic either side or any position in between with stone wool backing min 35kg/m ³ density, min annular 7mm, cables fitted at any position within aperture	-/240/120	min seal depth 25mm, max seal size 35x35mm/ Ø36mm, min 48mm backing	FAS180387C.1
Cables, single or bundled up to Ø21mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Acrylic to both sides with stone wool backing min 35kg/m ³ density, min annular 10mm, cables fitted at any position within aperture	-/240/120	min seal depth 15mm, max seal size 300x300mm, min 25mm thick backing	FAS180387C.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL PENETRATION SERVICES						
Cables, single or bundled Ø22-Ø80mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Acrylic to both sides with stone wool backing min 35kg/m ³ density, min annular 10mm, cables fitted at any position within aperture	-/120/60	min seal depth 15mm, max seal size 300x300mm, min 25mm thick backing	FAS180387C.1
Cables, single or bundled up to Ø80mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Acrylic to both sides with stone wool backing min 35kg/m ³ density, min annular 10mm, cables fitted at any position within aperture	-240/60	min seal depth 25mm, max seal size 300x300mm, min 48mm thick backing	FAS180387C.1
Cables, single up to Ø21mm or in bundle up to Ø100mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Acrylic to both sides with stone wool backing min 35kg/m ³ density, min annular 10mm, cables fitted at any position within aperture	-240/240	min seal depth 25mm, max seal size 300x300mm, min 48mm thick backing	FAS180387C.1
Single cables up to Ø21mm	Wall	Plasterboard from 75mm, single layer 13mm board	iPASSIVE FR Acrylic 12.5mm deep, to both sides, cables fitted at any position within aperture	-/60/45	min seal depth 12.5mm, max seal size 150x150mm / Ø344mm, min 10mm annular	FAS180387C.1
Cables, single up to Ø21mm or in bundle up to Ø100mm	Wall	Plasterboard from 75mm, single layer 13mm board	iPASSIVE FR Acrylic 12.5mm deep, to both sides, cables fitted at any position within aperture	-/45/30	min seal depth 12.5mm, max seal size 150x150mm / Ø344mm, min 10mm annular	FAS180387C.1
Cables, single up to Ø21mm or in bundle up to Ø100mm	Wall	Plasterboard from 100mm	iPASSIVE FR Acrylic 25mm deep, to both sides, backed with 20mm deep stone wool 40kg/m ³ , cables fitted at any position within aperture	-/120/120	min seal depth 25mm, max seal size 300x300mm	FAS180387C.1
Cables, single up to Ø80mm or in bundle up to Ø100mm	Wall	Plasterboard from 100mm	iPASSIVE FR Acrylic 25mm deep, to both sides, backed with 25mm AES Mineral fibre, cables fitted at any position within aperture	-/120/60	min seal depth 25mm, max seal size 300x300mm	FAS180387C.1
Single 'e-cable' 1x185mm ² core HD603.3 with PVC sheath & insulation	Wall	Plasterboard from 100mm	iPASSIVE FR Acrylic 12.5mm deep, to both sides, backed with 20mm deep stone wool 140kg/m ³ , cables fitted at any position within aperture	-/120/60	min seal depth 12.5mm, max seal size 300x300mm	FAS180387C.1
Single cables up to Ø21mm	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to either side, backed with 25mm deep AES mineral fibre, cables fitted at any position within aperture	-/120/60	min seal depth 25mm, max aperture Ø82mm or 100x1000mm, min 30mm from edges	FAS180387C.1
Single cables up to Ø21mm	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to top side, backed with 48mm deep AES mineral fibre , cables fitted at any position within aperture,	-/120/90	min seal depth 25mm, max seal size 300x300mm, min 10mm annular	FAS180387C.1
Single cable 1x185mm ² core with PVC sheath & insulation Ø23-Ø27mm	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep, to top side, backed with 48mm deep AES mineral fibre , cables fitted at any position within aperture,	-240/240	min seal depth 25mm, max seal size 300x300mm, min 10mm annular	FAS180387C.1
Cables, single or bundled up to Ø21mm	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Acrylic 15mm deep, to both sides, backed with 25mm deep stone wool 35kg/m ³	-/120/120	min seal depth 15mm, max aperture 300x300mm, min 7mm annular	FAS180387C.1
Cables, single or bundled Ø22-Ø50mm	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Acrylic 15mm deep, to both sides, backed with 25mm deep stone wool 35kg/m ³	-/120/90	min seal depth 15mm, max aperture 300x300mm, min 7mm annular	FAS180387C.1
Cables, single or bundled Ø51-Ø80mm	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Acrylic 15mm deep, to both sides, backed with 25mm deep stone wool 35kg/m ³	-/120/60	min seal depth 15mm, max aperture 300x300mm, min 7mm annular	FAS180387C.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL PENETRATION SERVICES						
Single cables up to Ø21mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/180	max seal size 1200mm x unlimited width, penetration seal min 25mm from edges, min 30mm separation	FAS180387A.1
Cables, single or bundled up to Ø21mm, with/without trays	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/180	max seal size 1200mm x unlimited width, penetration seal min 25mm from edges, min 30mm separation	FAS180387A.1
Cables, single or bundled up to Ø80mm, with trays	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/180/60	max seal size 1200mm x unlimited width, penetration seal min 25mm from edges, min 30mm separation	FAS180387A.1
Cables, single up to Ø21mm in bundles up to Ø100mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/180/120	max seal size 1200mm x unlimited width, penetration seal min 25mm from edges, min 30mm separation	FAS180387A.1
Steel cable trays/ladders	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/180/60	max seal size 1200mm x unlimited width, penetration seal min 25mm from edges, min 30mm separation	FAS180387A.1
Single cables up to Ø21mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/90	max seal size 1200mm x unlimited width, penetration seal min 25mm from edges, min 30mm separation	FAS180387A.1
Single HD603.3, 5x1.5mm ² core with PVC sheath & insulation / Ø14mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/240	max seal size 70x70mm, penetration seals min 25mm from edges, min 30mm separation	FAS180387A.1
Single HD22.4, 5x1.5mm ² core with PO sheath & EPR insulation / Ø11.2 - Ø14.4mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/240	max seal size 70x70mm, penetration seals min 25mm from edges, min 30mm separation	FAS180387A.1
Single HD604.5, 5x1.5mm ² core with EVA sheath & XLPE insulation / Ø13mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/240	max seal size 70x70mm, penetration seals min 25mm from edges, min 30mm separation	FAS180387A.1
Cables, single or bundled up to Ø21mm, with/without trays	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, protruding, boards separated by min 90mm, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/120	max seal size 600x600mm	FAS180387A.1
Cables, single or bundled up to Ø80mm, with trays	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, protruding, boards separated by min 90mm, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/60	max seal size 600x600mm	FAS180387A.1
Cables, single up to Ø21mm in bundles up to Ø100mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, protruding, boards separated by min 90mm, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/240	max seal size 600x600mm	FAS180387A.1
Steel cable trays/ladders	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, protruding, boards separated by min 90mm, perimeter edges sealed with iPASSIVE FR Acrylic	-240/180	max seal size 600x600mm	FAS180387A.1
Non-sheathed wires up to Ø17mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, protruding, boards separated by min 90mm, perimeter edges sealed with iPASSIVE FR Acrylic	-240/180	max seal size 600x600mm	FAS180387A.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL PENETRATION SERVICES						
Non-sheathed wires up to Ø24mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, protruding, boards separated by min 90mm, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/90	max seal size 600x600mm	FAS180387A.1
Cables, single or bundled up to Ø50mm, with/without trays	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, pattress, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/90	max seal size 600x600mm, pattress fixed with 100mm steel screws & penny washers / 350mm centres, min 50mm overlap on opening	FAS180387A.1
Cables, single or bundled up to Ø80mm, with trays	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, pattress, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/60	max seal size 600x600mm, pattress fixed with 100mm steel screws & penny washers / 350mm centres, min 50mm overlap on opening	FAS180387A.1
Cables, single up to Ø21mm in bundles up to Ø100mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, pattress, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/240	max seal size 600x600mm, pattress fixed with 100mm steel screws & penny washers / 350mm centres, min 50mm overlap on opening	FAS180387A.1
Steel cable trays/ladders	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, pattress, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/180	max seal size 600x600mm, pattress fixed with 100mm steel screws & penny washers / 350mm centres, min 50mm overlap on opening	FAS180387A.1
Non-sheathed wires up to Ø24mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, pattress, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/120	max seal size 600x600mm, pattress fixed with 100mm steel screws & penny washers / 350mm centres, min 50mm overlap on opening	FAS180387A.1
Cables, single or bundled up to Ø21mm, with trays	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/120/120	max seal size 2400 x 1200mm	FAS180387A.1
Cables, single or bundled up to Ø80mm, with trays	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/120/60	max seal size 2400 x 1200mm	FAS180387A.1
Cables, single up to Ø21mm in bundles up to Ø100mm	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/120/120	max seal size 2400 x 1200mm	FAS180387A.1
Steel cable trays/ladders	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/120/60	max seal size 2400 x 1200mm	FAS180387A.1
Non-sheathed wires up to Ø24mm	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/180/30	max seal size 2400 x 1200mm	FAS180387A.1
Cables, single up to Ø21mm	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/120/30	max seal size 2400 x 1200mm	FAS180387A.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL PENETRATION SERVICES						
Cables, single up to Ø21mm	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/30	max seal size 600 x 1200mm	FAS180387A.1
Cables, single or bundled up to Ø21mm, with trays	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/90/30	max seal size 2400 x 1200mm	FAS180387A.1
Cables, single or bundled up to Ø80mm, with trays	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/90/30	max seal size 2400 x 1200mm	FAS180387A.1
Cables, single up to Ø21mm in bundles up to Ø100mm	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/30/30	max seal size 2400 x 1200mm	FAS180387A.1
Steel cable trays/ ladders	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/30/30	max seal size 2400 x 1200mm	FAS180387A.1
Non-sheathed wires up to Ø17mm	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/30/30	max seal size 2400 x 1200mm	FAS180387A.1
Non-sheathed wires up to Ø24mm	Floor	Concrete, Aertated Concrete from 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Board 60mm 2-sided to either side, perimeter edges sealed with iPASSIVE FR Acrylic	-/30/-	max seal size 2400 x 1200mm	FAS180387A.1
Cables, single or bundled up to Ø21mm, with trays	Wall	Plasterboard from 75mm, single layer 12.5mm board	iPASSIVE FR Board 30mm 1-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/30/30	max seal size 600x1200mm wide, min 30mm seal separation	FAS180387A.1
Cables, single or bundled up to Ø80mm, with trays	Wall	Plasterboard from 75mm, single layer 12.5mm board	iPASSIVE FR Board 30mm 1-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/30/30	max seal size 600x1200mm wide, min 30mm seal separation	FAS180387A.1
Cables including telecoms up to Ø21mm in bundles up to Ø100mm	Wall	Plasterboard from 75mm, single layer 12.5mm board	iPASSIVE FR Board 30mm 1-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/30/30	max seal size 600x1200mm wide, min 30mm seal separation	FAS180387A.1
Steel cable trays/ ladders	Wall	Plasterboard from 75mm, single layer 12.5mm board	iPASSIVE FR Board 30mm 1-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/30/30	max seal size 600x1200mm wide, min 30mm seal separation	FAS180387A.1
Non-sheathed wires up to Ø24mm	Wall	Plasterboard from 75mm, single layer 12.5mm board	iPASSIVE FR Board 30mm 1-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/30/-	max seal size 600x1200mm wide, min 30mm seal separation	FAS180387A.1
Cables, single or bundled up to Ø21mm, with trays	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 1-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/120/60	max seal size 1200 x 2400mm wide	FAS180387A.1
Cables, single or bundled up to Ø80mm, with trays	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 1-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/60/60	max seal size 1200 x 2400mm wide	FAS180387A.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL PENETRATION SERVICES						
Cables, single up to Ø21mm in bundles up to Ø100mm	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 1-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/60/60	max seal size 1200 x 2400mm wide	FAS180387A.1
Steel cable trays/ladders	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 1-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/60/60	max seal size 1200 x 2400mm wide	FAS180387A.1
Non-sheathed wires up to Ø24mm	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 1-sided to both sides, perimeter edges sealed with iPASSIVE FR Acrylic	-/60/30	max seal size 1200 x 2400mm wide	FAS180387A.1
Cables, single or bundled up to Ø80mm, with trays	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 2-sided to either side, framed aperture, Cables& trays coated 150mm each side, perimeter edges sealed with iPASSIVE FR Acrylic	-/60/60	max seal size 600x1200mm wide, min 30mm seal separation, cables & trays coated 150mm each side with 300µm WFT iPASSIVE FR Service Coat	FAS180387A.1
Cables, single up to Ø21mm in bundles up to Ø100mm	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 2-sided to either side, framed aperture, Cables& trays coated 150mm each side, perimeter edges sealed with iPASSIVE FR Acrylic	-/60/60	max seal size 600x1200mm wide, min 30mm seal separation, cables & trays coated 150mm each side with 300µm WFT iPASSIVE FR Service Coat	FAS180387A.1
Perforated steel cable trays/ladders	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 2-sided to either side, framed aperture, Cables& trays coated 150mm each side, perimeter edges sealed with iPASSIVE FR Acrylic	-/60/60	max seal size 600x1200mm wide, min 30mm seal separation, cables & trays coated 150mm each side with 300µm WFT iPASSIVE FR Service Coat	FAS180387A.1
Unperforated steel cable trays/ladders	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 2-sided to either side, framed aperture, Cables& trays coated 150mm each side, perimeter edges sealed with iPASSIVE FR Acrylic	-/60/30	max seal size 600x1200mm wide, min 30mm seal separation, cables & trays coated 150mm each side with 300µm WFT iPASSIVE FR Service Coat	FAS180387A.1
Non-sheathed wires up to Ø24mm	Wall	Plasterboard from 100mm, 2 layers 12.5mm board	iPASSIVE FR Board 50mm 2-sided to either side, framed aperture, Cables& trays coated 150mm each side, perimeter edges sealed with iPASSIVE FR Acrylic	-/60/30	max seal size 600x1200mm wide, min 30mm seal separation, cables & trays coated 150mm each side with 300µm WFT iPASSIVE FR Service Coat	FAS180387A.1
Cables, single up to Ø21mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool 150kg /m3 backing	-/180/60	max seal size 1200 x 2400mm wide, min 25mm seal separation	FAS180387D.1
Cables, single up to Ø21mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool 150kg /m3 backing	-/240/60	max seal size 80 x 80mm wide, min 25mm seal separation	FAS180387D.1
Cables, single or bundled up to Ø21mm, with trays	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool 150kg /m3 backing	-/180/60	max seal size 1200 x 2400mm wide, min 25mm seal separation	FAS180387D.1
Cables, single or bundled up to Ø50mm, with trays	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool 150kg /m3 backing	-/180/45	max seal size 1200 x 2400mm wide, min 25mm seal separation	FAS180387D.1
Cables, single or bundled up to Ø80mm, with trays	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool 150kg /m3 backing	-/180/45	max seal size 1200 x 2400mm wide, min 25mm seal separation	FAS180387D.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL PENETRATION SERVICES						
Cables, telecomms up to Ø21mm(Single or bundled up to Ø100mm)	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool 150kg /m3 backing	-/180/90	max seal size 1200 x 2400mm wide, min 25mm seal separation	FAS180387D.1
Steel cable trays/ladders	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool 150kg /m3 backing	-/180/60	max seal size 1200 x 2400mm wide, min 25mm seal separation	FAS180387D.1
Non-sheathed wires up to Ø17mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool 150kg /m3 backing	-/180/45	max seal size 1200 x 2400mm wide, min 25mm seal separation	FAS180387D.1
Non-sheathed wires up to Ø24mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 50mm to either side, 50mm stone wool 150kg /m3 backing	-/180/30	max seal size 1200 x 2400mm wide, min 25mm seal separation	FAS180387D.1
Cables, single or bundled up to Ø21mm, with trays	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 100mm to either side	-/240/60	max seal size 1200 x 2400mm wide, min 25mm seal separation	FAS180387D.1
Cables, single or bundled up to Ø80mm, with trays	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 100mm to either side	-/240/60	max seal size 1200 x 2400mm wide, min 25mm seal separation	FAS180387D.1
Cables, single up to Ø21mm in bundles up to Ø100mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 100mm to either side	-/120/120	max seal size 1200 x 2400mm wide, min 25mm seal separation	FAS180387D.1
Steel cable trays/ladders	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 100mm to either side	-/120/60	max seal size 1200 x 2400mm wide, min 25mm seal separation	FAS180387D.1
Non-sheathed wires up to Ø24mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 100mm to either side	-/120/60	max seal size 1200 x 2400mm wide, min 25mm seal separation	FAS180387D.1
Cables, single or bundled up to Ø80mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 50mm to both sides, 50mm stone wool 150kg/m3 backing	-/240/60	max seal size 1200 x 2400mm wide, min 30mm seal separation	FAS180387D.1
Cables, telecomms up to Ø21mm(Single or bundled up to Ø100mm)	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 50mm to both sides, 50mm stone wool 150kg/m3 backing	-/60/60	max seal size 1200 x 2400mm wide, min 30mm seal separation	FAS180387D.1
Steel cable trays/ladders up to 500mm wide	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 50mm to both sides, 50mm stone wool 150kg/m3 backing	-/240/60	max seal size 1200 x 2400mm wide, min 30mm seal separation	FAS180387D.1
Non-sheathed wires up to Ø24mm	Wall	Concrete, Aerated concrete, Masonry, from 150mm, wall thickness may be reduced to 75mm for derated FRL	iPASSIVE EX Mortar 50mm to both sides, 50mm stone wool 150kg/m3 backing	-/240/120	max seal size 1200 x 2400mm wide, min 30mm seal separation	FAS180387D.1
Cables, single up to Ø21mm	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm flush to top side, 50mm stone wool 150kg /m3 backing	-/180/90	max seal size 1200 x 2400mm, min 30mm separation	FAS180387D.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL PENETRATION SERVICES						
Cables, single or bundled up to Ø21mm, with trays	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm flush to top side, 50mm stone wool 150kg /m3 backing	-/180/60	max seal size 1200 x 2400mm, min 30mm separation	FAS180387D.1
Cables, single or bundled up to Ø80mm, with trays	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm flush to top side, 50mm stone wool 150kg /m3 backing	-/180/45	max seal size 1200 x 2400mm, min 30mm separation	FAS180387D.1
Cables, single up to Ø21mm in bundles up to Ø100mm	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm flush to top side, 50mm stone wool 150kg /m3 backing	-/180/180	max seal size 1200 x 2400mm, min 30mm separation	FAS180387D.1
Steel cable trays/ladders	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm flush to top side, 50mm stone wool 150kg /m3 backing	-/90/60	max seal size 1200 x 2400mm, min 30mm separation	FAS180387D.1
Non-sheathed wires up to Ø17mm	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm flush to top side, 50mm stone wool 150kg /m3 backing	-/180/60	max seal size 1200 x 2400mm, min 30mm separation	FAS180387D.1
Non-sheathed wires up to Ø24mm	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 50mm flush to top side, 50mm stone wool 150kg /m3 backing	-/180/30	max seal size 1200 x 2400mm, min 30mm separation	FAS180387D.1
Cables, single or bundled up to Ø50mm, with trays	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 100mm flush to top side	-/180/60	max seal size 1200 x 2400mm, min 30mm separation	FAS180387D.1
Cables, single or bundled up to Ø80mm, with trays	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 100mm flush to top side	-/120/60	max seal size 1200 x 2400mm, min 30mm separation	FAS180387D.1
Cables up to Ø21mm(Single or bundled up to Ø100mm)	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 100mm flush to top side	-/180/120	max seal size 1200 x 2400mm, min 30mm separation	FAS180387D.1
Steel cable trays/ladders	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 100mm flush to top side	-/120/60	max seal size 1200 x 2400mm, min 30mm separation	FAS180387D.1
Non-sheathed wires up to Ø17mm	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 100mm flush to top side	-/180/90	max seal size 1200 x 2400mm, min 30mm separation	FAS180387D.1
Non-sheathed wires up to Ø24mm	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 100mm flush to top side	-/180/-	max seal size 1200 x 2400mm, min 30mm separation	FAS180387D.1
Cables, single or bundled up to Ø21mm	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 150mm	-/240/120	max seal size 1200 x 2400mm, min 30mm separation	FAS180387D.1
Cables up to Ø21mm(Single or bundled up to Ø100mm)	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 150mm	-/120/120	max seal size 1200 x 2400mm, min 30mm separation	FAS180387D.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL PENETRATION SERVICES						
Steel cable trays/ladders up to 500mm wide	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 150mm	-/240/120	max seal size 1200 x 2400mm, min 30mm separation	FAS180387D.1
Cables Ø22-Ø50mm, single or bundled	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 150mm	-/240/90	max seal size 1200 x 2400mm, min 30mm separation	FAS180387D.1
Cables Ø51-Ø80mm, single or bundled	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 150mm	-/90/60	max seal size 1200 x 2400mm, min 30mm separation	FAS180387D.1
Non-sheathed wires up to Ø24mm	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 60mm for derated FRL	iPASSIVE EX Mortar 150mm	-/120/120	max seal size 1200 x 2400mm, min 30mm separation	FAS180387D.1
Cables, single up to Ø21mm	Wall	Plasterboard from 100mm	iPASSIVE EX Mortar 25mm both sides, 50mm stone wool 150kg /m3 backing	-/120/90	max seal size 1200 x 2400mm wide, min 100mm separation	FAS180387D.1
Cables, single or bundled up to Ø80mm, with trays	Wall	Plasterboard from 100mm	iPASSIVE EX Mortar 25mm both sides, 50mm stone wool 150kg /m3 backing	-/120/60	max seal size 1200 x 2400mm wide, min 25mm separation	FAS180387D.1
Steel cable trays/ladders	Wall	Plasterboard from 100mm	iPASSIVE EX Mortar 25mm both sides, 50mm stone wool 150kg /m3 backing	-/120/60	max seal size 1200 x 2400mm wide, min 25mm separation	FAS180387D.1
Non-sheathed wires up to Ø24mm	Wall	Plasterboard from 100mm	iPASSIVE EX Mortar 25mm both sides, 50mm stone wool 150kg /m3 backing	-/120/45	max seal size 1200 x 2400mm wide, min 25mm separation	FAS180387D.1
Cables up to Ø21mm(Single or bundled up to Ø50mm)	Wall	Flexible or Rigid walls ≥100mm	iPASSIVE FR Putty Cord 15mm to both sides	-/120/120	max annular 10mm, min 30mm seal separation	FAS180387E.1
Cables up to Ø80mm(Single or bundled up to Ø50mm)	Wall	Flexible or Rigid walls ≥100mm	iPASSIVE FR Putty Cord 15mm to both sides	-/60/60	max annular 10mm, min 30mm seal separation	FAS180387E.1
Cables up to Ø21mm(Single or bundled up to Ø50mm)	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 100mm for derated FRL	iPASSIVE FR Putty Cord 15mm to top side	-/120/60	max annular 10mm, min 30mm seal separation	FAS180387E.1
Cables, single up to Ø21mm	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 100mm for derated FRL	iPASSIVE FR Putty Cord 15mm to top side	-/120/120	max annular 10mm, min 30mm seal separation	FAS180387E.1
Cables Ø22-Ø50mm, single or bundled	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 100mm for derated FRL	iPASSIVE FR Putty Cord 15mm to top side	-/120/90	max annular 10mm, min 30mm seal separation	FAS180387E.1
Cables Ø51-Ø80mm, single or bundled	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 100mm for derated FRL	iPASSIVE FR Putty Cord 15mm to top side	-/120/60	max annular 10mm, min 30mm seal separation	FAS180387E.1
Cables up to Ø21mm(Single or bundled up to Ø75mm)	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 100mm for derated FRL	iPASSIVE FR Putty Cord 15mm to bottom side	-/60/45	max annular 10mm, min 30mm seal separation	FAS180387E.1
Cables, single up to Ø21mm	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 100mm for derated FRL	iPASSIVE FR Putty Cord 15mm to bottom side	-/120/60	max annular 10mm, min 30mm seal separation	FAS180387E.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL PENETRATION SERVICES						
Cables Ø22-Ø80mm, single or bundled	Floor	Concrete, Aerated concrete, Masonry, from 150mm, floor thickness may be reduced to 100mm for derated FRL	iPASSIVE FR Putty Cord 15mm to bottom side	-/90/45	max annular 10mm, min 30mm seal separation	FAS180387E.1
Cables up to Ø14mm, UK standard double flushbox	Wall	Flexible walls ≥100mm	iPASSIVE FR Putty Pad 4mm fully lining interior of box, up to 130mm wide x 70mm high x 47mm deep, up to 22mm hole for cables	-/60/60	aperture 135mm wide x 75mm high, min 30mm between cable penetrations	FAS180387E.1
Cables up to Ø14mm, UK standard double flushbox	Wall	Flexible walls ≥120mm	iPASSIVE FR Putty Pad 4mm fully lining interior of box, up to 130mm wide x 70mm high x 47mm deep, boxes fitted back to back, 1 to each face, up to 22mm hole for cables	-/90/90	aperture 135mm wide x 77mm high, min 30mm between cable penetrations	FAS180387E.1
Cables, 2.5mm twin & earth	Wall	Flexible walls ≥120mm	iPASSIVE FR Putty Pad 4mm fully lining interior of box, up to 130mm wide x 70mm high x 47mm deep, boxes fitted back to back, 1 to each face, up to 22mm hole for cables	-/90/90	aperture 135mm wide x 77mm high	FAS180387E.1
Cables up to Ø14mm, Schneider Electric IMT 36026 box	Wall	Flexible walls ≥100mm	iPASSIVE FR Putty Pad 4mm fully lining back of box, up to 72mm wide x 90mm high x 50mm deep, boxes fitted side by side, 1 to each face	-/60/45	aperture 73mm wide x 91mm high x 51mm deep	FAS180387E.1
Cables up to Ø14mm, ELKO 4189 1223720 box	Wall	Flexible walls ≥100mm	iPASSIVE FR Putty Pad 4mm fully lining interior of box, up to 72mm wide x 90mm high x 58mm deep, boxes fitted adjacent, 1 to each face	-/90/90	aperture 92mm wide x 112mm high	FAS180387E.1
Cables up to Ø14mm, ELKO 5421 1223470 box	Wall	Flexible walls ≥100mm	iPASSIVE FR Putty Pad 4mm fully lining interior of box, up to 73mm wide x 73mm high x 55mm deep, boxes fitted side by side, 1 to each face	-/90/90	aperture 74mm wide x 74mm high	FAS180387E.1
SEISMIC/CONSTRUCTION JOINTS						
Linear joint seals	Wall, Vertical	Plasterboard/concrete, min wall thickness 75mm with 1 layer 13mm board both sides	iPASSIVE FR Acrylic 12.5mm deep to both sides backed with 50mm steel partition head track/stud	-/60/45	min seal depth 12.5mm, max seal width 15mm	FAS180387C.1
Linear joint seals	Wall, Horizontal	Plasterboard/concrete, min wall thickness 75mm with 1 layer 13mm board both sides	iPASSIVE FR Acrylic 12.5mm deep to both sides backed with 50mm steel partition head track/stud	-/60/45	min seal depth 12.5mm, max seal width 25mm	FAS180387C.1
Linear joint seals	Wall, Vertical	Plasterboard/concrete, min wall thickness 100mm with 2 layers 13mm board both sides	iPASSIVE FR Acrylic 12.5mm deep to both sides backed with 50mm steel partition head track/stud and 12.5mm deep stone wool 35kg/m3	-/120/120	min seal depth 12.5mm, max seal width 15mm	FAS180387C.1
Linear joint seals	Wall, Horizontal	Plasterboard/concrete, min wall thickness 100mm with 2 layers 13mm board both sides	iPASSIVE FR Acrylic 12.5mm deep to both sides backed with 50mm steel partition head track/stud and 12.5mm deep stone wool 35kg/m3	-/120/120	min seal depth 12.5mm, max seal width 25mm	FAS180387C.1
Linear joint seals	Wall, Vertical	Plasterboard/concrete, min wall thickness 100mm with 2 layers 13mm board both sides	iPASSIVE FR Acrylic 25mm deep to both sides backed with 50mm steel partition head track/stud	-/120/120	min seal depth 25mm, max seal width 15mm	FAS180387C.1
Linear joint seals	Wall, Horizontal	Plasterboard/concrete, min wall thickness 100mm with 2 layers 13mm board both sides	iPASSIVE FR Acrylic 25mm deep to both sides backed with 50mm steel partition head track/stud	-/120/120	min seal depth 25mm, max seal width 30mm	FAS180387C.1
Linear joint seals	Wall, Vertical	Masonry/concrete, min wall thickness 150mm	iPASSIVE FR Acrylic 25mm deep to either side backed with 20mm deep stone wool 33kg/m3	-/240/60	min seal depth 25mm, max seal width 30mm	FAS180387C.1

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
SEISMIC/CONSTRUCTION JOINTS						
Linear joint seals	Wall, Horizontal	Masonry/concrete, min wall thickness 150mm	iPASSIVE FR Acrylic 25mm deep to either side backed with 20mm deep stone wool 40kg/m ³	-/240/60	min seal depth 25mm, max seal width 30mm	FAS180387C.1
Linear joint seals	Wall, Vertical	Masonry/concrete, min wall thickness 150mm	iPASSIVE FR Acrylic 15mm deep to both sides backed with 20mm deep stone wool 40kg/m ³	-/240/240	min seal depth 15mm, max seal width 30mm	FAS180387C.1
Linear joint seals	Wall, Horizontal	Masonry/concrete, min wall thickness 150mm	iPASSIVE FR Acrylic 15mm deep to both sides backed with 20mm deep stone wool 40kg/m ³	-/240/240	min seal depth 15mm, max seal width 30mm	FAS180387C.1
Linear joint seals	Wall, Vertical	Masonry/concrete, min wall thickness 150mm	iPASSIVE FR Acrylic 25mm deep to either side backed with 48mm deep AES mineral fibre	-/240/120	min seal depth 25mm, max seal width 30mm	FAS180387C.1
Linear joint seals	Wall, Horizontal	Masonry/concrete, min wall thickness 150mm	iPASSIVE FR Acrylic 25mm deep to either side backed with 48mm deep AES mineral fibre	-/240/120	min seal depth 25mm, max seal width 30mm	FAS180387C.1
Linear joint seals	Wall, Vertical	Masonry/concrete, min wall thickness 150mm	iPASSIVE FR Acrylic 10mm deep to either side backed with 60mm deep stone wool 33kg/m ³	-/240/60	min seal depth 10mm, max seal width 30mm	FAS180387C.1
Linear joint seals	Wall, Horizontal	Masonry/concrete, min wall thickness 150mm	iPASSIVE FR Acrylic 10mm deep to either side backed with 60mm deep stone wool 33kg/m ³	-/240/60	min seal depth 10mm, max seal width 30mm	FAS180387C.1
Linear joint seals	Floor, Horizontal	Masonry/concrete, min floor thickness 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep to any position backed with 25mm deep AES mineral fibre	-/120/60	min seal depth 25mm, max seal width 100mm	FAS180387C.1
Linear joint seals	Floor, Horizontal	Masonry/concrete, min floor thickness 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Acrylic 25mm deep to top face backed with 25mm deep AES mineral fibre	-/180/180	min seal depth 25mm, max seal width 100mm	FAS180387C.1
Linear joint seals	Floor, Horizontal	Masonry/concrete, min floor thickness 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Acrylic 15mm deep to both sides backed with 25mm deep stone wool 40kg/m ³	-/120/120	min seal depth 15mm, max seal width 100mm	FAS180387C.1
Linear joint seals	Floor, Horizontal	Masonry/concrete, min floor thickness 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Acrylic 15mm deep to both sides backed with 25mm deep stone wool 140kg/m ³	-/180/180	min seal depth 15mm, max seal width 100mm	FAS180387C.1
Linear joint seals	Floor, Horizontal	Masonry/concrete, min floor thickness 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Acrylic 15mm deep to both sides backed with 25mm deep stone wool 35kg/m ³	-/240/240	min seal depth 15mm, max seal width 100mm	FAS180387C.1
Linear joint seals	Floor, Horizontal	Masonry/concrete, min floor thickness 150mm, floor thickness may be reduced to min 60mm for derated FRL	iPASSIVE FR Acrylic 10mm deep to both sides backed with 90mm deep stone wool 33kg/m ³	-/240/240	min seal depth 10mm, max seal width 100mm	FAS180387C.1
Linear joint seals	Wall, Horizontal	Plasterboard	iPASSIVE FR Board 60mm 2-sided, cut to shape & friction fitted to either side, top plate to support board, perimeter edges sealed with iPASSIVE FR Acrylic	nominal FRR of substrate	max seal size 1200mm x unlimited width	FAS180387A.1
Linear joint seals	Wall, Horizontal	Masonry/concrete	iPASSIVE FR Board 60mm 2-sided, cut to shape & friction fitted to either side, top plate to support board, perimeter edges sealed with iPASSIVE FR Acrylic	-/240/90	max seal size 1200mm x unlimited width	FAS180387A.1
Control/linear joint seals	Wall, Horizontal	Plasterboard, min wall thickness 100mm, single or double layer board as long as overall board thickness is equal to seal depth	iPASSIVE FR IPT 12.5mm deep to both sides backed with stone wool & partition head track	-/120/120	min seal depth 12.5mm, max seal width 30mm, 12.5mm deep stone wool backing 35kg/m ³	4788656094-B
Control/linear joint seals	Wall, Vertical	Plasterboard, min wall thickness 100mm, single or double layer board as long as overall board thickness is equal to seal depth	iPASSIVE FR IPT 12.5mm deep to both sides backed with stone wool & steel/timber studs	-/120/120	min seal depth 12.5mm, max seal width 30mm, 12.5mm deep stone wool backing 35kg/m ³	4788656094-B
Control/linear joint seals	Wall, Horizontal	Concrete/Masonry, min wall thickness 100mm	iPASSIVE FR IPT 12.5mm deep to both sides backed with stone wool & partition head track	-/120/120	min seal depth 12.5mm, max seal width 30mm, 12.5mm deep stone wool backing 35kg/m ³	4788656094-B

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
SEISMIC/CONSTRUCTION JOINTS						
Control/linear joint seals	Wall, Vertical	Concrete/Masonry, min wall thickness 100mm	iPASSIVE FR IPT 12.5mm deep to both sides backed with stone wool	-/120/120	min seal depth 12.5mm, max seal width 30mm, 12.5mm deep stone wool backing 35kg/m3	4788656094-B
Control/linear joint seals	Wall, Horizontal	Concrete/masonry, min wall thickness 64mm,	iPASSIVE FR IPT 12.5mm deep to both sides backed with stone wool & partition head track	-/60/60	min seal depth 12.5mm, max seal width 30mm, 12.5mm deep stone wool backing 35kg/m3	4788656094-B
Control/linear joint seals	Wall, Vertical	Concrete/masonry, min wall thickness 64mm,	iPASSIVE FR IPT 12.5mm deep to both sides backed with stone wool & partition head track	-/60/60	min seal depth 12.5mm, max seal width 30mm, 12.5mm deep stone wool backing 35kg/m3	4788656094-B
Control/linear joint seals	Floor, Horizontal	Concrete, min floor thickness 150mm	iPASSIVE FR IPT 15mm deep to both sides backed with stone wool	-/240/240	min seal depth 15mm, max seal width 30mm, 20mm deep stone wool backing 33kg/m3	4788656094-B
Control/linear joint seals	Floor, Horizontal	Concrete, min floor thickness 100mm	iPASSIVE FR IPT 15mm deep to both sides backed with stone wool	-/120/120	min seal depth 15mm, max seal width 30mm, 20mm deep stone wool backing 33kg/m3	4788656094-B
Control/linear joint seals	Floor, Horizontal	Concrete, min floor thickness 64mm	iPASSIVE FR IPT 15mm deep to both sides backed with stone wool	-/90/90	min seal depth 15mm, max seal width 30mm, 20mm deep stone wool backing 33kg/m3	4788656094-B
Control/linear joint seals	Floor, Horizontal	Concrete, min floor thickness 150mm	iPASSIVE FR IPT 25mm deep anywhere within floor backed with AES mineral fibre	-/240/180	min seal depth 25mm, max seal width 30mm, 48mm AES mineral fibre 128kg/m3	4788656094-B
Control/linear joint seals	Floor, Horizontal	Concrete, min floor thickness 100mm	iPASSIVE FR IPT 25mm deep anywhere within floor backed with AES mineral fibre	-/120/120	min seal depth 25mm, max seal width 30mm, 48mm AES mineral fibre 128kg/m3	4788656094-B
Control/linear joint seals	Floor, Horizontal	Concrete, min floor thickness 64mm	iPASSIVE FR IPT 25mm deep anywhere within floor backed with AES mineral fibre	-/90/90	min seal depth 25mm, max seal width 30mm, 48mm AES mineral fibre 128kg/m3	4788656094-B
Control/linear joint seals	Wall, Horizontal/ Vertical	Plasterboard, min wall thickness 100mm, single or double layer board as long as overall board thickness is equal to seal depth	iPASSIVE FR ASF 9mm deep to both sides backed with 20mm deep stone wool	-/90/90	min seal depth 9mm, max seal width 30mm, 20mm deep stone wool backing 33kg/m3	4788656094-A
Control/linear joint seals	Wall, Horizontal/ Vertical	Concrete/Masonry, min wall thickness 100mm	iPASSIVE FR ASF 9mm deep to both sides backed with 20mm deep stone wool	-/90/90	min seal depth 9mm, max seal width 30mm, 20mm deep stone wool backing 33kg/m3	4788656094-A
Control/linear joint seals	Wall, Horizontal/ Vertical	Plasterboard, min wall thickness 100mm, single or double layer board as long as overall board thickness is equal to seal depth	iPASSIVE FR ASF 20mm deep to both sides backed with PEF rod	-/120/120	min seal depth 20mm, max seal width 30mm, PEF rod backing	4788656094-A
Control/linear joint seals	Wall, Horizontal/ Vertical	Concrete/Masonry, min wall thickness 100mm	iPASSIVE FR ASF 20mm deep to both sides backed with PEF rod	-/120/120	min seal depth 20mm, max seal width 30mm, PEF rod backing	4788656094-A
Control/linear joint seals	Wall, Horizontal/ Vertical	Plasterboard, min wall thickness 90mm, single or double layer board as long as overall board thickness is equal to seal depth	iPASSIVE FR ASF 9mm deep to both sides backed with stone wool	-/60/60	min seal depth 9mm, max seal width 30mm, stone wool 35 kg/m3 backing	4788656094-A
Control/linear joint seals	Wall, Horizontal/ Vertical	Plasterboard, min wall thickness 130mm, single or double layer board as long as overall board thickness is equal to seal depth	iPASSIVE FR ASF 15mm deep to both sides backed with 15mm deep stone wool	-/120/120	min seal depth 15mm, max seal width 30mm, 15mm deep stone wool backing	4788656094-A

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
SEISMIC/CONSTRUCTION JOINTS						
Control/linear joint seals	Wall, Horizontal/ Vertical	Plasterboard, min wall thickness 130mm, single or double layer board as long as overall board thickness is equal to seal depth	iPASSIVE FR ASF 30mm deep to both sides backed with any backing material	-/120/120	min seal depth 30mm, max seal width 30mm, any backing material	4788656094-A
Control/linear joint seals	Wall, Horizontal/ Vertical	Plasterboard, min wall thickness 130mm, single or double layer board as long as overall board thickness is equal to seal depth	iPASSIVE FR ASF 15mm deep to both sides backed with any backing material	-/120/90	min seal depth 15mm, max seal width 30mm, any backing material	4788656094-A
Control/linear joint seals	Wall, Horizontal/ Vertical	Plasterboard, min wall thickness 130mm, single or double layer board as long as overall board thickness is equal to seal depth	iPASSIVE FR ASF 15mm deep to both sides backed by head/base track	-/120/120	min seal depth 15mm, max seal width 30mm	4788656094-A
Control/linear joint seals	Wall, Horizontal/ Vertical	Plasterboard, min wall thickness 100mm, single or double layer board as long as overall board thickness is equal to seal depth	iPASSIVE FR ASF 20mm deep to both sides backed by head/base track	-/120/120	min seal depth 20mm, max seal width 30mm	4788656094-A
Control/linear joint seals	Wall, Horizontal/ Vertical	Plasterboard, min wall thickness 100mm, single or double layer board as long as overall board thickness is equal to seal depth	iPASSIVE FR ASF 9mm deep to both sides backed by head/base track	-/90/90	min seal depth 9mm, max seal width 30mm	4788656094-A
Control/linear joint seals	Wall, Horizontal/ Vertical	Plasterboard, min wall thickness 90mm, single or double layer board as long as overall board thickness is equal to seal depth	iPASSIVE FR ASF 9mm deep to both sides backed by head/base track	-/60/60	min seal depth 9mm, max seal width 30mm	4788656094-A
Control/linear joint seals	Wall, Horizontal/ Vertical	Concrete/Masonry, min wall thickness 130mm	iPASSIVE FR ASF 15mm deep to both sides backed with 15mm deep stone wool	-/120/120	min seal depth 15mm, max seal width 30mm, 15mm deep stone wool backing	4788656094-A
Control/linear joint seals	Wall, Horizontal/ Vertical	Concrete/Masonry, min wall thickness 130mm	iPASSIVE FR ASF 30mm deep to both sides backed with any backing material	-/120/120	min seal depth 30mm, max seal width 30mm, any backing material	4788656094-A
Control/linear joint seals	Wall, Horizontal/ Vertical	Concrete/Masonry, min wall thickness 130mm	iPASSIVE FR ASF 15mm deep to both sides backed with any backing material	-/120/90	min seal depth 15mm, max seal width 30mm, any backing material	4788656094-A
Control/linear joint seals	Floor, Horizontal	Concrete, min floor thickness 150mm	iPASSIVE FR ASF 25mm deep to top side backed with 25mm deep stone wool 35kg/m ³	-/120/120	min seal depth 25mm, max seal width 100mm, 25mm deep stone wool 35kg/m ³ backing	4788656094-A
Control/linear joint seals	Floor, Horizontal	Concrete, min floor thickness 64mm	iPASSIVE FR ASF 25mm deep to top side backed with 25mm deep stone wool 35kg/m ³	-/90/90	min seal depth 25mm, max seal width 100mm, 25mm deep stone wool 35kg/m ³ backing	4788656094-A

*Not tested to AS 1530.4-2005 or assessed to AS 4072.1 – 2005 for use with Waste Water, Drainage or Vent pipes

RYANFIRE PRODUCTS LTD

Manufacturer Code: RF

11 Ashfield Road
Wairau Valley
AucklandPh: (09) 443 0362
Fax: (09) 443 0364
Website: www.ryanfire.co.nz
info@ryanfire.co.nz

The products listed in this register have all been tested to AS1530.4-2005 or Assessed to AS 4072.1-2005 as referenced within the New Zealand Building Code.

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report No.	ID/Ref
NON-INSULATED NON-COMBUSTIBLE PIPES							
COPPER PIPE	WALL	90X45MM UNLINED TIMBER FRAME WALL	RYANFIRE 802 BOARD	/60/-	80MM DIA PIPE	PF 20007	A
20MM BRASS WINGBACK	WALL	90MM THICK INSULATED FR PLASTERBOARD WALL	RYANFIRE MASTIC	/90/60	20MM DIA PIPE	PF 19025	A
COPPER PIPE	WALL	90MM THICK STANDARD PLASTERBOARD WALL	RYANFIRE 502 BOARD	/30/-	80MM DIA PIPE	PF 20040	F
COPPER PIPE - ONE SIDED PENETRATION	WALL	90MM THICK INSULATED FR PLASTERBOARD WALL	RYANFIRE MASTIC	/90/60	32MM DIA	PF 19025	B
COPPER PIPE	WALL	116MM THICK INSULATED PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD + ROKWRAP	/120/120	32MM DIA PIPE	PF 21005	A
COPPER PIPE	WALL	116MM THICK INSULATED PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD + ROKWRAP	/120/120	150MM DIA PIPE	PF 21005	B
BRASS PIPE	WALL	116MM THICK INSULATED PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD + ROKWRAP	/120/90	100MM DIA PIPE	PF 21005	C
COPPER PIPE	WALL	116MM THICK FR PLASTERBOARD WALL / MASONRY	RYANFIRE MASTIC CONE	/60/15	65MM DIA	FRT 200058	B
COPPER PIPES	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUMASTIC HP	/120/60	15MM DIA PIPE	52208000.1	15
COPPER PIPES	WALL	116MM THICK FR PLASTERBOARD/MASONRY/CONCRETE	INTUMASTIC HP	/120/0	80MM DIA PIPE	51892000.2	C
STEEL PIPES	WALL	120MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUBATT (ONE LAYER EITHER SIDE OF WALL) / INTUMASTIC	/60/30	87MM DIA PIPE	35084000.2	1
STEEL PIPES	WALL	120MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUMASTIC	/60/30	87MM DIA PIPE	35084000.2	2
COPPER PIPE	WALL	126MM THICK WALL - FR PLASTERBOARD / MASONRY	RYANFIRE 502 BOARD	/60/-	150MM DIA	PF 19010	1
BRASS PIPE	WALL	126MM THICK WALL - FR PLASTERBOARD / MASONRY	RYANFIRE 502 BOARD	/60/-	100MM DIA	PF 19010	2
COPPER PIPE	WALL	126MM THICK WALL - FR PLASTERBOARD / MASONRY	RYANFIRE 502 BOARD	/60/-	32MM DIA PIPE	PF 19010	10
COPPER PIPES	WALL	128MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUBATT (ONE LAYER EITHER SIDE OF WALL) / INTUMASTIC / ROCKWOOL SLEEVE	/120/120	152MM DIA PIPE	35084000.2	7
STEEL PIPES	WALL	130MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUBATT (ONE LAYER EITHER SIDE OF WALL) / INTUMASTIC	/120/60	220MM DIA PIPE	35084000.2	5
STEEL PIPES	WALL	130MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUMASTIC	/120/90	60MM DIA PIPE	35084000.2	6
COPPER PIPE	WALL	140X45MM UNLINED TIMBER FRAME	RYANFIRE 502 BOARD	/90/-	34MM DIA PIPE	PF 19031	A
COPPER PIPE (ONE-WAY)	WALL	140X45MM UNLINED TIMBER FRAME	RYANFIRE 502 BOARD	/120/120	34MM DIA PIPE	PF 19039	A

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report No.	ID/Ref
NON-INSULATED NON-COMBUSTIBLE PIPES							
COPPER PIPES	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUSIL	/120/0	15MM DIA PIPE	35256800	1
COPPER PIPES	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUSIL	/120/0	15MM DIA PIPE	35256800	2
STEEL PIPES	WALL	150MM THICK MASONRY WALLS	INTUCOMPOUND / ROCKWOOL SLEEVE	/240/180	170MM DIA PIPE	35084000.2	97
COPPER PIPES	WALL	150MM THICK MASONRY WALLS	INTUCOMPOUND / ROCKWOOL SLEEVE	/240/60	108MM DIA PIPE	35084000.2	98
COPPER PIPE	CEILING	16MM FR PLASTERBOARD CEILING	RYANFIRE MASTIC	/45/-	50MM DIA PIPE	FRT 190272	D
STEEL PIPES	CEILING	26MM THICK FR PLASTERBOARD	INTUMASTIC	/60/0	60MM DIA PIPE	35256800	3
COPPER PIPES	CEILING	26MM THICK FR PLASTERBOARD	INTUMASTIC	/60/0	42MM DIA PIPE	35256800	4
STEEL PIPES	CEILING	26MM THICK FR PLASTERBOARD	INTUBATT / INTUMASTIC	/60/0	50MM DIA PIPE	35256800	5
COPPER PIPE	FLOOR	90MM THICK PLT FLOOR	RYANFIRE HP-X	/60/-	150MM DIA PIPE	PF 20061	B
COPPER PIPES	FLOOR	100MM THICK STAHLTON TIMBER INFILL FLOOR	INTUBATT	/120/0	100MM DIA PIPE	51882400.2	D
COPPER PIPE	FLOOR	120MM THICK WOODTEX FLOOR	RYANFIRE 502 BOARD	/60/-	65MM DIA PIPE	PF 20106	C
COPPER PIPES	FLOOR	120MM THICK CONCRETE	INTUBATT / INSULATION SLEEVE	/90/60	150MM DIA PIPE	35319300	3
COPPER PIPES	FLOOR	120MM THICK CONCRETE	INTUBATT / ARMAFLEX SLEEVE	/120/120	25MM DIA PIPE	2600703	5
COPPER PIPES	FLOOR	120MM THICK CONCRETE	INTUBATT / INTUMASTIC	/180/0	160MM DIA PIPE	2600703.2A	A
BRASS PIPES	FLOOR	120MM THICK CONCRETE	INTUBATT / INTUMASTIC	/180/0	100MM DIA PIPE	2600703.2A	B
BRASS PIPE	FLOOR	130MM THICK COMPOSITE FLOOR	RYANFIRE MASTIC CONE	/120/-	100MM DIA	PF 19012	A
COPPER PIPE	FLOOR	130MM THICK COMPOSITE FLOOR	RYANFIRE MASTIC CONE	/120/-	150MM DIA	PF 19012	B
COPPER PIPE	FLOOR	130MM THICK COMPOSITE FLOOR	RYANFIRE MASTIC CONE	/120/-	34MM DIA	PF 19012	C
BRASS PIPE	FLOOR	130MM THICK COMPOSITE FLOOR	RYANFIRE MASTIC	/120/-	100MM DIA	PF 19012	D
COPPER PIPE	FLOOR	130MM THICK COMPOSITE FLOOR	RYANFIRE MASTIC	/120/-	150MM DIA	PF 19012	E
COPPER PIPE	FLOOR	130MM THICK COMPOSITE FLOOR	RYANFIRE MASTIC	/120/-	34MM DIA	PF 19012	F
STEEL PIPES	FLOOR	COMPOSITE FLOORING - 65MM THICK CONCRETE	INTUBATT / INTUMASTIC	/60/-	150MM DIA PIPE	FAS19047	6
COPPER PIPES	FLOOR	COMPOSITE FLOORING - 65MM THICK CONCRETE	INTUBATT / INTUMASTIC	/120/0	100MM DIA PIPE	46813300.1	6
COPPER PIPE	FLOOR	140X45MM UNLINED TIMBER FLOOR	RYANFIRE 502 BOARD	/60/-	32MM DIA PIPE	FP 19037	A
COPPER PIPE	FLOOR	140X45MM UNLINED TIMBER FLOOR	RYANFIRE 502 BOARD / RYANFIRE MASTIC CONE	/60/-	63MM DIA PIPE	FP 19047	A
COPPER PIPES	FLOOR	150MM THICK CONCRETE	INTUCOMPOUND / ROCKWOOL SLEEVE	/240/240	15MM DIA PIPE	35084000.2	105
STEEL PIPES	FLOOR	150MM THICK CONCRETE	INTUCOMPOUND / ROCKWOOL SLEEVE	/240/90	170MM DIA PIPE	35084000.2	101
COPPER PIPES	FLOOR	150MM THICK CONCRETE	INTUCOMPOUND / ROCKWOOL SLEEVE	/240/30	108MM DIA PIPE	35084000.2	102
STEEL PIPES	FLOOR	150MM THICK CONCRETE	INTUCOMPOUND / ROCKWOOL SLEEVE	/240/240	40MM DIA PIPE	35084000.2	103
STEEL PIPES	FLOOR	150MM THICK CONCRETE	INTUMASTIC / ROCKWOOL SLEEVE	/120/90	49MM DIA PIPE	35084000.2	3
STEEL PIPES	FLOOR	150MM THICK CONCRETE	INTUBATT (SINGLE LAYER)	/30/0	220MM DIA PIPE	35319300	1
STEEL PIPES	FLOOR	150MM THICK CONCRETE	INTUBATT	/120/30	160MM DIA PIPE	35319300	2
STEEL PIPES	FLOOR	150MM THICK CONCRETE	INTUBATT	/120/0	220MM DIA PIPE	35084000.2	4

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report No.	ID/Ref
INSULATED NON-COMBUSTIBLE PIPES							
COPPER PIPE + 32MM ARMAFLEX	WALL	90X45MM UNLINED TIMBER FRAME WALL	RYANFIRE 802 BATT / RYANFIRE STRAP	/60/30	80MM DIA COPPER + 32MM ARMAFLEX	PF 20007	F
COPPER PIPE + ARMAFLEX	WALL	116MM FR PLASTERBOARD / MASONRY WALL	RYANFIRE SL COLLAR	/60/60	20MM DIA COPPER + 25MM ARMAFLEX	FRT 200058	C
COPPER PIPE + THERMOBREAK	WALL	116MM FR PLASTERBOARD / MASONRY WALL	RYANFIRE SL COLLAR	/60/60	32MM DIA COPPER + 40MM THERMOBREAK	FRT 200058	F
COPPER PIPE + ARMAFLEX	WALL	116MM FR PLASTERBOARD / MASONRY WALL	RYANFIRE SL COLLAR	/60/60	80MM DIA COPPER + 38MM ARMAFLEX	FRT 200058	E
COPPER PIPE + ARMAFLEX	WALL	116MM INSULATED FR PLASTERBOARD WALL / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE STRAP	/120/120	32MM DIA COPPER + 38MM ARMAFLEX	PF 20096	D
COPPER PIPE + GLASS FIBRE	WALL	116MM INSULATED FR PLASTERBOARD WALL / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE STRAP	/120/90	32MM DIA COPPER + 50MM FIBREGLASS	PF 20096	E
COPPER PIPES / 40MM THICK THERMOBREAK	WALL	116MM THICK FR PLASTERBOARD / MASONRY / CONCRETE	INTUBATT / INTUSTRAP	/120/30	80MM DIA PIPE	51892000.2	G
COPPER PIPES / 38MM THICK ARMAFLEX	WALL	128MM THICK FR PLASTERBOARD / MASONRY / CONCRETE	INTUBATT / INTUSTRAP	/120/90	25MM DIA PIPE	35084000.2	10
COPPER PIPES / 50MM THICK FIBREGLASS	WALL	128MM THICK FR PLASTERBOARD / MASONRY / CONCRETE	INTUBATT / INTUSTRAP	/120/90	25MM DIA PIPE	35084000.2	11
COPPER PIPES / 50MM THICK FIBREGLASS	WALL	128MM THICK FR PLASTERBOARD / MASONRY / CONCRETE	INTUBATT / INTUSTRAP	/180/90	25MM DIA PIPE	35084000.2	11
COPPER PIPES / 38MM THICK ARMAFLEX	WALL	128MM THICK FR PLASTERBOARD / MASONRY / CONCRETE	INTUBATT / INTUSTRAP	/180/90	25MM DIA PIPE	35084000.2	10
COPPER PIPES / 32MM THICK ARMAFLEX	WALL	130MM THICK FR PLASTERBOARD / MASONRY / CONCRETE	INTUSLEEVE / INTUMASTIC	/120/120	15MM DIA PIPE	35084000.2	8
COPPER PIPES / 50MM THICK FIBREGLASS	WALL	130MM THICK FR PLASTERBOARD / MASONRY / CONCRETE	INTUSLEEVE / INTUMASTIC	/120/120	15MM DIA PIPE	35084000.2	9
COPPER PIPES / 30MM THICK FIBREGLASS	WALL	142MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUMASTIC HP	/120/90	160MM DIA PIPE	52208000.1	11
COPPER PIPES / 33MM THICK ARMAFLEX	WALL	142MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUMASTIC HP	/120/30	160MM DIA PIPE	52208000.1	12
COPPER PIPES / 33MM THICK ARMAFLEX	WALL	142MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUMASTIC HP	/120/120	67MM DIA PIPE	52208000.1	13
COPPER PIPES / 13MM THICK ARMAFLEX	WALL	142MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUMASTIC HP	/120/120	15MM DIA PIPE	52208000.1	14
COPPER PIPES / 33MM THICK ARMAFLEX	WALL	142MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUMASTIC HP	/120/120	15MM DIA PIPE	52208000.1	15
COPPER PIPES / 33MM THICK ARMAFLEX	WALL	142MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUMASTIC HP	/120/120	40MM DIA PIPE	52208000.1	16
STEEL PIPES / 38MM THICK ARMAFLEX	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUBATT / INTUSTRAP / INTUMASTIC	/120/60	220MM DIA PIPE	35256800	6
STEEL PIPES / 50MM THICK FIBREGLASS	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUBATT / INTUSTRAP / INTUMASTIC	/120/90	220MM DIA PIPE	35256800	7

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report No.	ID/Ref
INSULATED NON-COMBUSTIBLE PIPES							
COPPER PIPES / 30MM THICK PIR	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUBATT / INTUMASTIC HP	/120/120	22MM DIA PIPE	35319300	4
COPPER PIPES / 60MM THICK FIBREGLASS	WALL	150MM THICK MASONRY WALL	INTUCOMPOUND	/240/60	108MM DIA PIPE	35084000.2	98
COPPER PIPES / 40MM THICK ROCKWOOL	WALL	150MM THICK MASONRY WALL	INTUCOMPOUND	/240/180	15MM DIA PIPE	35084000.2	99
COPPER PIPES / 60MM THICK FIBREGLASS	WALL	150MM THICK MASONRY WALL	INTUCOMPOUND	/240/240	15MM DIA PIPE	35084000.2	103
STEEL PIPE / 25MM THICK ARMAFLEX	CEILING	26MM THICK FR FR PLASTERBOARD	INTUMASTIC HP	/60/30	34MM DIA PIPE	35256800	8
COPPER PIPE + 25MM THERMOBREAK	FLOOR	90MM THICK PLT FLOOR	RYANFIRE SL COLLAR	/30/30	32MM DIA COPPER + 25MM THERMOBREAK	PF 20061	K
COPPER PIPE + 25MM ARMAFLEX	FLOOR	90MM THICK PLT FLOOR	RYANFIRE SL COLLAR	/30/30	32MM DIA COPPER + 25MM THERMOBREAK	PF 20061	L
COPPER PIPE / 38MM THICK ARMAFLEX	FLOOR	100MM THICK STALTON TIMBER INFILL FLOOR	INTUBATT / INTUSTRAP	/90/90	80MM DIA COPPER PIPE	51892400.2	B
COPPER PIPES / 38MM THICK ARMAFLEX	FLOOR	120MM THICK CONCRETE	INTUBATT / INTUSTRAP	/120/120	25MM DIA PIPE	35084000.2	14
COPPER PIPES / 50MM THICK PIR INSULATION	FLOOR	120MM THICK CONCRETE	INTUBATT / INTUSTRAP	/120/90	25MM DIA PIPE	2600703.2A	D
COPPER PIPES / 50MM THICK GLASSFIBRE INSULATION	FLOOR	120MM THICK CONCRETE	INTUBATT / INTUSTRAP	/180/90	25MM DIA PIPE	2600703.2A	F
COPPER PIPES / 50MM THICK ROCKWOOL INSULATION	FLOOR	120MM THICK CONCRETE	INTUBATT / INTUSTRAP	/180/90	25MM DIA PIPE	2600703.2A	G
COPPER PIPE / 19MM THICK ARMAFLEX INSULATION	FLOOR	120MM THICK CONCRETE	RYANFIRE 502 BOARD / RYANFIRE STRAP	/120/120	32MM DIA COPPER + 19MM ARMAFLEX	PF 20102	A
COPPER PIPE / 50MM THICK GLASSFIBRE INSULATION	FLOOR	120MM THICK CONCRETE	RYANFIRE 502 BOARD / RYANFIRE STRAP	/120/120	32MM DIA COPPER + 50MM FIBREGLASS	PF 20102	B
COPPER PIPE / 38MM THICK ARMAFLEX	FLOOR	120MM THICK CONCRETE	RYANFIRE 502 BOARD / RYANFIRE STRAP	/120/30	32MM DIA COPPER + 38MM ARMAFLEX	PF 20102	D
COPPER PIPE / 38MM THICK FIBREGLASS	FLOOR	120MM THICK CONCRETE	RYANFIRE 502 BOARD / RYANFIRE STRAP	/90/90	32MM DIA COPPER + 38MM FIBREGLASS	PF 20100	F
COPPER PIPE + FIBREGLASS	FLOOR	120MM THICK WOODTEX FLOOR	RYANFIRE 502 BOARD / RYANFIRE STRAP	/60/60	32MM DIA COPPER + 32MM GLASSFIBRE	PF 20106	E
COPPER / 40MM THICK ARMAFLEX	FLOOR	COMPOSITE FLOORING - 65MM THICK CONCRETE	INTUBATT / INTUSTRAP	/120/90	80MM DIA PIPE	46812300.1	7
COPPER PIPE + 25MM ARMAFLEX	FLOOR	140X45MM UNLINED TIMBER FLOOR	RYANFIRE 502 BOARD / RYANFIRE STRAP	/60/30	32MM DIA COPPER + 25MM ARMAFLEX	PF 19047	D
COPPER PIPE + 25MM ARMAFLEX	FLOOR	140X45MM UNLINED TIMBER FLOOR	RYANFIRE 502 BOARD / RYANFIRE STRAP	/60/30	32MM DIA COPPER + 25MM ARMAFLEX	PF 19047	F
STEEL PIPES / 38MM THICK ARMAFLEX	FLOOR	150MM THICK CONCRETE	INTUCOLLAR	/120/60	89MM DIA PIPE	35256800	9
STEEL PIPES / 40MM THICK ARMAFLEX	FLOOR	150MM THICK CONCRETE	INTUMASTIC HP	/90/60	89MM DIA PIPE	35256800	10
STEEL PIPES / 38MM THICK ARMAFLEX	FLOOR	150MM THICK CONCRETE	INTUBATT (SINGLE LAYER) / INTUSTRAP	/30/30	220MM DIA PIPE	35256800	11
STEEL PIPES / 50MM THICK FIBREGLASS	FLOOR	150MM THICK CONCRETE	INTUBATT (SINGLE LAYER) / INTUSTRAP	/90/30	220MM DIA PIPE	35256800	12
COPPER PIPES / 50MM THICK FIBREGLASS	FLOOR	150MM THICK CONCRETE	INTUSTRAP / INTUMASTIC	/120/120	15MM DIA PIPE	35084000.2	12
COPPER PIPES / 35MM THICK ARMAFLEX	FLOOR	150MM THICK CONCRETE	INTUSTRAP / INTUMASTIC	/120/120	15MM DIA PIPE	35084000.2	13

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report No.	ID/Ref
INSULATED NON-COMBUSTIBLE PIPES							
STEEL PIPES / 60MM THICK FIBREGLASS	FLOOR	150MM THICK CONCRETE	INTUSTRAP	/60/30	160MM DIA PIPE	35319300	5
STEEL PIPES / 60MM THICK ARMAFLEX	FLOOR	150MM THICK CONCRETE	INTUBATT / INTUSTRAP	/60/0	160MM DIA PIPE	35319300	6
STEEL PIPES / 40MM THICK ARMAFLEX	FLOOR	150MM THICK CONCRETE	INTUBATT / INTUSTRAP	/240/30	220MM DIA PIPE	35319300	7
STEEL PIPES / 38MM THICK ARMAFLEX	FLOOR	150MM THICK CONCRETE	INTUCOMPOUND / INTUSTRAP	/180/180	55MM DIA PIPE	35084000.2	15
STEEL PIPES / 50MM THICK FIBREGLASS	FLOOR	150MM THICK CONCRETE	INTUCOMPOUND / INTUSTRAP	/60/60	160MM DIA PIPE	35084000.2	16
COPPER PIPES / 60MM THICK FIBREGLASS	FLOOR	150MM THICK CONCRETE	INTUCOMPOUND / INTUSTRAP	/240/240	15MM DIA PIPE	35084000.2	104
NON-INSULATED COMBUSTIBLE PIPES							
PVC PIPE	WALL	KOROK 51 - 30MIN INSULATION WALL SYSTEM	SL COLLAR	/90/30	50MM DIA	FP 10847.002	5
PVC PIPE	WALL	KOROK 51 - 60MIN INSULATION WALL SYSTEM	SL COLLAR	/90/60	50MM DIA	FP 10847.002	5
PVC PIPE	WALL	KOROK 51 - 30MIN INSULATION WALL SYSTEM	SL COLLAR	/90/30	160MM DIA	FP 10847.002	2
PVC PIPE	WALL	KOROK 51 - 60MIN INSULATION WALL SYSTEM	SL COLLAR	/90/60	160MM DIA	FP 10847.002	2
PVC PIPE	WALL	90X45MM UNLINED TIMBER FRAME	RYANFIRE 802 BATT / RYANFIRE SERVICE SLEEVE	/60/60	100MM DIA PIPE	PF 20007	D
POLYBUTYLENE PIPE	WALL	90X45MM UNLINED TIMBER FRAME	RYANFIRE 802 BATT / RYANFIRE STRAP	/60/60	25MM DIA PIPE	PF 20007	B
PVC PIPE	WALL	90MM THICK WALL - STANDARD PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE SL COLLAR	/30/30	100MM DIA PIPE	PF 20040	A
PVC PIPE	WALL	90MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE SL COLLAR / RYANFIRE MASTIC	/60/45	80MM DIA PIPE	FRT 190250	A
PVC PIPE	WALL	90MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE SL COLLAR / RYANFIRE MASTIC	/60/45	100MM DIA PIPE	FRT 190250	B
PVC PIPE	WALL	90MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE SL COLLAR / RYANFIRE MASTIC	/60/	150MM DIA PIPE	FRT 190250	C
PVC PIPE	WALL	90MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE SL COLLAR / RYANFIRE MASTIC	/60/45	40MM DIA PIPE	FRT 190250	F
PVC PIPE	WALL	90MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE SL COLLAR / RYANFIRE MASTIC	/60/45	50MM DIA PIPE	FRT 190250	G
PVC PIPE	WALL	90MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE SL COLLAR / RYANFIRE MASTIC	/60/45	65MM DIA PIPE	FRT 190250	H
PEX PIPE	WALL	90MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE SL COLLAR / RYANFIRE HPX	/60/45	16MM DIA PIPE	FRT 190250	D
PP-R PIPE	WALL	90MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE SL COLLAR / RYANFIRE MASTIC	/60/45	32MM DIA PIPE	FRT 190250	E
PE-RT/AL/PE-RT (KELOX)	WALL	90MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE SL COLLAR / RYANFIRE MASTIC	/60/15	32MM DIA PIPE	FRT 190251	A

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report No.	ID/Ref
NON-INSULATED COMBUSTIBLE PIPES							
PP-R	WALL	90MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE SL COLLAR / RYANFIRE MASTIC	/30/30	160MM DIA PIPE	FRT 190251	B
PEX AL GAS	WALL	90MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE SL COLLAR / RYANFIRE HPX	/60/45	16MM DIA PIPE	FRT 190251	C
PEX	WALL	90MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE SL COLLAR / RYANFIRE MASTIC	/60/30	40MM DIA PIPE	FRT 190251	D
POLYBUTENE PIPE	WALL	90MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE SL COLLAR / RYANFIRE MASTIC	/60/45	28MM DIA PIPE	FRT 190251	E
PE-RT/AL/PE-RT (KELOX)	WALL	90MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE SL COLLAR / RYANFIRE HPX	/60/45	16MM DIA PIPE	FRT 190251	F
PEX AL GAS	WALL	90MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE SL COLLAR / RYANFIRE MASTIC	/60/15	40MM DIA PIPE	FRT 190251	G
PVC PIPE - ONE SIDED PENETRATION	WALL	90MM THICK INSULATED FR PLASTERBOARD WALL	RYANFIRE SL COLLAR	90/60	40MM DIA PIPE	PF 19025	E
POLYBUTYLENE PIPE - ONE SIDED PENETRATION	WALL	90MM THICK INSULATED FR PLASTERBOARD WALL	RYANFIRE HPX	/90/90	25MM DIA	PF 19025	C
PVC PIPE + KNUCKLE JOINT	WALL	90MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE SL COLLAR	/60/45	110MM + JOINT	FRT 190252	B
KELOX PIPE	WALL	90MM THICK INSULATED FR PLASTERBOARD WALL	RYANFIRE SL COLLAR	/60/30	16MM DIA PIPE	PF 20067	D
PEX PIPE	WALL	90MM THICK INSULATED FR PLASTERBOARD WALL	RYANFIRE SL COLLAR	/60/30	16MM DIA PIPE	PF 20067	F
PEX AL GAS	WALL	90MM THICK INSULATED FR PLASTERBOARD WALL	RYANFIRE SL COLLAR	/60/60	16MM DIA PIPE	PF 20067	G
PPR PIPE	WALL	90MM THICK INSULATED FR PLASTERBOARD WALL	RYANFIRE SL COLLAR	/60/60	16MM DIA PIPE	PF 20067	H
POLYBUTYLENE	WALL	90MM THICK INSULATED FR PLASTERBOARD WALL	RYANFIRE SL COLLAR	/60/60	16MM DIA PIPE	PF 20067	I
DBLUE (MDPE) PIPE	WALL	90MM THICK INSULATED FR PLASTERBOARD WALL	RYANFIRE SL COLLAR	/60/60	20MM DIA PIPE	PF 20067	J
PVC PIPE	WALL	90MM THICK INSULATED FR PLASTERBOARD WALL	RYANFIRE SL COLLAR	/60/60	20MM DIA PIPE	PF 20067	L
PVC PIPE / COUPLING / KNUCKLE JOINT	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	SL COLLAR	/90/60	110MM DIA PIPE	46469500.2	H
PVC PIPE / COUPLING / KNUCKLE JOINT	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUSLEEVE / INTUMASTIC HP	/90/0	110MM DIA PVC PIPE WITH COUPLING	51028300.1	C
PVC PIPE	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	80MM DIA PVC PIPE - 160MM DIA SL COLLAR - INTUMASTIC HP	90/90	80MM DIA PVC PIPE	51028300.1	E
PVC PIPE	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	80MM DIA PVC PIPE - 160MM DIA INTUSLEEVE - INTUMASTIC HP	90/60	80MM DIA PVC PIPE	51028300.1	F
PVC PIPE	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUSLEEVE 300	/60/60	160MM DIA PIPE	46469500.2	G
PVC PIPE	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	SL COLLAR	/90/60	160MM DIA PIPE	46469500.2	F
BUTELINE PIPE	WALL	116MM THICK FR PLASTERBOARD/MASONRY/CONCRETE	SL COLLAR / INTUMASTIC HP	/120/120	22MM DIA PIPE	51892000.2	H
BUTELINE PIPE	WALL	116MM THICK FR PLASTERBOARD/MASONRY/CONCRETE	INTUMASTIC HP	/120/120	22MM DIA PIPE	51892000.2	I
PEX PIPE	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUMASTIC HP	/60/0	32MM DIA PIPE	46469500.2	B
PVC PIPE	WALL	116MM THICK FR PLASTERBOARD/MASONRY/CONCRETE	RYANFIRE HPX SEALANT	/120/120	50MM DIA PIPE	51892000.2	B
PVC PIPE + KNUCKLE JOINT	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE SERVICE SLEEVE	/60/0	100MM DIA PIPE + SOCKET	FRT 200058	F
PVC PIPE	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANSTRAP	/120/60	32MM DIA PIPE	FRT 190079	C
HDPE PIPE	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANSTRAP	/120/90	40MM DIA PIPE	FRT 190079	D

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report No.	ID/Ref
NON-INSULATED COMBUSTIBLE PIPES							
BUTELINE	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANSTRAP	/120/60	28MM DIA PIPE	FRT 190079	E
BUTELINE	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANSTRAP	/120/60	18MM DIA PIPE	FRT 190079	F
PE-RT TYPE II/AL/PE-RT PIPE	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE HPX	/60/15	32MM DIA PIPE	FRT 190079	G
PE-RT TYPE II/AL/PE-RT PIPE	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE HPX	/120/45	16MM DIA PIPE	FRT 190079	I
HDPE PIPE	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE FS COLLAR	/45/45	40MM DIA PIPE	FRT 190079	L
PVC	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE FS COLLAR	/60/45	50MM DIA PIPE	FRT 190079	N
PVC	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANSTRAP	/60/	50MM DIA PIPE	FRT 190079	O
HDPE PIPE	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANSTRAP	/60/	60MM DIA PIPE	FRT 190079	P
PVC	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE FS COLLAR	/120/60	40MM DIA PIPE	FRT 190079	Q
PVC	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE FS COLLAR	/120/60	65MM DIA PIPE	FRT 190079	R
PVC	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE FS COLLAR	/120/60	80MM DIA PIPE	FRT 190079	S
HDPE PIPE	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE FS COLLAR	/60/60	150MM DIA PIPE	FRT 190079	U
PVC	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE FS COLLAR	/45/	150MM DIA PIPE	FRT 190079	V
PVC	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE FS COLLAR	/120/	100MM DIA PIPE	FRT 190079	W
PVC + PVC SOCKET	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE FS COLLAR / RYANFIRE HPX	/60/	100MM DIA PIPE	FRT 190079	X
POLYBUTENE	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE HPX	/120/30	28MM DIA PIPE	FRT 190080	C
PVC	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE HPX	/120/90	20MM DIA PIPE	FRT 190080	D
PE-RT TYPE II/AL/PE-RT PIPE (KELOX)	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE HPX	/120/15	32MM DIA PIPE	FRT 190080	E
PEX	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE HPX	/120/120	16MM DIA PIPE	FRT 190080	F
PEX GAS	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE HPX	/120/90	16MM DIA PIPE	FRT 190080	G
PE-RT TYPE II/AL/PE-RT PIPE (KELOX)	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE HPX	/120/60	16MM DIA PIPE	FRT 190080	H
PEX	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE HPX	/30/	40MM DIA PIPE	FRT 190080	I
PEX GAS	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE HPX	/120/15	40MM DIA PIPE	FRT 190080	J
PPR	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE HPX	/30/	63MM DIA PIPE	FRT 190080	L
PEX GAS	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE HPX	/15/15	63MM DIA PIPE	FRT 190080	M
PE-HD	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE HPX	/120/60	40MM DIA PIPE	FRT 190080	N
POLYPROPYLENE ACOUSTIC (DBLUE)	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE HPX	/60/	50MM DIA PIPE	FRT 190080	O
PVC	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE HPX	/60/15	50MM DIA PIPE	FRT 190080	P
PE-RT TYPE II/AL/PE-RT PIPE (KELOX)	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE FS COLLAR	/30/30	50MM DIA PIPE	FRT 190080	Q
PE-RT TYPE II/AL/PE-RT PIPE (KELOX)	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE FS COLLAR	/120/120	16MM DIA PIPE	FRT 190080	S
PVC	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE FS COLLAR	/120/90	40MM DIA PIPE	FRT 190080	T
PVC	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE FS COLLAR	/120/90	50MM DIA PIPE	FRT 190080	U

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report No.	ID/Ref
NON-INSULATED COMBUSTIBLE PIPES							
PVC	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE FS COLLAR	/120/60	65MM DIA PIPE	FRT 190080	V
PVC	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE FS COLLAR	/120/60	80MM DIA PIPE	FRT 190080	W
PVC	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE FS COLLAR	/120/	100MM DIA PIPE	FRT 190080	X
PVC	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE FS COLLAR	/120/90	150MM DIA PIPE	FRT 190080	Y
PEX PIPE	WALL	116MM THICK INSULATED FR PLASTERBOARD WALL	RYANFIRE HP-X	/60/-	40MM DIA PIPE	PF 20094	E
PEX AL GAS PIPE	WALL	116MM THICK INSULATED FR PLASTERBOARD WALL	RYANFIRE HP-X	/120/120	16MM DIA PIPE	PF 20094	F
PEX AL GAS PIPE	WALL	116MM THICK INSULATED FR PLASTERBOARD WALL	RYANFIRE HP-X	/120/60	40MM DIA PIPE	PF 20094	G
PEX PIPE	WALL	116MM THICK INSULATED FR PLASTERBOARD WALL	RYANFIRE 502 BOARD / HP-X	/120/120	16MM DIA PIPE	PF 20095	A
PEX PIPE	WALL	116MM THICK INSULATED FR PLASTERBOARD WALL	RYANFIRE 502 BOARD / HP-X	/90/-	40MM DIA PIPE	PF 20095	B
PEX AL GAS PIPE	WALL	116MM THICK INSULATED FR PLASTERBOARD WALL	RYANFIRE 502 BOARD / HP-X	/120/120	16MM DIA PIPE	PF 20095	C
PEX AL GAS PIPE	WALL	116MM THICK INSULATED FR PLASTERBOARD WALL	RYANFIRE 502 BOARD / HP-X	/90/30	40MM DIA PIPE	PF 20095	F
PVC PIPE	WALL	116MM THICK INSULATED FR PLASTERBOARD WALL	RYANFIRE 502 BOARD / RYANFIRE STRAP	/120/120	50MM DIA PIPE	PF 20095	G
PVC PIPE	WALL	116MM THICK INSULATED FR PLASTERBOARD WALL	RYANFIRE 502 BOARD / RYANFIRE STRAP	/120/120	20MM DIA PIPE	PF 20095	H
PVC PIPE	WALL	120MM THICK MASONRY WALL	INTUCOLLAR GV	/120/90	100MM DIA PIPE	FAR 4035	G
PVC PIPE	WALL	FR PLASTERBOARD / MASONRY / CONCRETE	INTUCOLLAR GV	/120/120	40MM DIA PIPE	FAR 4035	G
PVC PIPE	WALL	126MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE STRAP	/60/60	36MM DIA PIPE	PF 19010	2
PVC PIPE	WALL	126MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE SL COLLAR	/30/30	150MM DIA PIPE	PF 19010	3
PVC PIPE	WALL	126MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE SL COLLAR	/60/60	32MM DIA PIPE	PF 19010	6
PVC PIPE	WALL	126MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE SL COLLAR	/30/30	100MM DIA PIPE	PF 19010	7
PVC PIPE + KNUCKLE JOINT	WALL	126MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE SL COLLAR	/60/60	100MM DIA PIPE + KNUCKLE JOINT	PF 19010	8
PVC PIPE	WALL	126MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE SL COLLAR	/60/60	50MM DIA PIPE	PF 19010	9
PVC PIPE	WALL	126MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE STRAP	/60/-	65MM DIA PIPE	PF 19010	11
KELOX	WALL	126MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / HPX	/30/-	32MM DIA PIPE	PF 19010	13
PVC PIPE	WALL	126MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE SL COLLAR	/60/60	82MM DIA PIPE	PF 19010	16
PVC PIPE	WALL	126MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE SL COLLAR	/30/30	40MM DIA PIPE	PF 19010	18
HDPE PIPE	WALL	126MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE SL COLLAR	/30/30	150MM DIA PIPE	PF 19010	19
HDPE PIPE	WALL	126MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE SL COLLAR	/60/60	40MM DIA PIPE	PF 19010	20
KELOX	WALL	126MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE HPX	/60/30	16MM DIA PIPE	PF 19010	22
BANK OF 25MM DIA PPR PIPES	WALL	126MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE SL COLLAR	/60/60	4X 25MM DIA PIPES	PF 19010	23
HDPE PIPE	WALL	126MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE STRAP	/60/60	40MM DIA PIPE	PF 19010	24
KELOX	WALL	126MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE STRAP	/60/60	32MM DIA PIPE	PF 19010	25
PVC PIPE	WALL	128MM THICK FR PLASTERBOARD WALL	INTUCOLLAR GV	/120/60	100MM DIA PIPE	FAR 4035	G
HDPE PIPE	WALL	128MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUBATT / INTUSTRAP	/120/120	40MM DIA PIPE	35084000.2	17
PVC PIPE	WALL	128MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUBATT / INTUSTRAP	/120/120	43MM DIA PIPE	35084000.2	20
HDPE PIPE	WALL	128MM THICK FR PLASTERBOARD / MASONRY / CONCRETE	INTUBATT / INTUSTRAP	/240/120	40MM DIA PIPE	35084000.2	17

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report No.	ID/Ref
NON-INSULATED COMBUSTIBLE PIPES							
PVC PIPE	WALL	128MM THICK FR PLASTERBOARD / MASONRY / CONCRETE	INTUBATT / INTUSTRAP	/240/240	43MM DIA PIPE	35084000.2	20
HDPE PIPE	WALL	130MM THICK FR PLASTERBOARD / MASONRY / CONCRETE	INTUSLEEVE / ROCKWOOL SLEEVE	/120/120	110MM DIA PIPE	35084000.2	18
PVC PIPE	WALL	130MM THICK FR PLASTERBOARD / MASONRY / CONCRETE	INTUSLEEVE / ROCKWOOL SLEEVE	/120/120	50MM DIA PIPE	35084000.2	19
PVC PIPE - ONE SIDED PENETRATION	WALL	140X45MM UNLINED TIMBER FRAME	RYANFIRE 502 BOARD / RYANFIRE STRAP	/120/120	32MM DIA PIPE	PF 19039	E
POLYBUTYLENE PIPE - ONE SIDED PENETRATION	WALL	140X45MM UNLINED TIMBER FRAME	RYANFIRE 502 BOARD / RYANFIRE STRAP	/120/120	28MM DIA PIPE	PF 19039	D
POLYBUTYLENE PIPE	WALL	140X45MM UNLINED TIMBER FRAME	RYANFIRE 502 BOARD / RYANFIRE STRAP	/90/90	25MM DIA PIPE	PF 19031	C
PVC PIPE	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUBATT / INTUSTRAP	/120/120	55MM DIA PIPE	35319300	8
HDPE PIPE	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUCOLLAR	/90/90	160MM DIA PIPE	35256800	13 - 16
PPR PIPE	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUCOLLAR	/90/90	75MM DIA PIPE	35256800	17
ABS PIPE	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUCOLLAR	/90/90	90MM DIA PIPE	35256800	18
PVC PIPE	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUCOLLAR	/120/60	55MM DIA PIPE	35256800	19
PVC PIPE	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUCOLLAR	/60/60	160MM DIA PIPE	35256800	20-21
PVC PIPE	WALL	192MM THICK FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUSTRAP	/240/0	50MM DIA PIPE	2600700	G
PVC PIPE	CEILING	16MM FR PLASTERBOARD CEILING	RYANFIRE SL COLLAR	/60/45.	50MM DIA PIPE	FRT 190271	A
PVC PIPE + SOCKET JOINT	CEILING	16MM FR PLASTERBOARD CEILING	RYANFIRE SL COLLAR + HP-X	/60/45	100MM DIA PIPE + SOCKET	FRT 190271	B
PVC PIPE	CEILING	16MM FR PLASTERBOARD CEILING	RYANFIRE SL COLLAR	/60/30	150MM DIA PIPE	FRT 190271	C
PVC PIPE	CEILING	16MM FR PLASTERBOARD CEILING	RYANFIRE SL COLLAR	/60/45	100MM DIA PIPE + SOCKET	FRT 190271	F
PVC PIPE	CEILING	16MM FR PLASTERBOARD CEILING	RYANFIRE SL COLLAR	/60/45	65MM DIA PIPE	FRT 190271	G
PVC PIPE	CEILING	16MM FR PLASTERBOARD CEILING	RYANFIRE SL COLLAR	/60/60	40MM DIA PIPE	FRT 190271	I
PVC PIPE	CEILING	16MM FR PLASTERBOARD CEILING	RYANFIRE SL COLLAR	/60/45	80MM DIA PIPE	FRT 190271	J
PEX PIPE	CEILING	16MM FR PLASTERBOARD CEILING	RYANFIRE SL COLLAR + HP-X	/60/60	16MM DIA PIPE	FRT 190271	H
PPR PIPE	CEILING	16MM FR PLASTERBOARD CEILING	RYANFIRE SL COLLAR + HP-X	/60/45	32MM DIA PIPE	FRT 190271	E
PPR PIPE	CEILING	16MM FR PLASTERBOARD CEILING	RYANFIRE SL COLLAR	/30/30	110MM DIA PIPE	FRT 190272	A
KELOX PIPE	CEILING	16MM FR PLASTERBOARD CEILING	RYANFIRE SL COLLAR	/45/-	32MM DIA PIPE	FRT 190272	B
PEX AL GAS PIPE	CEILING	16MM FR PLASTERBOARD CEILING	RYANFIRE SL COLLAR	/45/-	40MM DIA PIPE	FRT 190272	C
PEX AL GAS PIPE	CEILING	16MM FR PLASTERBOARD CEILING	RYANFIRE SL COLLAR + HP-X	/45/-	16MM DIA PIPE	FRT 190272	G
PEX PIPE	CEILING	16MM FR PLASTERBOARD CEILING	RYANFIRE SL COLLAR	/45/45	40MM DIA PIPE	FRT 190272	H
POLYBUTENE PIPE	CEILING	16MM FR PLASTERBOARD CEILING	RYANFIRE SL COLLAR + HP-X	/45/30	28MM DIA PIPE	FRT 190272	I
PVC PIPE	CEILINGS	26MM THICK FR PLASTERBOARD	INTUCOLLAR	/60/30	110MM DIA PIPE	35256800	22
PVC PIPE	FLOOR	90MM THICK PLT FLOOR	RYANFIRE SL COLLAR	/60/60	65MM DIA PIPE	PF 20061	C
PVC PIPE	FLOOR	90MM THICK PLT FLOOR	RYANFIRE SL COLLAR	/60/60	100MM DIA PIPE	PF 20061	D
PVC PIPE	FLOOR	90MM THICK PLT FLOOR	RYANFIRE SL COLLAR	/60/60	40MM DIA PIPE	PF 20061	E
POLYBUTYLENE PIPE	FLOOR	90MM THICK PLT FLOOR	RYANFIRE HP-X	/60/60	28MM DIA PIPE	PF 20061	F
POLYBUTYLENE PIPE	FLOOR	90MM THICK PLT FLOOR	RYANFIRE SL COLLAR	/60/60	28MM DIA PIPE	PF 20061	G
PPR PIPE	FLOOR	90MM THICK PLT FLOOR	RYANFIRE SL COLLAR	/60/60	32MM DIA PIPE	PF 20061	H

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report No.	ID/Ref
NON-INSULATED COMBUSTIBLE PIPES							
PPR PIPE	FLOOR	90MM THICK PLT FLOOR	RYANFIRE SL COLLAR	/30/30	90MM DIA PIPE	PF 20061	I
HDPE PIPE	FLOOR	90MM THICK PLT FLOOR	RYANFIRE SL COLLAR	/60/60	40MM DIA PIPE	PF 20061	J
PEX PIPE	FLOOR	90MM THICK PLT FLOOR	RYANFIRE SL COLLAR	/30/-	32MM DIA PIPE	PF 20061	M
PEX PIPE	FLOOR	90MM THICK PLT FLOOR	RYANFIRE HP-X	/30/-	32MM DIA PIPE	PF 20061	N
PEX AL GAS PIPE	FLOOR	90MM THICK PLT FLOOR	RYANFIRE HP-X	/60/-	40MM DIA PIPE	PF 20061	O
KELOX PIPE	FLOOR	90MM THICK PLT FLOOR	RYANFIRE SL COLLAR	/30/-	32MM DIA PIPE	PF 20061	T
PVC FLOOR WASTE	FLOOR	100MM THICK TIMBER INFILL	RYANFIRE SL COLLAR	/90/90	100MM DIA PIPE	PF 19059	B
PVC PIPE	FLOOR	100MM THICK TIMBER INFILL	RYANFIRE SL COLLAR	/90/90	100MM DIA PIPE	PF 19059	A
PPR PIPE	FLOOR	100MM THICK TIMBER INFILL	RYANFIRE SL COLLAR	/60/60	65MM DIA PIPE	PF 19059	C
PVC PIPE	FLOOR	100MM THICK TIMBER INFILL	RYANFIRE TD COLLAR	/120/60	100MM DIA PIPE	PF 19059	D
PVC PIPE	FLOOR	100MM THICK TIMBER INFILL	RYANFIRE SL COLLAR	/90/90	40MM DIA PIPE	PF 19060	A
PVC PIPE	FLOOR	100MM THICK TIMBER INFILL	RYANFIRE SL COLLAR	/90/90	50MM DIA PIPE	PF 19060	B
PVC PIPE	FLOOR	100MM THICK TIMBER INFILL	RYANFIRE SL COLLAR	/60/60	65MM DIA PIPE	PF 19060	C
PVC PIPE	FLOOR	100MM THICK TIMBER INFILL	RYANFIRE SL COLLAR	/60/60	80MM DIA PIPE	PF 19060	D
PVC PIPE BUNDLE	FLOOR	100MM THICK TIMBER INFILL	RYANFIRE SL COLLAR / RYANFIRE HP-X	/120/90	6X 25MM DIA PVC PIPES	PF 19060	E
PVC PIPE	FLOOR	100MM THICK STAHLTON TIMBER INFILL FLOOR	INTUBATT / SL COLLAR	/60/60	150MM DIA PIPE	51892400.2	C
PE PIPE	FLOOR	100MM THICK STAHLTON TIMBER INFILL FLOOR	INTUBATT / SL COLLAR	/30/15	150MM DIA PIPE	51892200.2	B
PVC / REHAU RAUTITAN / PEX -AL / BUTELINE PIPES	FLOOR	100MM THICK STAHLTON TIMBER INFILL FLOOR	INTUBATT / SL COLLAR / INTUMASTIC HP	/60/0	25MM DIA PVC / 2X32MM DIA REHAU / 50MM DIA PVC / 22MM DIA BUTE	51892200.2	D
DBLUE PVC	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE TD COLLAR	/120/-	110MM DIA PIPE	FRT 190286	A
PVC PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE TD COLLAR	/120/90	65MM DIA PIPE	FRT 190286	B
PVC PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE TD COLLAR	/120/90	40MM DIA PIPE	FRT 190286	C
PVC PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE TD COLLAR	/120/90	80MM DIA PIPE	FRT 190286	D
PVC PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE TD COLLAR	/120/-	150MM DIA PIPE	FRT 190286	E
PVC PIPE + SOCKET JOINT	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE TD COLLAR	/120/90	100MM DIA PIPE + SOCKET	FRT 190286	G
PVC PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE TD COLLAR	/120/60	50MM DIA PIPE	FRT 190286	H
PVC PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE TD COLLAR	/120/60	100MM DIA PIPE	FRT 190286	J
PPR PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE TD COLLAR	/120/90	32MM DIA PIPE	FRT 190286	F
PPR PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE TD COLLAR	/30/30	160MM DIA PIPE	FRT 190287	G
PEX PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE TD COLLAR / RYANFIRE HPX	/120/90	16MM DIA PIPE	FRT 190286	I
PEX PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE TD COLLAR	/120/-	40MM DIA PIPE	FRT 190287	C
KELOX PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE TD COLLAR	/120/60	16MM DIA PIPE	FRT 190287	A
KELOX PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE TD COLLAR	/90/-	30MM DIA PIPE	FRT 190287	B
PEX AL GAS PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE TD COLLAR	/120/90	16MM DIA PIPE	FRT 190287	D
BUTELINE PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE TD COLLAR	/120/90	28MM DIA PIPE	FRT 190287	F
PEX AL GAS PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE TD COLLAR	/120/-	40MM DIA PIPE	FRT 190287	H
PVC PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR	/120/-	150MM DIA PIPE	FRT 190284	A
PVC PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR	/120/60	40MM DIA PIPE	FRT 190284	C
PVC PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR	/120/120	100MM DIA PIPE	FRT 190284	E

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report No.	ID/Ref
NON-INSULATED COMBUSTIBLE PIPES							
PVC PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR	/120/90	50MM DIA PIPE	FRT 190284	F
PVC PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR	/60/60	80MM DIA PIPE	FRT 190284	G
PVC PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR	/30/30	65MM DIA PIPE	FRT 190284	H
FLOOR WASTE SYSTEM	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR	/120/	100MM DIA PIPE	FRT 190284	I
PPR PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR	/120/90	32MM DIA PIPE	FRT 190284	B
PEX PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR	/120/90	16MM DIA PIPE	FRT 190284	D
PEX PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR	/30/15	40MM DIA PIPE	FRT 190285	B
KELOX PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR / RYANFIRE HP-X	/120/90	16MM DIA PIPE	FRT 190285	C
PEX PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR / RYANFIRE HP-X	/120/90	16MM DIA PIPE	FRT 190285	D
POLYBUTENE PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR	/120/15	28MM DIA PIPE	FRT 190285	F
PEX AL GAS PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR	/60/15	40MM DIA PIPE	FRT 190285	G
KELOX PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR	/60/15	32MM DIA PIPE	FRT 190285	H
PVC PIPE + SOCKET JOINT	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR	/120/120	100MM DIA PIPE + SOCKET	FRT 190285	I
PVC PIPE	FLOOR	120MM THICK WOODTEX FLOOR	RYANFIRE 502 BOARD / RYANFIRE STRAP	/60/60	40MM DIA PIPE	PF 20106	A
PVC PIPE	FLOOR	120MM THICK WOODTEX FLOOR	RYANFIRE 502 BOARD / RYANFIRE STRAP	/60/60	100MM DIA PIPE	PF 20106	B
KELOX PIPE	FLOOR	120MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR	/120/90	16MM DIA PIPE	PF 20091	C
PEX PIPE	FLOOR	120MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR	/120/120	16MM DIA PIPE	PF 20091	E
PEX AL GAS PIPE	FLOOR	120MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR	/120/120	16MM DIA PIPE	PF 20091	F
PPR PIPE	FLOOR	120MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR	/120/120	16MM DIA PIPE	PF 20091	G
POLYBUTYLENE PIPE	FLOOR	120MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR	/120/120	16MM DIA PIPE	PF 20091	H
DBLUE (MDPE) PIPE	FLOOR	120MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR	/120/120	20MM DIA PIPE	PF 20091	I
PVC PIPE	FLOOR	120MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR	/120/120	20MM DIA PIPE	PF 20091	K
PEX	FLOOR	120MM THICK CONCRETE FLOOR	RYANFIRE HP-X	/120/120	16MM DIA PIPE	PF 20097	A
PEX	FLOOR	120MM THICK CONCRETE FLOOR	RYANFIRE HP-X	/120/-	32MM DIA PIPE	PF 20097	B
PEX AL GAS PIPE	FLOOR	120MM THICK CONCRETE FLOOR	RYANFIRE HP-X	/120/60	16MM DIA PIPE	PF 20097	C
PEX AL GAS PIPE	FLOOR	120MM THICK CONCRETE FLOOR	RYANFIRE HP-X	/120/30	32MM DIA PIPE	PF 20097	D
PEX BUNDLE	FLOOR	120MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR + HP-X	/120/120	4X 25MM DIA PIPES	PF 20097	G
PVC PIPE	FLOOR	120MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR	/120/120	65MM DIA PIPE	PF 20097	I
HDPE PIPE	FLOOR	120MM THICK CONCRETE FLOOR	INTUBATT / INTUSTRAP / INTUMASTIC	/180/180	40MM DIA PIPE	2600703.2A	C
HDPE PIPE	FLOOR	120MM THICK CONCRETE FLOOR	INTUBATT / INTUSLEEVE	/120/120	112MM DIA PIPE	35319300	11
PVC PIPE	FLOOR	120MM THICK CONCRETE FLOOR	INTUBATT / INTUSLEEVE	/90/90	110MM DIA PIPE	35319300	12
PVC PIPE	FLOOR	120MM THICK CONCRETE FLOOR	INTUBATT / INTUSLEEVE	/120/120	69MM DIA PIPE	35319300	13
PVC PIPE	FLOOR	120MM THICK CONCRETE FLOOR	INTUCOLLAR GV	/120/120	100MM DIA PIPE	FAR 4035	G
PVC PIPE	FLOOR	COMPOSITE FLOORING - 65MM THICK CONCRETE	INTUBATT / SL COLLAR	/90/60	160MM DIA PIPE	46812300.1	1
HDPE PIPE	FLOOR	COMPOSITE FLOORING - 65MM THICK CONCRETE	INTUBATT / SL COLLAR	/120/120	160MM DIA PIPE	46812300.1	2
DBLUE ACOUSTIC PIPE	FLOOR	COMPOSITE FLOORING - 65MM THICK CONCRETE	INTUBATT / SL COLLAR	/120/120	160MM DIA PIPE	46812300.1	3
PPR-CT PIPE	FLOOR	COMPOSITE FLOORING - 65MM THICK CONCRETE	INTUBATT / SL COLLAR	/30/30	125MM DIA PIPE	46812300.1	4
PVC PIPE	FLOOR	COMPOSITE FLOORING - 65MM THICK CONCRETE	INTUBATT / INTUSTRAP	/60/-	110MM DIA PIPE	FAS 19047	7

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report No.	ID/Ref
NON-INSULATED COMBUSTIBLE PIPES							
PVC PIPE	FLOOR	COMPOSITE FLOORING - 65MM THICK CONCRETE	INTUSLEEVE	/60/-	160MM DIA PIPE	FAS 19047	1
HDPE PIPE	FLOOR	COMPOSITE FLOORING - 65MM THICK CONCRETE	INTUSLEEVE	/60/-	160MM DIA PIPE	FAS 19047	2
DBLUE ACOUSTIC PIPE	FLOOR	COMPOSITE FLOORING - 65MM THICK CONCRETE	INTUSLEEVE	/60/-	160MM DIA PIPE	FAS 19047	3
PPR-CT PIPE	FLOOR	COMPOSITE FLOORING - 65MM THICK CONCRETE	INTUSLEEVE	/60/-	110MM DIA PIPE	FAS 19047	8
KELOX	FLOOR	130MM THICK COMPOSITE FLOOR (COMFLOR)	RYANFIRE HPX	/60/-	32MM DIA PIPE	PF 19011	5
PPR PIPE	FLOOR	130MM THICK COMPOSITE FLOOR (COMFLOR)	RYANFIRE TD COLLAR	/60/60	75MM DIA PIPE	PF 19011	6
PVC PIPE	FLOOR	120MM THICK COMPOSITE FLOOR (COMFLOR)	RYANFIRE TD COLLAR	/120/-	150MM DIA PIPE	PF 19070	A
PVC PIPE	FLOOR	120MM THICK COMPOSITE FLOOR (COMFLOR)	RYANFIRE TD COLLAR	/120/60	40MM DIA PIPE	PF 19070	B
PVC PIPE	FLOOR	120MM THICK COMPOSITE FLOOR (COMFLOR)	RYANFIRE TD COLLAR	/120/30	50MM DIA PIPE	PF 19070	C
PVC PIPE	FLOOR	120MM THICK COMPOSITE FLOOR (COMFLOR)	RYANFIRE TD COLLAR	/120/60	100MM DIA PIPE	PF 19070	D
HDPE PIPE	FLOOR	120MM THICK COMPOSITE FLOOR (COMFLOR)	RYANFIRE TD COLLAR	/120/30	40MM DIA PIPE	PF 19070	E
RAUPIANO PLUS PIPE	FLOOR	120MM THICK COMPOSITE FLOOR (COMFLOR)	RYANFIRE TD COLLAR	/120/30	40MM DIA PIPE	PF 19070	F
PVC PIPE	FLOOR	120MM THICK COMPOSITE FLOOR (COMFLOR)	RYANFIRE TD COLLAR	/120/30	65MM DIA PIPE	PF 19071	A
PVC PIPE	FLOOR	120MM THICK COMPOSITE FLOOR (COMFLOR)	RYANFIRE TD COLLAR	/120/-	80MM DIA PIPE	PF 19071	B
PVC PIPE + SOCKET JOINT	FLOOR	120MM THICK COMPOSITE FLOOR (COMFLOR)	RYANFIRE TD COLLAR	/120/30	100MM DIA PIPE + SOCKET	PF 19071	C
RAUPIANO PLUS PIPE	FLOOR	120MM THICK COMPOSITE FLOOR (COMFLOR)	RYANFIRE TD COLLAR	/120/-	150MM DIA PIPE	PF 19071	D
PPR PIPE	FLOOR	120MM THICK COMPOSITE FLOOR (COMFLOR)	RYANFIRE TD COLLAR	/120/30	90MM DIA PIPE	PF 19071	E
PEX PIPE	FLOOR	120MM THICK COMPOSITE FLOOR (COMFLOR)	RYANFIRE TD COLLAR	/120/60	16MM DIA PIPE	PF 19071	F
HDPE PIPE	FLOOR	120MM THICK COMPOSITE FLOOR (COMFLOR)	RYANFIRE TD COLLAR	/120/30	150MM DIA PIPE	PF 19072	A
DBLUE PIPE	FLOOR	120MM THICK COMPOSITE FLOOR (COMFLOR)	RYANFIRE TD COLLAR	/120/-	150MM DIA PIPE	PF 19072	B
DBLUE PIPE	FLOOR	120MM THICK COMPOSITE FLOOR (COMFLOR)	RYANFIRE TD COLLAR	/120/60	50MM DIA PIPE	PF 19072	C
PEX PIPE	FLOOR	120MM THICK COMPOSITE FLOOR (COMFLOR)	RYANFIRE TD COLLAR	/60/30	40MM DIA PIPE	PF 19072	D
PEX AL GAS PIPE	FLOOR	120MM THICK COMPOSITE FLOOR (COMFLOR)	RYANFIRE TD COLLAR	/60/30	40MM DIA PIPE	PF 19072	E
POLYBUTYLENE PIPE	FLOOR	120MM THICK COMPOSITE FLOOR (COMFLOR)	RYANFIRE TD COLLAR	/120/60	28MM DIA PIPE	PF 19072	F
PVC PIPE	FLOOR	140X45MM UNLINED TIMBER FRAME	RYANFIRE 502 BOARD / RYANFIRE STRAP	/60/30	40MM DIA PIPE	PF 19047	D
PVC PIPE	FLOOR	140X45MM UNLINED TIMBER FRAME	RYANFIRE 502 BOARD / RYANFIRE STRAP	/60/60	40MM DIA PIPE	PF 19037	B
POLYBUTYLENE PIPE	FLOOR	140X45MM UNLINED TIMBER FRAME	RYANFIRE 502 BOARD / RYANFIRE STRAP	/60/30	25MM DIA PIPE	PF 19037	E
POLYBUTYLENE PIPE	FLOOR	140X45MM UNLINED TIMBER FRAME	RYANFIRE 502 BOARD / RYANFIRE STRAP	/60/60	25MM DIA PIPE	PF 19047	B
PVC PIPE	FLOOR	150MM THICK CONCRETE	RYANFIRE TD COLLAR	/120/120	100MM DIA PIPE	FRT 200018	A
PVC PIPE	FLOOR	150MM THICK CONCRETE	RYANFIRE TD COLLAR	/120/120	50MM DIA PIPE	FRT 200018	D
PVC PIPE + SOCKET JOINT	FLOOR	150MM THICK CONCRETE	RYANFIRE TD COLLAR	/120/120	80MM DIA PIPE + SOCKET	FRT 200018	H
PPR PIPE	FLOOR	150MM THICK CONCRETE	RYANFIRE TD COLLAR	/120/120	75MM DIA PIPE	FRT 200018	B
POLYBUTYLENE	FLOOR	150MM THICK CONCRETE	RYANFIRE TD COLLAR	/120/120	28MM DIA PIPE	FRT 200018	C
HDPE PIPE	FLOOR	150MM THICK CONCRETE	RYANFIRE TD COLLAR	/120/120	70MM DIA PIPE	FRT 200018	E
PP/PP-MD/PP PIPE	FLOOR	150MM THICK CONCRETE	RYANFIRE TD COLLAR	/120/120	100MM DIA PIPE	FRT 200018	F
HDPE PIPE	FLOOR	150MM THICK CONCRETE	INTUBATT (SINGLE LAYER) / INTUSTRAP / INTUMASTIC	/60/60	55MM DIA PIPE	35319300	9
HDPE PIPE	FLOOR	150MM THICK CONCRETE	INTUCOLLAR	/90/90	160MM DIA PIPE	35256800	23

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report No.	ID/Ref
NON-INSULATED COMBUSTIBLE PIPES							
HDPE PIPE	FLOOR	150MM THICK CONCRETE	INTUCOLLAR	/120/120	110MM DIA PIPE	35256800	24 - 26
PPR PIPE	FLOOR	150MM THICK CONCRETE	INTUCOLLAR	/120/120	75MM DIA PIPE	35256800	27
ABS PIPE	FLOOR	150MM THICK CONCRETE	INTUCOLLAR	/120/120	90MM DIA PIPE	35256800	28
PVC PIPE	FLOOR	150MM THICK CONCRETE	INTUCOLLAR GV	/180/180	100MM DIA PIPE	FAR 4035	G
PVC PIPE	FLOOR	150MM THICK CONCRETE	INTUCOLLAR	/120/120	160MM DIA PIPE	35256800	29-32
PVC PIPE	FLOOR	150MM THICK CONCRETE	INTUCOMPOUND / INTUSTRAP	/240/180	160MM DIA PIPE	35256800	33-36
PPR PIPE	FLOOR	150MM THICK CONCRETE	INTUCOMPOUND / INTUSLEEVE	/240/180	90MM DIA PIPE	35256800	37
HDPE PIPE	FLOOR	150MM THICK CONCRETE	INTUCOMPOUND / INTUSLEEVE	/240/180	82MM DIA PIPE	35256800	38
PVC PIPE	FLOOR	150MM THICK CONCRETE	INTUCOMPOUND / INTUSLEEVE	/240/180	160MM DIA PIPE	35256800	39-42
HDPE PIPE	FLOOR	150MM THICK CONCRETE	INTUCOMPOUND / INTUSLEEVE	/240/240	82MM DIA PIPE	35084000.2	22
PVC PIPE	FLOOR	150MM THICK CONCRETE	INTUCOMPOUND / INTUSLEEVE	/240/240	160MM DIA PIPE	35084000.2	23
PVC PIPE	FLOOR	150MM THICK CONCRETE	INTUBATT (DOUBLE LAYER) / INTUSTRAP / INTUMASTIC	/60/60	110MM DIA PIPE	35319300	10
PVC PIPE	FLOOR	170MM THICK CONCRETE	INTUCOLLAR GV	/240/240	100MM DIA PIPE	FAR 4035	G
PVC PIPE	FLOOR	175MM THICK CONCRETE	INTUCOMPOUND / INTUSTRAP	/240/240	160MM DIA PIPE	35256800	33-36
PPR PIPE	FLOOR	175MM THICK CONCRETE	INTUCOMPOUND / INTUSLEEVE	/240/240	90MM DIA PIPE	35256800	37
HDPE PIPE	FLOOR	175MM THICK CONCRETE	INTUCOMPOUND / INTUSLEEVE	/240/240	82MM DIA PIPE	35256800	38
PVC PIPE	FLOOR	175MM THICK CONCRETE	INTUCOMPOUND / INTUSLEEVE	/240/240	160MM DIA PIPE	35256800	39-42
INSULATED COMBUSTIBLE PIPES							
KELOX / 13MM THICK PE INSULATION	WALL	90MM THICK FR PLASTERBOARD WALL / MASONRY / CONCRETE	RYANFIRE SL COLLAR	/60/30	25MM DIA PIPE	PF 19061	A
KELOX / 13MM THICK PE INSULATION	WALL	90MM THICK FR PLASTERBOARD WALL / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE STRAP	/60/60	25MM DIA PIPE	PF 19061	B
KELOX / 13MM THICK PE INSULATION	WALL	90MM THICK FR PLASTERBOARD WALL / MASONRY / CONCRETE	RYANFIRE SL COLLAR	/60/30	32MM DIA PIPE	PF 19061	C
KELOX / 13MM THICK PE INSULATION	WALL	90MM THICK FR PLASTERBOARD WALL / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE STRAP	/60/60	32MM DIA PIPE	PF 19061	D
PPR PIPE / 38MM THICK ARMAFLEX	WALL	116MM THICK FR PLASTERBOARD/MASONRY/CONCRETE	RYANFIRE SL COLLAR	/90/60	90MM DIA PIPE	51892000.2	A
PP-R / 32MM THICK ARMAFLEX	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE FS COLLAR	/45/45	90MM DIA PIPE	FRT 190079	K
PP-R / 32MM THICK ARMAFLEX	WALL	126MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE SL COLLAR	/60/60	90MM DIA PIPE	PF 19010	12
PPR PIPE / 38MM THICK ARMAFLEX	FLOOR	100MM THICK STAHLTON TIMBER INFILL FLOOR	INTUBATT / SL COLLAR / INTUMASTIC HP	/90/90	75MM DIA PIPE	51892200.2	C
PPR PIPE - 32MM NITRILE RUBBER INSULATION	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE TD COLLAR	/120/60	90MM DIA PIPE +32MM THICK INSULATION	FRT 190287	E
KELOX - POLYETHYLENE INSULATION	FLOOR	130MM THICK COMPOSITE FLOOR (COMFLOR)	RYANFIRE HPX	/60/30	32MM DIA PIPE + 13MM THICK INSULATION	PF 19011	4

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report No.	ID/Ref
INSULATED COMBUSTIBLE PIPES							
PVC PIPE / 25MM THICK ARMAFLEX	FLOOR	150MM THICK CONCRETE FLOOR	INTUCOLLAR	/120/120	110MM DIA PIPE	35256800	44
PVC PIPE / 30MM THICK ARMAFLEX	FLOOR	150MM THICK CONCRETE FLOOR	INTUCOLLAR	/120/120	21.5MM DIA PIPE	35256800	43
POLYETHYLENE PIPE / 55MM FIBREGLASS	FLOOR	150MM THICK CONCRETE FLOOR	INTUSTRAP	/120/120	15MM DIA PIPE	35256800	45
ELECTRICAL PENETRATION SERVICES							
CABLE BUNDLE	WALL	KOROC 51 - 60 MIN INSULATION WALL SYSTEM	RYANFIRE SL COLLAR / INTUMASTIC HP	/90/60	30 X TPS / 25 X CAT 6 / 10 X 50PR COMMS CABLES	FP 10847.002	4
ELECTRICAL FLUSH BOX	WALL	90MM THICK STANDARD PLASTERBOARD WALL	RYANFIRE POWER PAD	/30/30	94X54X50MM FLUSH BOX	PF 20040	C
ELECTRICAL FLUSH BOX	WALL	90X45MM UNLINED TIMBER FRAMED WALL	RYANFIRE 802 BOARD	/60/60	94X54X50MM FLUSH BOX	PF 20007	E
CABLE BUNDLE	WALL	90X45MM UNLINED TIMBER FRAMED WALL	RYANFIRE 802 BOARD	/60/30	70MM DIA BUNDLE	PF 20007	C
CABLE BUNDLE - ONE SIDED PENETRATION	WALL	90MM THICK INSULATED FR PLASTERBOARD WALL	RYANFIRE HPX	/90/60	30MM DIA BUNDLE	PF 19025	D
CABLE BUNDLE	WALL	90MM THICK STANDARD PLASTERBOARD WALL	RYANFIRE HP-X	/30/30	13X MIXED CABLES	PF 20040	D
CABLE BUNDLE	WALL	90MM THICK STANDARD PLASTERBOARD WALL	RYANFIRE SL COLLAR	/30/31	13X MIXED CABLES	PF 20040	E
TPS CABLE BUNDLE	WALL	90MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE SL COLLAR	/60/45	15 X TPS CALBES	FRT 190252	D
TPS CABLE BUNDLE	WALL	90MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE MASTIC CONE	/60/45	15 X TPS CALBES	FRT 190252	E
CAT 6 CABLE BUNDLE	WALL	90MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE MASTIC CONE	/60/45	20X CAT 6 CABLES	FRT 190252	F
TPS CABLE BUNDLE	WALL	90MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE MASTIC CONE	/60/45	7X TPS CABLES	FRT 190252	G
OPTICAL CABLE BUNDLE	WALL	90MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE MASTIC CONE	/60/45	17X OPTICAL CABLES	FRT 190252	H
SINGLE TPS CABLE	WALL	90MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE MASTIC CONE	/60/45	1X TPS	FRT 190252	I
PVC CONDUIT	WALL	90MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE SL COLLAR	/60/45	50MM DIA CONDUIT	FRT 190252	C
PVC CONDUIT	WALL	90MM THICK INSULATED FR PLASTERBOARD WALL	RYANFIRE SL COLLAR	/60/60	50MM DIA CONDUIT	PF 20067	A
PVC CONDUIT	WALL	90MM THICK INSULATED FR PLASTERBOARD WALL	RYANFIRE SL COLLAR (INVERTED)	/60/60	20MM DIA CONDUIT	PF 20067	B
PVC CONDUIT	WALL	90MM THICK INSULATED FR PLASTERBOARD WALL	RYANFIRE SL COLLAR	/60/30	20MM DIA CONDUIT (NO CABLES)	PF 20067	C
PVC CONDUIT	WALL	90MM THICK INSULATED FR PLASTERBOARD WALL	RYANFIRE SL COLLAR	/60/60	20MM DIA CONDUIT	PF 20067	E
PVC CONDUIT	WALL	90MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE SL COLLAR / HPX	/60/45	14NO CONDUITS	FRT 190252	A
CABLE BUNDLE	WALL	90MM THICK INSULATED FR PLASTERBOARD WALL	RYANFIRE SL COLLAR	60/60	25MM DIA CABLE BUNDLE	PF 20067	K
ELECTRICAL FLUSH BOX	WALL	90MM THICK INSULATED FR PLASTERBOARD WALL	RYANFIRE POWER PAD	/90/60	95X55MM FLUSH BOX	PF 19025	F
CABLE TRUNKING	WALL	100MM THICK FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUMASTIC / INTUPILLOW PRO	/120/120	CABLES - 10% FILL	35084000.2	65
CABLE TRUNKING	WALL	100MM THICK FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUMASTIC / INTUPILLOW PRO	/120/120	CABLES - 75% FILL	35084000.2	66
CABLE TRUNKING	WALL	100MM THICK FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUMASTIC / INTUPILLOW PRO	/120/120	CABLES - 45% FILL	35084000.2	67
CABLE TRUNKING	WALL	100MM THICK FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUMASTIC / INTUPILLOW PRO	/120/120	CABLES - 75% FILL	35084000.2	68

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report No.	ID/Ref
ELECTRICAL PENETRATION SERVICES							
ELECTRICAL FLUSH BOX	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE POWER PAD	/60/30	95X55MM FLUSH BOX	56662701	A
CABLE BUNDLE	WALL	116MM THICK INSULATION FR PLASTERBOARD WALL	RYANFIRE 502 BOARD	/120/120	30MM DIA CABLE BUNDLE DATA	PF 20096	A
MAINS CABLE	WALL	116MM THICK INSULATION FR PLASTERBOARD WALL	RYANFIRE 502 BOARD	/60/30	20MM DIA CABLE	PF 20096	B
CABLE BUNDLE	WALL	116MM THICK INSULATION FR PLASTERBOARD WALL	RYANFIRE 502 BOARD	/120/60	30MM DIA CABLE BUNDLE POWER	PF 20096	C
AS1530.4 APPENDIX D1	WALL	116MM THICK INSULATION FR PLASTERBOARD WALL	RYANFIRE 502 BOARD + SERVOWRAP	/120/120	D2	PF 20099	B
AS1530.4 APPENDIX D2	WALL	116MM THICK INSULATION FR PLASTERBOARD WALL	RYANFIRE 502 BOARD + SERVOWRAP	/120/120	D1	PF 21005	D
CABLE BUNDLE	WALL	116MM THICK INSULATION FR PLASTERBOARD WALL	RYANFIRE HP-X	/120/120	17NO CAT6	PF 20094	A
CABLE BUNDLE	WALL	116MM THICK INSULATION FR PLASTERBOARD WALL	RYANFIRE HP-X	/120/60	16NO TPS	PF 20094	B
PVC CONDUIT	WALL	116MM THICK INSULATION FR PLASTERBOARD WALL	RYANFIRE HP-X	/120/120	25MM DIA CONDUIT	PF 20094	D
PVC CONDUIT	WALL	116MM THICK INSULATION FR PLASTERBOARD WALL	RYANFIRE HP-X	/120/120	50MM DIA CONDUIT	PF 20094	C
PVC CONDUIT	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE FS COLLAR / RYANFIRE HPX	/120/60	32MM DIA	FRT 190079	H
PVC CONDUIT	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / RYANFIRE FS COLLAR / RYANFIRE HPX	/120/60	50MM DIA	FRT 190079	M
CABLE	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE HPX	/120/60	TPS - 2.5MM2 2C+E CABLE	FRT 190080	A
CABLE BUNDLE	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE HPX	/120/60	16X TPS -2.5MM2 2C+E CABLES	FRT 190080	B
MEDIUM DUTY ELECTRICAL CONDUIT	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE HPX	/90/30	50MM DIA	FRT 190080	K
MEDIUM DUTY ELECTRICAL CONDUIT	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE FS COLLAR	/120/120	32MM DIA	FRT 190080	R
OPTICAL CABLE BUNDLE	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE HPX	/60/60	30MM DIA BUNDLE	56662701	B
CABLE BUNDLE - TPS/ COMMS/DATA	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	SL COLLAR / INTUMASTIC HP	/120/90	25 X TPS / 50XCAT 6 / 50 COMMS CABLES	51892000.2	J
CABLE BUNDLE	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUMASTIC HP	/90/30	5 X TPS CABLES	51028300.1	H
CABLE BUNDLE	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	RYANFIRE HP-X	/60/60	8 MIXED OPTICAL CABLES	56662701.1	B
ELECTRICAL SOCKET BOX	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	RYANFIRE PUTTY PAD	/90/60	TESTED BOTH SIDES WALL	51028300.1	A / B
ELECTRICAL SOCKET BOX	WALL	116MM FR PLASTERBOARD/MASONRY/CONCRETE WALL	RYANFIRE PUTTY PAD	/120/120	TESTED BOTH SIDES WALL - COMPLETE WITH CABLES	51892000.2	D
CABLE BUNDLE	WALL	120MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUMASTIC HP	/60/60	4 CABLES	34084000.2	27
CABLE BUNDLE	WALL	120MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT	/60/60	4 CABLES	34084000.2	24
CABLE TRAY	WALL	120MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUMASTIC HP	/60/60	4X21MM DIA & 1X23MM DIA	34084000.2	28
CABLE - SINGLE	WALL	120MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUMASTIC HP	/60/60	1 X COAX CABLE	34084000.2	26

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report No.	ID/Ref
ELECTRICAL PENETRATION SERVICES							
CABLE TRAY	WALL	120MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUMASTIC	/60/60	4X21MM DIA & 1X23MM DIA	34084000.2	25
AS1530.4 APPEND IX D - D1	WALL	126MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD	/60/60	D1	PF 19010	15
OPTICAL CABLE BUNDLE	WALL	126MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD	/60/60	80MM DIA BUNDLE	PF 19010	21
AS1530.4 APPEND IX D - D2	WALL	126MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD	/60/60	D2	PF 19010	14
CABLE LADDER	WALL	128MM THICK PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUMASTIC / SLEEVE	/120/120	D1 & D2 CABLE CONFIGURATION	35084000.2	42/43
CABLE LADDER	WALL	128MM THICK FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUMASTIC / SLEEVE	/240/180	D1 & D2 CABLE CONFIGURATION	35084000.2	42/43
CABLE CONDUIT - 22MM DIA	WALL	130MM THICK FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUMASTIC HP	/120/120	2 CABLES	35084000.2	33
CABLE CONDUIT - 55MM DIA	WALL	130MM THICK FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUMASTIC HP	/120/120	4 X CABLES	35084000.2	34
CABLE TRAY / LADDER	WALL	130MM THICK FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUMASTIC	/120/120	4 CABLE TRAYS - 48 CABLES + 100MM DIA BUNDLE	35084000.2	35
CABLE BUNDLE - OPTICAL	WALL	130MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUMASTIC	/60/60	21 CABLES	34084000.2	63
CABLE BUNDLE - OPTICAL	WALL	130MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUMASTIC	/60/60	12 CABLES	34084000.2	64
CABLE TRANSIT	WALL	130MM THICK FR PLASTERBOARD / MASONRY / CONCRETE WALL	FIRETHERM CABLE TRANSIT	/120/120	CABLE TRAY / VARIOUS CABLES	35084000.2	41
CABLE TRANSIT	WALL	130MM THICK FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUMASTIC / FIRETHERM CABLE TRANSIT	/120/90	19 CABLES + CABLE CONDUIT + 2XPVC PIPES	35084000.2	40
CABLE BUNDLE	WALL	130MM THICK FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUMASTIC	/120/120	12 X OPTICAL CABLES	35084000.2	64
CABLE BUNDLE	WALL	130MM THICK FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUMASTIC	/120/120	21 CABLES	35084000.2	63
ELECTRICAL FLUSH BOX	WALL	140X45MM UNLINED TIMBER FRAMED WALL	RYANFIRE 502 BOARD	/120/120	95X55MM FLUSH BOX	PF 19039	C
CABLE BUNDLE - ONE SIDED PENETRATION	WALL	140X45MM UNLINED TIMBER FRAMED WALL	RYANFIRE 502 BOARD	/120/119	30MM DIA BUNDLE (DATA)	PF 19039	F
CABLE BUNDLE - ONE SIDED PENETRATION	WALL	140X45MM UNLINED TIMBER FRAMED WALL	RYANFIRE 502 BOARD	/120/120	30MM DIA BUNDLE (POWER)	PF 19039	B
CABLE BUNDLE	WALL	140X45MM UNLINED TIMBER FRAMED WALL	RYANFIRE 502 BOARD	/90/60	17NO TPS - 44MM DIA	PF 19031	B
CABLE CONDUIT - 82MM DIA	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUCOLLAR	/120/120	65 CABLES	35256800	48
CABLE CONDUITS X2 X 63MM DIA PLUS BUNDLE	WALL	142MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUMASTIC HP	/120/30	2 CABLES PLUS CABLE BUNDLE	52208000.1	20
CABLE LADDER / CABLE TRAY / BUNDLE	WALL	142MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUMASTIC HP	/120/90	8 CABLES	52208000.1	19
CABLE LADDER / CABLE TRAY / BUNDLE	WALL	142MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUMASTIC HP	/120/90	36 CABLES PLUS 40MM DIA BUNDLE	52208000.1	17
CABLE TRAY	WALL	142MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUMASTIC HP	/120/90	5 X POWER CABLES	52208000.1	18
CABLE BUNDLE	WALL	142MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUMASTIC	/120/120	70MM DIA BUNDLE	52208000.1	10
CABLE CONDUIT - 82MM DIA	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUSTRAP / INTUMASTIC	/120/120	65 CABLES	35256800	49
CABLE CONDUITS - ONLY HAVE TREATED	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUSTRAP	/120/120	12 CABLES	35319300	14
CABLE CONDUITS - TOUCHING	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUSTRAP	/120/120	12 CABLES	35319300	15
CABLE CONDUIT - 55MM DIA	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUMASTIC HP	/120/120	20MM DIA BUNDLE	35319300	16

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report No.	ID/Ref
ELECTRICAL PENETRATION SERVICES							
CABLE CONDUIT - 55MM DIA	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUSTRAP	/60/60	6 X TPS / ALARM CABLES	35319300	17
CABLE CONDUIT - 55MM DIA	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUSTRAP	/60/60	7 X TPS CABLES	35319300	18
CABLE TRAY	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUMASTIC	/120/120	16 CABLES	35256800	50
CABLE TRAY OR CABLE BUNDLE	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUMASTIC	/120/120	80MM DIA + 61MM DIA + CABLE BUNDLE	35319300	19
CABLE TRAY OR CABLE BUNDLE	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUMASTIC / INTUMASTIC HP	/120/120	80MM DIA + 61MM DIA + CABLE BUNDLE	35319300	20
CABLE BUNDLES - 3 NUMBER	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUMASTIC	/60/60	30MM DIA + 30MM DIA + 40MM DIA BUNDLE	35319300	21
CABLE BUNDLE	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUMASTIC	/120/120	20 DATA CABLES + 5 TPS	35319300	22
CABLE BUNDLE	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUMASTIC / INTUMASTIC HP	/120/120	6 CABLES	35319300	23
CABLE BUNDLE X 2	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUMASTIC	/60/60	30MM DIA COAX + 35MM DIA FIRE ALARM	35319300	24
CABLE - SINGLE	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUMASTIC	/120/120	1 X TPS CABLE	35319300	25
CABLE - SINGLE	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUMASTIC	/120/120	1 X OPTICAL CABLE	35319300	26
CABLE - SINGLE	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUMASTIC	/120/120	1 X COAX CABLE	35319300	27
CABLE - SINGLE	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUMASTIC	/120/90	1 X 21MM DIA CABLE	35319300	28
CABLE TRANSIT	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	FIRETHERM CABLE TRANSIT	/120/60	140 CABLES	35319300	30
CABLE TRANSIT - CIRCULAR	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	FIRETHERM CABLE TRANSIT - 200MM DIA	/120/120	16 X CONDUITS EACH FILLED WITH CABLES	35319300	31
CABLE TRAY	WALL	150MM THICK MASONRY / CONCRETE WALL	INTUCOMPOUND	/180/60	52MM DIA CABLE	35084000.2	69
CABLE TRAY	WALL	150MM THICK MASONRY / CONCRETE WALL	INTUCOMPOUND	/240/60	2 X 27MM DIA CABLES	35084000.2	70
CABLE TRAY	WALL	150MM THICK MASONRY / CONCRETE WALL	INTUCOMPOUND	/120/90	1 X 80MM DIA CABLE	35084000.2	71
CABLE TRAY	WALL	150MM THICK MASONRY / CONCRETE WALL	INTUCOMPOUND	/240/90	1 X 62MM DIA CABLE	35084000.2	72
CABLE TRAY	WALL	150MM THICK MASONRY / CONCRETE WALL	INTUCOMPOUND	/180/120	10 X 14MM DIA CABLES	35084000.2	73
CABLE TRAY	WALL	150MM THICK MASONRY / CONCRETE WALL	INTUCOMPOUND	/90/90	1 X 100MM DIA CABLE BUNDLE	35084000.2	82
CABLE TRAY	WALL	150MM THICK MASONRY / CONCRETE WALL	INTUCOMPOUND	/240/120	10 X 13MM DIA CABLES	35084000.2	75
CABLE TRAY	WALL	150MM THICK MASONRY / CONCRETE WALL	INTUCOMPOUND	/180/90	10 CABLES	35084000.2	74
CABLE TRAY	WALL	150MM THICK MASONRY / CONCRETE WALL	INTUCOMPOUND	/240/120	2 X 21MM DIA CABLES	35084000.2	76
CABLE TRAY	WALL	150MM THICK MASONRY / CONCRETE WALL	INTUCOMPOUND	/240/90	3 X 61MM DIA CABLES	35084000.2	78
2X TPS CABLES	CEILING	16MM FR PLASTERBOARD CEILING	RYANFIRE HP-X	/60/60	2X CABLES	FRT 190271	D
CABLE BUNDLE	CEILING	16MM FR PLASTERBOARD CEILING	RYANFIRE SL COLLAR + HP-X	/45/45	100MM DIA BUNDLE APPROX	FRT 190272	E
CABLE BUNDLE	CEILING	16MM FR PLASTERBOARD CEILING	RYANFIRE HP-X	/45/45	2X TPS, 1X SPEACKER CABLE	FRT 190272	F
CABLE BUNDLE	CEILINGS	26MM THICK FR PLASTERBOARD	INTUMASTIC HP	/60/30	6 X TPS CABLES	35256800	51
CABLE BUNDLE	CEILINGS	26MM THICK FR PLASTERBOARD	INTUMASTIC HP	/60/30	12 CABLES	35256800	52

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report No.	ID/Ref
ELECTRICAL PENETRATION SERVICES							
CABLE BUNDLE	FLOOR	90MM THICK PLT FLOOR	RYANFIRE HP-X	/60/30	30MM DIA CABLE BUNDLE	PF 20061	Q
CABLE BUNDLE + CONDUIT	FLOOR	90MM THICK PLT FLOOR	RYANFIRE SL COLLAR	/30/30	100MM DIA CABLE BUNDLE	PF 20061	R
CABLE TRAY / CONDUIT	FLOOR	100MM THICK TIMBER INFILL	RYANFIRE 502 BOARD / RYANFIRE STRAP	/120/30	300MM WIDE CABLE TRAY	PF 19059	E
CABLE BUNDLE - TPS / CAT 6 / COMMS	FLOOR	100MM THICK STAHLTON TIMBER INFILL FLOOR	INTUBATT / SL COLLAR / INTUMASTIC HP	/180/60	25 X TPS / 25 X CAT6 / 10 COMMS CABLES	51892400.2	A
CABLE BUNDLE	FLOOR	120MM THICK WOODTEX FLOOR	RYANFIR SL COLLAR	/60/60	40MM DIA CABLE BUNDLE	PF 20106	D
CABLE BUNDLE	FLOOR	120MM THICK CONCRETE FLOOR	RYANFIRE HP-X	/120/90	45MM DIA BUNDLE (POWER)	PF 20097	E
CABLE BUNDLE	FLOOR	120MM THICK CONCRETE FLOOR	RYANFIRE HP-X	/120/120	30MM DIA BUNDLE (DATA)	PF 20097	F
PVC CONDUIT BUNDLE	FLOOR	120MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR	/120/120	4X 25MM FLEXI CONDUITS	PF 20097	H
PVC CONDUIT	FLOOR	120MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR	/90/60	50MM DIA CONDUIT	PF 20091	A
CABLE CONDUIT	FLOOR	120MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR	/120/90	80MM DIA CABLE BUNDLE	PF 20091	B
CABLE CONDUIT	FLOOR	120MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR	/120/120	20MM DIA CONDUIT	PF 20091	D
CABLE BUNDLE	FLOOR	120MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR	/120/120	25MM DIA CABLE BUNDLE	PF 20091	J
CABLE TRAY / LADDER	FLOOR	120MM THICK CONCRETE/MASORY FLOOR	INTUBATT / INTUMASTIC / SLEEVE	/240/180	60 X COMMS CABLES	2600703.2A	H
CABLE TRAY / LADDER	FLOOR	120MM THICK CONCRETE/MASORY FLOOR	INTUBATT / INTUMASTIC / SLEEVE	/180/180	13 X MIXED CABLES	2600703.2A	I
CABLE TRAY / LADDER	FLOOR	120MM THICK CONCRETE/MASORY FLOOR	INTUBATT / INTUMASTIC / SLEEVE	/180/180	D1 CABLE CONFIGURATION	35084000.2	45
CABLE TRAY / LADDER	FLOOR	120MM THICK CONCRETE/MASORY FLOOR	INTUBATT / INTUMASTIC / SLEEVE	/240/180	D2 CABLE CONFIGURATION	35084000.2	44
CABLE BUNDLE	FLOOR	120MM THICK CONCRETE/MASORY FLOOR	INTUBATT / INTUMASTIC	/120/120	21 OPTICAL CABLES	35084000.2	31
CABLE BUNDLE	FLOOR	120MM THICK CONCRETE/MASORY FLOOR	INTUBATT / INTUMASTIC	/120/120	12 OPTICAL CABLES	35084000.2	32
CABLE BUNDLE	FLOOR	COMPOSITE FLOORING - 65MM THICK CONCRETE	INTUBATT / INTUMASTIC	/60/30	75 CABLES	46812300.1	5
CABLE BUNDLE	FLOOR	COMPOSITE FLOORING - 65MM THICK CONCRETE	INTUMASTIC HP	/60/-	75 CABLES	FAS 19047	5
CABLE TRAY / LADDER	FLOOR	COMPOSITE FLOORING - 65MM THICK CONCRETE	INTUBATT / INTUMASTIC	/60/-	13 CABLES	FAS 19047	4
CABLE BUNDLE	FLOOR	140X45MM UNLINED TIMBER FRAME	RYANFIRE 502 BOARD	/60/-	6 X TPS CABLES	PF 19037	C
CABLE BUNDLE	FLOOR	140X45MM UNLINED TIMBER FRAME	RYANFIRE 502 BOARD	/60/30	3X CAT6, 3 X RED ALARM CABLES	PF 19037	F
CABLE BUNDLE	FLOOR	140X45MM UNLINED TIMBER FRAME	RYANFIRE 502 BOARD	/60/-	40MM DIA BUNDLE	PF 19047	C
CABLE BUNDLE	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUMASTIC HP	/90/30	100MM DIA CABLE BUNDLE	52208000.1	1
CABLE/CABLE BUNDLES	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUMASTIC HP	/120/120	18MM DIA / 20MM DIA / 14MM DIA	52208000.1	2+3+4
CABLE BUNDLE	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUMASTIC HP	/120/120	3 CABLES	52208000.1	5
CABLE TRAY / LADDERS	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUMASTIC HP	/120/90 (MAX)	1X52MM DIA + 2X27MM DIA + 1X80MM DIA	52208000.1	6
CABLE TRAY / LADDERS	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUMASTIC HP	/120/30	1 X 60MM DIA	52208000.1	7
CABLE TRAY / LADDERS	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUMASTIC HP	/120/90 (MAX)	41 X MIXED DIA CABLES	52208000.1	8
CABLE TRAY / LADDERS	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUMASTIC HP	/120/30	1X17MM DIA + 1X23MM DIA + 100MM DIA BUNDLE	52208000.1	9
CABLE BUNDLE	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUBATT / INTUMASTIC (SINGLE LAYER)	/60/30	7 MIXED CABLES	35256800	53

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report No.	ID/Ref
ELECTRICAL PENETRATION SERVICES							
CABLE CONDUIT - 50MM DIA	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUBATT / INTUMASTIC / INTUSTRAP - SINGLE LAYER	/240/180	8 X TPS CABLES	35319300	33
CABLE TRAY	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUBATT / INTUMASTIC	/120/30	7 MIXED CABLES	35256800	54
CABLE TRAY	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUCOMPOUND	/240/60	1 X 52MM DIA CABLE	35084000.2	83
CABLE TRAY	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUCOMPOUND	/240/120	2 X 27MM DIA CABLES	35084000.2	84
CABLE TRAY	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUCOMPOUND	/240/60	1 X 80MM DIA CABLE	35084000.2	85
CABLE TRAY	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUCOMPOUND	/240/120	20 X 14MM DIA CABLES	35084000.2	88/89
CABLE TRAY	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUCOMPOUND	/240/60	2X21MM DIA CABLES	35084000.2	90
CABLE TRAY	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUCOMPOUND	/180/120	3 X 61MM DIA CABLES	35084000.2	92
CABLE TRAY / LADDER	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUCOMPOUND	/240/240	1 X 17MM DIA CABLE	35084000.2	94
CABLE TRAY	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUCOMPOUND	/120/120	100MM DIA CABLE BUNDLE	35084000.2	96
CABLE TRANSIT	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	CABLE TRANSIT / INTUMASTIC HP	/120/30	36 CABLES	35084000.2	38
CABLE CONDUIT - 50MM DIA	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUMASTIC HP	/120/120	3 - 6 CABLES	35084000.2	36 - 37
CABLE BUNDLE	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUMASTIC HP	/120/120	80MM DIA BUNDLE	352568000	57
CABLE CONDUIT - 50MM DIA	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUBATT / INTUMASTIC / INTUSTRAP	/240/180	15 CABLES	35319300	34
CABLE BUNDLES	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUBATT / INTUMASTIC	/180/120	10 X DATA + 5 X OPTICAL + 3 X ALARM CABLES	35319300	35
CABLE BUNDLES	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUBATT / INTUMASTIC	/60/60	30MM DIA + 50MM DIA CABLE BUNDLE	35319300	36
CABLE BUNDLE	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUCOLLAR	/120/120	61 CABLES	35256800	55
CABLE TRAY / LADDER	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUCOMPOUND / INTUBATT / INTUMASTIC	/240/120	1 X 52MM DIA/2 X 27MM DIA/1 X 80MM DIA CABLES	35084000.2	62
CABLE TRAY / LADDER	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUCOMPOUND / INTUBATT / INTUMASTIC	/240/240	1 X 58MM DIA CABLE	35084000.2	61
CABLE TRAY / LADDER	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUCOMPOUND / INTUBATT / INTUMASTIC	/240/120	35 X MIXED SIZE CABLES	35084000.2	59
CABLE TRAY / LADDER	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUCOMPOUND / INTUBATT / INTUMASTIC	/240/120	1X100MM DIA BUNDLE + 1X17MM DIA + 1X23MM DIA	35084000.2	60
CABLE TRAY / LADDER	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUCOMPOUND	/180/60	3 X 47MM DIA CABLES	35084000.2	91
CABLE TRAY / LADDER	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUBATT / INTUMASTIC	/120/120	1X300MM 1X200MM 1X500MM WIDE CABLE LADDERS/TRAYS	35084000.2	39
CABLE TRAY / LADDER	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUCOMPOUND / INTUBATT / INTUMASTIC	/240/120	35 CABLES - RANGING FROM 14MM - 47MM DIA	35256800	58
CABLE BUNDLE	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUMASTIC HP	/120/120	80MM DIA BUNDLE	352568000	56
CABLE CONDUIT - 55MM DIA	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUMASTIC HP	/240/120	24 MIXED CABLES	35319300	32
CABLE CONDUIT - 55MM DIA	FLOOR	175MM THICK CONCRETE / MASONRY FLOOR	INTUBATT / INTUMASTIC (SINGLE LAYER)	/240/240	8 X TPS CABLES	35319300	33

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report No.	ID/Ref
SEISMIC/CONSTRUCTION JOINTS							
BLANK SEAL	WALL	KOROK 51 WALL 60 MINUTE INSULATION SYSTEM	INTUBATT	/90/60	700X400 OPENING	FP10847-002	1
BLANK SEAL	WALL	51MM KOROK WALL	RYANFIRE 502 BOARD	/60/30	2500 X 1000MM BLANK APERTURE	PF 20063	A
BLANK SEAL	WALL	51MM KOROK WALL	RYANFIRE 502 BOARD (PATTRESS)	/60/60	2500 X 1000MM BLANK APERTURE	PF 20063	B
BLANK SEAL	WALL	78MM THICK KOROK WALL	RYANFIRE 502 BOARD (PATTRESS)	/90/90	2350 X 900MM BLANK APERTURE	PF 20064	A
BLANK SEAL	WALL	78MM THICK KOROK WALL	RYANFIRE 502 BOARD	/90/90	2350 X 900MM BLANK APERTURE	PF 20064	B
BLANK SEAL	WALL	90MM THICK INSULATED FR PLASTERBOARD WALL / MASONRY / CONCRETE	RYANFIRE 502 BOARD	/60/60	2350 X 1000MM BLANK APERTURE	FRT 200321	A
BLANK SEAL	WALL	90MM THICK INSULATED FR PLASTERBOARD WALL / MASONRY / CONCRETE	RYANFIRE 502 BOARD (PATTRESS)	/60/60	2350 X 1000MM BLANK APERTURE	FRT 200321	B
BLANK SEAL	WALL	116MM THICK PLASTERBOARD WALL / MASONRY / CONCRETE	RYANFIRE 401 BOARD	/60/60	1200MM LONG	FRT 200058	A
BLANK SEAL	WALL	116MM THICK FR PLASTERBOARD WALL / MASONRY / CONCRETE	RYANSPAN 75X50	/60/60	75MM WIDE X 780MM LONG	PF 19067	A
BLANK SEAL	WALL	116MM THICK FR PLASTERBOARD WALL / MASONRY / CONCRETE	RYANFIRE BATSPAN 250MM WIDE	/60/30	250MM WIDE X 780MM LONG	PF 19067	B
BLANK SEAL	WALL	116MM THICK FR PLASTERBOARD WALL / MASONRY / CONCRETE	RYANFIRE 502 BOARD (PATTRESS)	/120/120	2350MM X 1000MM	PF 20103	A
LINEAR GAP SEAL	WALL	120MM THICK FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUMASTIC	/60/0	10X10MM GAP	35084000.2	46
LINEAR GAP SEAL	WALL	142MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUMASTIC HP	/120/120	25MM GAP	52208000.1	21
LINEAR GAP SEAL	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUMASTIC - BARE TIMBER FRAMING	/120/120	30MM GAP	35256800	60 / 61
LINEAR GAP SEAL	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUMASTIC	/120/120	40MM GAP	35319300	38
LINEAR GAP SEAL	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUSIL - BARE TIMBER FRAMING	/120/120	30MM GAP	35256800	62
LINEAR GAP SEAL	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUSIL	/120/120	40MM GAP	35319300	37
BLANK SEAL	WALL	140X45MM UNLINED TIMBER FRAMED WALL	RYANFIRE BATT	/90/90	1200MM LONG X 145MM HIGH	PF 19031	E
BLANK SEAL	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT	/120/120	300X310MM	35319300	38
WALL - INTUBATT - MASTIC GLUED JOINTS	WALL	150MM THICK MASONRY / CONCRETE WALL	INTUBATT / INTUMASTIC	/240/240	1500 X 1500 VOID	35319300	39
HEAD OF WALL JOINT	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE WALL	INTUBATT / INTUMASTIC	/120/120	300MM WIDE GAP	35256800	59
LINEAR GAP SEAL	WALL	150MM THICK CONCRETE WALL	INTUSPAN	/120/120	100MM WIDE GAP	35084000.1	53
LINEAR GAP SEAL	WALL	150MM CONCRETE/AERATED/MASONRY WALL	INTUMASTIC	/180/180	35MM GAP	35084000.2	49
LINEAR GAP SEAL	WALL	175MM THICK AERATED BLOCK WALL	INTUMASTIC	/240/240	35MM GAP	35084000.2	49
LINEAR GAP SEAL	WALL	150MM THICK AERATED BLOCK WALL	INTUSIL	/180/180	35MM GAP	35084000.2	50
LINEAR GAP SEAL	WALL	175MM THICK AERATED BLOCK WALL	INTUSIL	/240/240	35MM GAP	35084000.2	50
LINEAR GAP SEAL VERTICAL	WALL	150MM THICK ACC CONCRETE / MASONRY	INTUSPAN	/60/60	25MM WIDE	25794-01	FIG 1 & 2

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report No.	ID/Ref
SEISMIC/CONSTRUCTION JOINTS							
LINEAR GAP SEAL VERTICAL	WALL	150MM THICK ACC CONCRETE / MASONRY	INTUSPAN	/120/120	50MM WIDE	25794-01	FIG 1 & 2
LINEAR GAP SEAL VERTICAL	WALL	150MM THICK ACC CONCRETE / MASONRY	INTUSPAN	/120/120	75MM WIDE	25794-01	FIG 1 & 2
LINEAR GAP SEAL VERTICAL	WALL	150MM THICK ACC CONCRETE / MASONRY	INTUSPAN	/120/120	100MM WIDE	25794-01	FIG 1 & 2
BLANK SEAL	FLOOR	150MM CONCRETE / MASONRY FLOOR	INTUCOMPOUND - 100MM THICK	/240/180	800 X 600MM VOID	35256800	68
BLANK SEAL	FLOOR	150MM CONCRETE / MASONRY FLOOR	INTUBATT / INTUMASTIC - SINGLE LAYER	/120/60	500 X 500MM VOID	35256800	64
BLANK SEAL	FLOOR	150MM CONCRETE / MASONRY FLOOR	INTUBATT / INTUMASTIC - DOUBLE LAYER - FITTED FROM BELOW - 50MM O/LAP	/120/120	500 X 500MM VOID	35256800	65
BLANK SEAL	FLOOR	150MM CONCRETE / MASONRY FLOOR	INTUBATT / INTUMASTIC - DOUBLE LAYER - WITHIN A GIB LINED OPENING	/120/120	400X450MM VOID	35319300	43
BLANK SEAL	FLOOR	150MM CONCRETE / MASONRY FLOOR	INTUBATT / INTUMASTIC - SINGLE LAYER - FIXED TO TIMBER FRAMING BELOW	/120/120	400 X 450MM VOID	35319300	42
BLANK SEAL	FLOOR	150MM CONCRETE / MASONRY FLOOR	INTUBATT/INTUMASTIC - SINGLE LAYER - FIXED TO LOWER FLOOR SURFACE LEVEL	/120/120	1100 X 400MM VOID	35319300	41
BLANK SEAL	FLOOR	150MM CONCRETE / MASONRY FLOOR	INTUBATT / INTUMASTIC - FIXED TO TIMBER FRAME	/120/60	200MM WIDE VOID	35256800	66
LINEAR GAP SEAL	FLOOR	150MM CONCRETE / MASONRY FLOOR	INTUMASTIC	/180/120	35M GAP	35084000.2	47
LINEAR GAP SEAL	FLOOR	150MM CONCRETE / MASONRY FLOOR	INTUMASTIC	/180/180	210MM GAP	35084000.2	51
LINEAR GAP SEAL	FLOOR	150MM CONCRETE / MASONRY FLOOR	INTUSIL	/180/180	35MM GAP	35084000.2	48
LINEAR GAP SEAL	FLOOR	150MM CONCRETE / MASONRY FLOOR	INTUSIL - 20MM THICK - FITTED FLUSH WITH TOP OF FLOOR LEVEL	/120/120	80MM GAP	35256800	70
LINEAR GAP SEAL	FLOOR	150MM CONCRETE / MASONRY FLOOR	INTUSIL - 20MM THICK - FITTED FLUSH WITH UNDERSIDE OF FLOOR LEVEL	/120/90	80MM GAP	35256800	71
LINEAR GAP SEAL	FLOOR	150MM CONCRETE / MASONRY FLOOR	INTUSIL	/180/180	120MM GAP	35084000.2	52
LINEAR GAP SEAL	FLOOR	150MM CONCRETE / MASONRY FLOOR	INTUSIL	/120/120	220MM GAP	35256800	67
LINEAR GAP SEAL	FLOOR	150MM CONCRETE / MASONRY FLOOR	INTUSPAN 50X50	/240/60	50MM GAP	35084000.2	107
LINEAR GAP SEAL	FLOOR	150MM CONCRETE / MASONRY FLOOR	INTUSPAN 75X50	/120/60	75MM GAP	35084000.2	108
LINEAR GAP SEAL	FLOOR	150MM CONCRETE / MASONRY FLOOR	INTUSPAN 100 X 75	/240/120	100MM GAP	35084000.2	109
LINEAR GAP SEAL	FLOOR	150MM CONCRETE / MASONRY FLOOR	INTUSPAN - 100 X 100 WITH Z CLIPS	/60/60	100MM GAP	35256800	63
LINEAR GAP SEAL	FLOOR	150MM THICK ACC CONCRETE / MASONRY	INTUSPAN	/60/60	25MM WIDE	25794-01	FIG 3 & 4
LINEAR GAP SEAL	FLOOR	150MM THICK ACC CONCRETE / MASONRY	INTUSPAN	/120/120	50MM WIDE	25794-01	FIG 3 & 4
BLANK SEAL	FLOOR	175MM THICK CONCRETE FLOOR	INTUCOMPOUND - 100MM THICK	/240/240	600X800MM VOID	35256800	68
LINEAR GAP SEAL	FLOOR	175MM THICK CONCRETE FLOOR	INTUMASTIC	/240/240	210MM GAP	35084000.2	51
LINEAR GAP SEAL	FLOOR	175MM THICK CONCRETE FLOOR	INTUSIL	/240/240	35MM GAP	35084000.2	48
LINEAR GAP SEAL	FLOOR	175MM THICK CONCRETE FLOOR	INTUSIL	/240/240	120MM GAP	35084000.2	52
LINEAR GAP SEAL	FLOOR	FLOOR THICKNESS OF THE REQUIRED FRL	TBA TITAN FIRE CURTAIN WITH ROCKWOOL BELOW	/120/120	1100MM GAP	FCO-2896	8
LINEAR GAP SEAL	FLOOR	FLOOR THICKNESS OF THE REQUIRED FRL	TBA TITAN FIRE CURTAIN	/120/60	1100MM GAP	FCO-2896	8
LINEAR GAP SEAL	FLOOR	FLOOR THICKNESS OF THE REQUIRED FRL	TBA PLUS 60 FIRE CURTAIN	/120/30	1100MM GAP	FCO-2896	8
LINEAR GAP SEAL	FLOOR	FLOOR THICKNESS OF THE REQUIRED FRL	TBA PHOENIX FIRE CURTAIN	/120/0	1100MM GAP	FCO-2896	8

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report No.	ID/Ref
HVAC							
INTUVENT SLEEVE	WALL	145MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUVENT SLEEVE	/120/120	152MM DIA OPENING	352568000	72
DAMPER - MECHANICAL	WALL	130MM THICK FR PLASTERBOARD / MASONRY / CONCRETE	INTUVENT / INTUBATT / INTUMASTIC	/60/30	510 X 260 DUCT	35084000.2	55
DAMPER - MECHANICAL	WALL	130MM THICK CONCRETE / MASONRY WALL	INTUBATT / INTUMASTIC	/120/0	400X400 DUCT	35084000.2	56
STEEL DUCT	WALL	150MM THICK CONCRETE / MASONRY WALL	INTUMASTIC	/120/0	600X300 DUCT	35084000.2	54
DAMPER - MECHANICAL	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUCOMPOUND	/180/0	ACTION AIR	35084000.2	58
DAMPER - MECHANICAL	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUCOMPOUND	/240/0	ACTION AIR	35256800	74
DAMPER - MECHANICAL	FLOOR	150MM THICK CONCRETE / MASONRY FLOOR	INTUBATT / INTUMASTIC	/120/0	ACTION AIR	35084000.2	57
MIXED SERVICE PENETRATION DEVICES							
A/C PAIR COIL/PVC PIPE/TPS CABLES	WALL	KOROK 51 - 60 MIN INSULATION WALL SYSTEM	SL COLLAR / INTUMASTIC HP	/90/60	1X25MM PVC PIPE/S X PAIR COIL/6XTPS CABLES	FP 10847.002	3
A/C PAIR COIL PIPES / TPS CABLES / UPVC PIPE	WALL	90MM THICK WALL - STANDARD PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE SL COLLAR / RYANFIRE HPX	/30/30	1X 25MM PVC / 3X PAIR COIL PIPES / 5X TPS CABLES	/30/30	B
A/C PAIR COIL PIPES / TPS CABLES / UPVC PIPE	WALL	90MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE SL COLLAR / RYANFIRE HPX	/60/45	1X 25MM PVC / 3X PAIR COIL PIPES / 6X TPS CABLES	FRT 190251	H
COPPER PIPES /PAIR COIL / PVC PIPE / CABLES	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	SL COLLAR - 110MM DIA	/90/30	25MM PVC PIPE / 5 CABLES / 3 PAIR COIL	46469500.2	D
COPPER PIPES /PAIR COIL / PVC PIPE / CABLES	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUMASTIC HP - 110MM DIA OPENING	/90/60	25MM PVC PIPE / 5 CABLES / PAIR COIL	46469500.2	E
PVC PIPES / DATA / TPS CABLES / PEX PIPE / BEER LINES	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE SL COLLAR - INVERTED / INTUMASTIC HP	/90/0	80MM/55MM DIA PVC PIPE/20 MIX CABLES/PEX PIPE / BEER LINE	51028300.1	D
A/C PAIR COIL / TPS CABLES / PVC PIPE	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE SL COLLAR - INTUMASTIC HP	/90/0	3 X A/C PAIR COIL / 6 X TPS CABLES / 1 X 32MM DIA PVC PIPE	51028300.1	G
A/C PAIR COIL / TPS CABLES / PVC PIPE	WALL	116MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	INTUBATT / INTUMASTIC HP	/120/60	4 X A/C PAIR COIL / 6 TPS CABLES / 1X25MM DIA PVC PIPE	51892000.2	E
A/C PAIR COIL PIPES / TPS CABLES / UPVC PIPE	WALL	140X45MM UNLINED TIMBER FRAMED WALL	RYANFIRE 502 BOARD / RYANFIRE SERVICE SLEEVE	/90/30	2X 33MM PVC, 3X PAIR COIL PIPES, 8X TPS CABLES	PF 19031	D
A/C PAIR COIL PIPES / TPS CABLES / UPVC PIPE	CEILING	16MM FR PLASTERBOARD CEILING	RYANFIRE SL COLLAR + HP-X	/45/30	3X PAIR COIL PIPES / 3X TPS CABLES / 1X PVC PIPE	FRT 190272	J
A/C PAIR COIL PIPES / TPS CABLES / UPVC PIPE	FLOOR	90MM THICK PLT FLOOR	RYANFIRE SL COLLAR	/60/30	1X 25MM PVC / 3X PAIR COIL PIPES / 5X TPS CABLES	PF 20061	S
A/C PAIR COIL PIPES / TPS CABLES / UPVC PIPE	FLOOR	40X45MM UNLINED TIMBER FLOOR	RYANFIRE 502 BOARD / RYANFIRE STRAP / RYANFIRE HPX	/60/-	1X 25MM PVC / 3X PAIR COIL PIPES / 3X TPS CABLES	PF 19047	E
A/C PAIR COIL PIPES / TPS CABLES / UPVC PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE TD COLLAR / RYANFIRE HPX	/120/90	3X PAIR COIL PIPES / 3X TPS CABLES / 1X PVC PIPE	FRT 190287	I
A/C PAIR COIL PIPES / TPS CABLES / UPVC PIPE	FLOOR	100MM THICK CONCRETE FLOOR	RYANFIRE SL COLLAR / RYANFIRE HP-X	/120/90	2X PAIR COIL PIPES / 3X TPS CABLES / 1X PVC PIPE	FRT 190285	A
A/C PAIR COIL/TPS CABLES / PVC PIPE	FLOOR	100MM THICK STAHLTON TIMBER INFILL FLOOR	INTUBATT / SL COLLAR / INTUMASTIC HP	/90/30	4 X PAIR COIL / 1 X 25MM DIA PVC PIPE / 6 X TPS CABLES	51892200.2	A
PAIR COIL / PVC PIPE / TPS CABLES	FLOOR	COMPOSITE FLOORS - 65MM THICK CONCRETE	INTUBATTT / INTUMASTIC / INTUMASTIC HP	/120/60	PAIR COIL / 25MM DIA PVC PIPE / TPS CABLES	46812300.1	9

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report No.	ID/Ref
MIXED SERVICE PENETRATION DEVICES							
CABLE CONDUIT / PVC PIPE / TPS CABLES	FLOOR	COMPOSITE FLOORS - 65MM THICK CONCRETE	INTUBATT / INTUMASTIC / INTUMASTIC HP / INTUSTRAP	/90/60	50MM DIA PVC / 30MM DIS PEX / 50MM DIA CONDUIT	46812300.1	8
A/C PAIR COIL PIPES / TPS CABLES / UPVC PIPE	FLOOR	130MM THICK COMPOSITE FLOOR (COMFLOR)	RYANFIRE TD COLLAR / HPX	/60/60	1X UPVC 25MM / 1X PAIR COIL PIPE / 6X TPS CABLES	PF 19011	1
CABLES / CONDUITS / TPS CABLES / PVC PIPE	FLOOR	150MM CONCRETE / MASONRY FLOOR	INTUSLEEVE / INTUSIL	/240/60	20 X OPTICAL / 8 X TPS CABLES / 4 X PVC PIPES	35319300	44
A/C PAIR COIL PIPES / TPS CABLES / UPVC PIPE	FLOOR	150MM THICK CONCRETE FLOOR	RYANFIRE TD COLLAR	/120/-	3X PAIR COIL PIPES / 6X TPS CABLES / 1X PVC PIPE	FRT 200018	G
MISCELLANEOUS PENETRATIONS							
TIMBER PURLIN	WALL	90MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / BATT SLEEVE	/90/60	290X45MM - 4 SIDED	PF19018	SPEC 1
TIMBER PURLIN	WALL	90MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / BATT SLEEVE	/90/60	290X45MM - 3 SIDED	PF19018	SPEC 2
TIMBER PURLIN	WALL	116MM THICK FR PLASTERBOARD / MASONRY / CONCRETE WALL	RYANFIRE 502 BOARD	/60/60	290X45MM	FRT 200058	D
TIMBER PURLIN	WALL	116MM THICK INSULATED fr PLASTERBOARD WALL / MASONRY WALL	RYANFIRE 502 BOARD + SERVOWRAP	/120/120	285X45MM	PF 20098	B
C- STUD PURLIN	WALL	116MM THICK INSULATED fr PLASTERBOARD WALL / MASONRY WALL	RYANFIRE 502 BOARD + SERVOWRAP	/120/120	300 C PURLIN	PF 20098	A
200UB BEAM	WALL	116MM THICK INSULATED fr PLASTERBOARD WALL / MASONRY WALL	RYANFIRE 502 BOARD + SERVOWRAP	/120/120	200UB	PF 20098	D
C- STUD PURLIN	WALL	126MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	DOUBLE RYANFIRE BATT PATRESS	/60/60	300 C PURLIN	PF 19010	29
C- STUD PURLIN	WALL	126MM THICK WALL - FR PLASTERBOARD / MASONRY / CONCRETE	RYANFIRE 502 BOARD / BOARD SLEEVE	/60/60	300 C PURLIN	PF 19010	30
TIMBER JOIST	WALL	145MM THICK WALL - CONCRETE / MASONRY / HEBEL WALLS	INTUBATT / INTUMASTIC	/120/120	95MM X 45MM TIMBER	35319300	45
VENTILLATED ELECTRICAL DOWNLIGHTER COVER	CEILING	FR PLASTERBOARD - THICKNESS OF THE REQUIRED DRL	RYANFIRE DOWNLIGHTER COVER	/60/60	150 / 200 / 250 / 320 / 420 DIA DOWNLIGHTERS	4863	
TIMBER JOIST	FLOOR	150MM THICK CONCRETE FLOOR	INTUBATT / INTUMASTIC	/240/180	95X45MM TIMBER	35319300	46

SNAP FIRE SYSTEMS

Manufacturer Code: SP

1343 Wynnum Rd
Tingalpa
QLD 4173Ph: +61 7 3390 5420
Fax: +61 7 3348 9417
Website: www.snapcollars.com.au

The products listed in this register have all been tested to AS1530.4-2005 or Assessed to AS 4072.1-2005 as referenced within the New Zealand Building Code.

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
uPVC pipe only (or with fitting)	BEAM	Concrete Beam	SNAP H100S - Cast In collar - Stack	-/240/240	100mm	FSP1715
uPVC pipe only (or with fitting)	BEAM	Concrete Beam	SNAP L100FWS - Cast In collar - Floorwaste & Shower	-/240/240	100mm	FSP1715
dBlue pipe	FLOOR	150mm Concrete Slab	SNAP L40/L50S - Retrofit collar - Stack	-/240/240	40mm	FSP1648
dBlue pipe	FLOOR	150mm Concrete Slab	SNAP H50S - Retrofit collar - Stack	-/240/240	50mm	FSP1648
dBlue pipe	FLOOR	150mm Concrete Slab	SNAP L80S - Cast In collar - Stack	-/240/240	75mm	FSP1648
dBlue pipe	FLOOR	150mm Concrete Slab	SNAP H100S - Cast In collar - Stack	-/240/240	110mm	FSP1648
dBlue pipe	FLOOR	150mm Concrete Slab	SNAP H150S - Cast In collar - Stack	-/240/120	160mm	FSP1648
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP 50R - Retrofit collar - Stack	-/240/240	40mm	FP4837
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP H50S - Retrofit collar - Stack	-/240/240	40mm	FSP1736
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP H65S - Retrofit collar - Stack	-/240/240	40mm	FR5670
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP LP65R - Retrofit collar - Floorwaste & Shower	-/240/240	40mm	FSP1789
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP H50FWS - Retrofit collar - Floorwaste & Shower	-/240/240	50mm	FR5670
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP H50S - Retrofit collar - Stack	-/240/240	50mm	FSP1615
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP LP50R - Retrofit collar - Floorwaste & Shower	-/180/180	50mm	FSP1146
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP H50FWS - Retrofit collar - Floorwaste & Shower	-/240/240	56mm	FSP1592
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP H50S - Retrofit collar - Stack	-/240/240	56mm	FP4640
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP H65S - Retrofit collar - Stack	-/240/240	56mm	FSP1700
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP H100S - Cast In collar - Stack	-/240/240	63mm	FAR3932
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP H65S - Cast In collar - Stack	-/240/240	63mm	FSP1696
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP H100S - Cast In collar - Stack	-/240/240	75mm	FAR3932
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP H100S - Cast In collar - Stack	-/240/240	90mm	FAR3932
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP L100FWS - Cast In collar - Floorwaste & Shower	-/240/240	100mm	FSP1592
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP 110R - Cast In collar - Stack	-/240/240	110mm	FP4837
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP H100FWS - Cast In collar - Floorwaste & Shower	-/180/180	110mm	FSP1134
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP H100S - Cast In collar - Stack	-/240/240	110mm	FSP1577

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP HP100R - Cast In collar - Floorwaste & Shower	-/240/240	110mm	FP4640
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP LP100R-D - Cast In collar - Floorwaste & Shower	-/240/240	110mm	FSP1830
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP H150S - Cast In collar - Stack	-/240/240	125mm	FR5670
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP H150S - Cast In collar - Stack	-/240/180	125mm	FSP1615
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP HP150R - Cast In collar - Stack	-/240/240	125mm	FSP1615
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP H150S - Cast In collar - Stack	-/180/180	160mm	FAR3528
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP H150S - Cast In collar - Stack	-/180/180	160mm	FSP1132
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP H150S - Cast In collar - Stack	-/180/120	160mm	FR5670
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP HP150R - Cast In collar - Stack	-/240/240	160mm	FSP1615
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP LP200R - Cast In collar - Stack	-/180/180	200mm	FSP1641
HDPE pipe	FLOOR	150mm Concrete Slab	SNAP HP250R-B - Cast In collar - Stack	-/180/180	250mm	FSP1692
HDPE Silent pipe	FLOOR	150mm Concrete Slab	SNAP LP50R - Retrofit collar - Floorwaste & Shower	-/180/180	50mm	FSP1146
HDPE Silent pipe	FLOOR	150mm Concrete Slab	SNAP H100S - Cast In collar - Stack	-/240/240	110mm	FAR3932
HDPE Silent pipe	FLOOR	150mm Concrete Slab	SNAP L100S - Cast In collar - Stack	-/240/240	110mm	FAR3932
IPEX PE-AL-PE pipe	FLOOR	150mm Concrete Slab	SNAP 32GAS - Retrofit collar - Stack	-/240/240	16mm	FSP1339
IPEX PE-AL-PE pipe	FLOOR	150mm Concrete Slab	SNAP 32GAS - Retrofit collar - Stack	-/240/240	20mm	FCO2718
IPEX PE-AL-PE pipe	FLOOR	150mm Concrete Slab	SNAP 32GAS - Retrofit collar - Stack	-/240/240	25mm	FCO2718
IPEX PE-AL-PE pipe	FLOOR	150mm Concrete Slab	SNAP 32GAS - Retrofit collar - Stack	-/240/240	32mm	FSP1339
IPEX PE-AL-PE pipe	FLOOR	150mm Concrete Slab	SNAP 50GAS - Retrofit collar - Stack	-/240/240	32mm	FCO2718
IPEX PE-AL-PE pipe	FLOOR	150mm Concrete Slab	SNAP 50GAS - Retrofit collar - Stack	-/240/240	32mm	FSP1340
IPEX PE-AL-PE pipe	FLOOR	150mm Concrete Slab	SNAP 50GAS - Retrofit collar - Stack	-/240/240	40mm	FCO2718
IPEX PE-AL-PE pipe	FLOOR	150mm Concrete Slab	SNAP 50GAS - Retrofit collar - Stack	-/240/0	40mm	FCO2718
IPEX PE-AL-PE pipe	FLOOR	150mm Concrete Slab	SNAP 50GAS - Retrofit collar - Stack	-/240/240	50mm	FSP1339
IPEX PE-AL-PE pipe	FLOOR	150mm Concrete Slab	SNAP 50GAS - Retrofit collar - Stack	-/240/0	50mm	FSP1340
PE 11 pipe	FLOOR	150mm Concrete Slab	SNAP H100FWS - Cast In collar - Stack	-/240/180	110mm	FSP1367a
PE 11 pipe	FLOOR	150mm Concrete Slab	SNAP 125C - Cast In collar - Stack	-/240/120	125mm	FSP1367a
PE 11 pipe	FLOOR	150mm Concrete Slab	SNAP H150S - Cast In collar - Stack	-/240/120	160mm	FAR3528
PE 11 pipe	FLOOR	150mm Concrete Slab	SNAP H150S - Cast In collar - Stack	-/240/120	160mm	FSP1367a
PE 7.4 pipe	FLOOR	150mm Concrete Slab	SNAP H50FWS - Retrofit collar - Stack	-/240/240	20mm	FSP1367a
PE 7.4 pipe	FLOOR	150mm Concrete Slab	SNAP H50FWS - Retrofit collar - Stack	-/240/240	25mm	FAR3932
PE 7.4 pipe	FLOOR	150mm Concrete Slab	SNAP H50FWS - Retrofit collar - Stack	-/240/240	32mm	FAR3932
PE 7.4 pipe	FLOOR	150mm Concrete Slab	SNAP H50FWS - Retrofit collar - Stack	-/240/240	40mm	FAR3932
PE 7.4 pipe	FLOOR	150mm Concrete Slab	SNAP H100FWS - Retrofit collar - Stack	-/240/240	50mm	FSP1367a
PE 7.4 pipe	FLOOR	150mm Concrete Slab	SNAP H50FWS - Retrofit collar - Stack	-/240/240	50mm	FSP1367a
PE 7.4 pipe	FLOOR	150mm Concrete Slab	SNAP H100FWS - Cast In collar - Stack	-/240/180	63mm	FAR3932

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
PE 7.4 pipe	FLOOR	150mm Concrete Slab	SNAP H100FWS - Cast In collar - Stack	-/240/180	75mm	FAR3932
PE 7.4 pipe	FLOOR	150mm Concrete Slab	SNAP H100FWS - Cast In collar - Stack	-/240/180	90mm	FAR3932
PEX-A pipe	FLOOR	150mm Concrete Slab	SNAP 32R - Retrofit collar - Stack	-/240/180	16mm	FR5670
PEX-A pipe	FLOOR	150mm Concrete Slab	SNAP H50S - Retrofit collar - Stack	-/240/240	16mm	FR5670
PEX-A pipe	FLOOR	150mm Concrete Slab	SNAP 32R - Retrofit collar - Stack	-/240/240	20mm	FR5670
PEX-A pipe	FLOOR	150mm Concrete Slab	SNAP H50S - Retrofit collar - Stack	-/240/240	20mm	FR5670
PEX-A pipe	FLOOR	150mm Concrete Slab	SNAP 32R - Retrofit collar - Stack	-/240/240	25mm	FR5670
PEX-A pipe	FLOOR	150mm Concrete Slab	SNAP LP50R - Retrofit collar - Multiple Stack	-/240/240	3x20mm	FSP1849
PEX-AL pipe	FLOOR	150mm Concrete Slab	SNAP 32GAS - Retrofit collar - Stack	-/240/240	16mm	FSP1758
PEX-AL pipe	FLOOR	150mm Concrete Slab	SNAP 32GAS - Retrofit collar - Stack	-/240/240	20mm	FSP1758
PEX-AL pipe	FLOOR	150mm Concrete Slab	SNAP 32GAS - Retrofit collar - Stack	-/240/240	26mm	FSP1758
PEX-AL pipe	FLOOR	150mm Concrete Slab	SNAP 32GAS - Retrofit collar - Stack	-/240/240	32mm	FSP1758
PEX-AL pipe	FLOOR	150mm Concrete Slab	SNAP 50GAS - Retrofit collar - Stack	-/240/120	40mm	FSP1758
PEX-AL pipe	FLOOR	150mm Concrete Slab	SNAP 50GAS - Retrofit collar - Stack	-/240/180	50mm	FSP1771
PEX-AL pipe	FLOOR	150mm Concrete Slab	SNAP 63GAS - Retrofit collar - Stack	-/240/120	63mm	FSP1758
PEX-B pipe	FLOOR	150mm Concrete Slab	SNAP 32R - Retrofit collar - Stack	-/240/240	16mm	FR5670
PEX-B pipe	FLOOR	150mm Concrete Slab	SNAP H50S - Retrofit collar - Stack	-/240/240	16mm	FR5670
PEX-B pipe	FLOOR	150mm Concrete Slab	SNAP 32R - Retrofit collar - Stack	-/240/240	20mm	FR5670
PEX-B pipe	FLOOR	150mm Concrete Slab	SNAP H50S - Retrofit collar - Stack	-/240/240	20mm	FR5670
PEX-B pipe	FLOOR	150mm Concrete Slab	SNAP 32R - Retrofit collar - Stack	-/240/240	25mm	FR5670
PPR 7.4 pipe	FLOOR	150mm Concrete Slab	SNAP H50FWS - Retrofit collar - Stack	-/240/240	20mm	FSP1359
PPR 7.4 pipe	FLOOR	150mm Concrete Slab	SNAP H50FWS - Retrofit collar - Stack	-/240/240	25mm	FAR3932
PPR 7.4 pipe	FLOOR	150mm Concrete Slab	SNAP H50FWS - Retrofit collar - Stack	-/240/240	32mm	FAR3932
PPR 7.4 pipe	FLOOR	150mm Concrete Slab	SNAP H50FWS - Retrofit collar - Stack	-/240/240	40mm	FAR3932
PPR 7.4 pipe	FLOOR	150mm Concrete Slab	SNAP H100FWS - Retrofit collar - Stack	-/240/180	50mm	FSP1359
PPR 7.4 pipe	FLOOR	150mm Concrete Slab	SNAP H50FWS - Retrofit collar - Stack	-/240/240	50mm	FSP1359
PPR 7.4 pipe	FLOOR	150mm Concrete Slab	SNAP H100FWS - Cast In collar - Stack	-/240/180	63mm	FAR3932
PPR 7.4 pipe	FLOOR	150mm Concrete Slab	SNAP H100FWS - Cast In collar - Stack	-/240/180	75mm	FAR3932
PPR 7.4 pipe	FLOOR	150mm Concrete Slab	SNAP H100FWS - Cast In collar - Stack	-/240/180	90mm	FAR3932
PPR 7.4 pipe	FLOOR	150mm Concrete Slab	SNAP H100FWS - Cast In collar - Stack	-/240/240	110mm	FSP1359
PPR 7.4 pipe	FLOOR	150mm Concrete Slab	SNAP 125C - Cast In collar - Stack	-/240/180	125mm	FSP1359
PPR 7.4 pipe	FLOOR	150mm Concrete Slab	SNAP H150S - Cast In collar - Stack	-/240/180	160mm	FAR3528
PPR 7.4 pipe	FLOOR	150mm Concrete Slab	SNAP H150S - Cast In collar - Stack	-/240/180	160mm	FSP1359
P-PVC pipe	FLOOR	150mm Concrete Slab	SNAP H50FWS - Retrofit collar - Stack	-/240/240	15mm	FSP1601
P-PVC pipe	FLOOR	150mm Concrete Slab	SNAP H50S - Retrofit collar - Stack	-/240/240	32mm	FR5670

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
P-PVC pipe	FLOOR	150mm Concrete Slab	SNAP H50FWS - Retrofit collar - Stack	-/240/240	50mm	FSP1601
Progef pipe	FLOOR	150mm Concrete Slab	SNAP 32R - Retrofit collar - Stack	-/240/240	25mm	FSP1657
Progef pipe	FLOOR	150mm Concrete Slab	SNAP H50FWS - Retrofit collar - Stack	-/240/240	25mm	FSP1657
Progef pipe	FLOOR	150mm Concrete Slab	SNAP 32R - Retrofit collar - Stack	-/240/240	32mm	FSP1657
Progef pipe	FLOOR	150mm Concrete Slab	SNAP 50R - Retrofit collar - Stack	-/240/240	40mm	FSP1657
Progef pipe	FLOOR	150mm Concrete Slab	SNAP H50FWS - Retrofit collar - Stack	-/240/240	40mm	FSP1657
Progef pipe	FLOOR	150mm Concrete Slab	SNAP 50R - Retrofit collar - Stack	-/240/240	50mm	FSP1657
Progef pipe	FLOOR	150mm Concrete Slab	SNAP H50FWS - Retrofit collar - Stack	-/240/240	50mm	FSP1657
Progef pipe	FLOOR	150mm Concrete Slab	SNAP 63R - Retrofit collar - Stack	-/240/240	63mm	FSP1657
Progef pipe	FLOOR	150mm Concrete Slab	SNAP H50FWS - Cast In collar - Stack	-/240/240	63mm	FSP1657
Raupiano pipe	FLOOR	150mm Concrete Slab	SNAP H50S - Retrofit collar - Stack	-/240/240	40mm	FSP1564
Raupiano pipe	FLOOR	150mm Concrete Slab	SNAP H50FWS - Retrofit collar - Floorwaste & Shower	-/240/240	50mm	FSP1564
Raupiano pipe	FLOOR	150mm Concrete Slab	SNAP H100FWS - Cast In collar - Floorwaste & Shower	-/240/240	100mm	FSP1564
Raupiano pipe	FLOOR	150mm Concrete Slab	SNAP H100S - Cast In collar - Stack	-/240/240	100mm	FSP1564
Raupiano pipe	FLOOR	150mm Concrete Slab	SNAP H150S - Cast In collar - Stack	-/240/240	150mm	FSP1592
Raupiano pipe	FLOOR	150mm Concrete Slab	SNAP H150S - Cast In collar - Stack	-/240/180	150mm	FR5670
Raupiano pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP L40/L50S - Retrofit collar - Stack	-/240/240	40mm	FSP1614
Raupiano pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP LP50R - Retrofit collar - Stack	-/240/240	40mm	FSP1713
Raupiano pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP L40/L50S - Retrofit collar - Stack	-/240/240	50mm	FSP1614
Raupiano pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP LP50R - Retrofit collar - Floorwaste & Shower	-/240/240	50mm	FSP1713
Raupiano pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP L80FWS - Cast In collar - Stack	-/240/240	75mm	FSP1614
Raupiano pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP H150S - Cast In collar - Stack	-/240/240	100mm	FSP1614
Raupiano pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP H100S - Cast In collar - Stack	-/240/240	110mm	FSP1741
Raupiano pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP H150S - Cast In collar - Stack	-/240/180	110mm	FR5670
Raupiano pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP LP100R-B - Cast In collar - Stack	-/240/240	110mm	FSP1713
REHAU PX-AL-PE pipe	FLOOR	150mm Concrete Slab	SNAP 32GAS - Retrofit collar - Stack	-/240/240	32mm	FSP1339
REHAU PX-AL-PE pipe	FLOOR	150mm Concrete Slab	SNAP 50GAS - Retrofit collar - Stack	-/240/180	40mm	FSP1340
REHAU PX-AL-PE pipe	FLOOR	150mm Concrete Slab	SNAP 50GAS - Retrofit collar - Stack	-/240/240	40mm	FSP1340
Rifeng PX-AL-PX pipe	FLOOR	150mm Concrete Slab	SNAP 32GAS - Retrofit collar - Stack	-/240/240	16mm	FSP1339
Rifeng PX-AL-PX pipe	FLOOR	150mm Concrete Slab	SNAP 32GAS - Retrofit collar - Stack	-/240/240	20mm	FCO2719
Rifeng PX-AL-PX pipe	FLOOR	150mm Concrete Slab	SNAP 32GAS - Retrofit collar - Stack	-/240/240	25mm	FCO2719
Rifeng PX-AL-PX pipe	FLOOR	150mm Concrete Slab	SNAP 32GAS - Retrofit collar - Stack	-/240/240	32mm	FSP1339
Rifeng PX-AL-PX pipe	FLOOR	150mm Concrete Slab	SNAP 50GAS - Retrofit collar - Stack	-/240/240	32mm	FSP1339
Rifeng PX-AL-PX pipe	FLOOR	150mm Concrete Slab	SNAP 50GAS - Retrofit collar - Stack	-/240/240	32mm	FSP1340
Rifeng PX-AL-PX pipe	FLOOR	150mm Concrete Slab	SNAP 50GAS - Retrofit collar - Stack	-/240/240	40mm	FCO2719

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
Rifeng PX-AL-PX pipe	FLOOR	150mm Concrete Slab	SNAP 50GAS - Retrofit collar - Stack	-/240/180	40mm	FCO2719
Rifeng PX-AL-PX pipe	FLOOR	150mm Concrete Slab	SNAP 50GAS - Retrofit collar - Stack	-/240/240	50mm	FCO2719
Rifeng PX-AL-PX pipe	FLOOR	150mm Concrete Slab	SNAP 50GAS - Retrofit collar - Stack	-/240/180	50mm	FSP1340
Rifeng PX-AL-PX pipe	FLOOR	150mm Concrete Slab	SNAP 63GAS - Retrofit collar - Stack	-/240/240	63mm	FSP1340
Triplus pipe	FLOOR	150mm Concrete Slab	SNAP L40/L50S - Retrofit collar - Stack	-/240/240	40mm	FSP1652
Triplus pipe	FLOOR	150mm Concrete Slab	SNAP H50S - Retrofit collar - Stack	-/240/240	50mm	FSP1652
Triplus pipe	FLOOR	150mm Concrete Slab	SNAP L80S - Cast In collar - Stack	-/240/240	75mm	FSP1652
Triplus pipe	FLOOR	150mm Concrete Slab	SNAP H100S - Cast In collar - Stack	-/240/240	110mm	FSP1652
Triplus pipe	FLOOR	150mm Concrete Slab	SNAP L100FWS - Cast In collar - Floorwaste & Shower	-/240/240	110mm	FSP1652
Triplus pipe	FLOOR	150mm Concrete Slab	SNAP H150S - Cast In collar - Stack	-/240/180	160mm	FSP1652
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP H50FWS - Retrofit collar - Floorwaste & Shower	-/240/240	40mm	FSP1576
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP H50S - Retrofit collar - Stack	-/240/120	40mm	FR5670
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP L40/L50S - Retrofit collar - Stack	-/240/240	40mm	FSP1575
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP 50R - Retrofit collar - Stack	-/240/240	50mm	FSP1686
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP H100FWS - Retrofit collar - Floorwaste & Shower	-/240/240	50mm	FP4640
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP H50FWS - Retrofit collar - Floorwaste & Shower	-/240/240	50mm	FSP1576
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP H50FWS - Retrofit collar - Floorwaste & Shower	-/240/240	50mm	FR5670
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP H50S - Retrofit collar - Stack	-/240/240	50mm	FSP1575
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP LP50R - Retrofit collar - Floorwaste & Shower	-/240/240	50mm	FP4640
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP LP65R - Retrofit collar - Stack	-/180/180	50mm	FSP1641
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP 65-80R - Cast In collar - Stack	-/240/240	65mm	FP4837
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP H100FWS - Cast In collar - Floorwaste & Shower	-/240/240	65mm	FSP1577
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP H100S - Cast In collar - Stack	-/240/60	65mm	FR5670
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP L65S - Cast In collar - Stack	-/240/240	65mm	FSP1575
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP 65-80R - Cast In collar - Stack	-/240/240	80mm	FP4837
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP H100FWS - Cast In collar - Floorwaste & Shower	-/240/240	80mm	FSP1576
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP H100S - Cast In collar - Stack	-/240/240	80mm	FSP1575
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP LP100R-C - Cast In collar - Floorwaste & Shower	-/180/120	80mm	FR5670
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP LP100R-D - Cast In collar - Floorwaste & Shower	-/240/240	80mm	FSP1781
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP LP80R - Cast In collar - Floorwaste & Shower	-/240/240	80mm	FSP1592
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP 110R - Cast In collar - Stack	-/240/240	100mm	FP4640
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP H100FWS - Cast In collar - Floorwaste & Shower	-/240/240	100mm	FSP1576
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP H100FWS - Cast In collar - Floorwaste & Shower	-/240/240	100mm	FR5670
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP H100S - Cast In collar - Stack	-/240/240	100mm	FP4837
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP H100S - Cast In collar - Stack	-/240/240	100mm	FSP1575

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP H150S - Cast In collar - Floorwaste & Shower	-/240/240	100mm	FSP1592
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP L100FWS - Cast In collar - Floorwaste & Shower	-/240/240	100mm	FP4837
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP H150S - Cast In collar - Stack	-/180/180	150mm	FAR3528
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP HP150R - Cast In collar - Stack	-/240/240	150mm	FSP1601
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP 250C - Cast In collar - Stack	-/180/180	225mm	FSP1641
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP HP250R-B - Cast In collar - Stack	-/240/240	225mm	FSP1849
uPVC pipe	FLOOR	150mm Concrete Slab	SNAP 315C - Cast In collar - Stack	-/180/180	315mm	FSP1144
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP 50R - Retrofit collar - Stack	-/240/240	40mm	FP4837
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP H50S - Retrofit collar - Stack	-/240/240	40mm	FSP1577
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP H65S - Retrofit collar - Stack	-/240/240	40mm	FSP1735
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP LP50R - Retrofit collar - Floorwaste & Shower	-/240/120	40mm	FR5670
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP LP65R - Retrofit collar - Floorwaste & Shower	-/180/180	40mm	FSP1641
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP 63R - Retrofit collar - Stack	-/240/240	50mm	FP4640
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP H50FWS - Retrofit collar - Floorwaste & Shower	-/240/240	50mm	FSP1564
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP H50S - Retrofit collar - Stack	-/240/240	50mm	FAR3932
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP H65S - Retrofit collar - Stack	-/240/240	50mm	FSP1696
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP L40/L50S - Retrofit collar - Stack	-/240/240	50mm	FAR3932
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP LP50R - Retrofit collar - Floorwaste & Shower	-/240/240	50mm	FSP1700
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP H100S - Cast In collar - Stack	-/240/240	65mm	FAR3932
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP H65S - Cast In collar - Stack	-/240/240	65mm	FSP1696
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP L65S - Cast In collar - Stack	-/240/240	65mm	FAR3932
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP LP65R - Cast In collar - Floorwaste & Shower	-/240/240	65mm	FSP1789
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP H100S - Cast In collar - Stack	-/240/240	80mm	FAR3932
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP H100S - Cast In collar - Stack	-/240/240	80mm	FSP1830
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP L80S - Cast In collar - Stack	-/240/240	80mm	FAR3932
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP LP100R-D - Cast In collar - Floorwaste & Shower	-/240/240	80mm	FSP1789
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP H100S - Cast In collar - Stack	-/240/240	90mm	FAR3932
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP L100S - Cast In collar - Stack	-/240/240	90mm	FAR3932
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP 110R - Cast In collar - Stack	-/240/240	100mm	FP4640
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP H100FWS - Cast In collar - Floorwaste & Shower	-/240/240	100mm	FSP1577
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP H100S - Cast In collar - Stack	-/240/240	100mm	FAR3932
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP H100S - Cast In collar - Stack	-/240/240	100mm	FSP1577
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP H150S - Cast In collar - Stack	-/240/240	100mm	FAR3932
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP H150S - Cast In collar - Stack	-/240/240	100mm	FR5670
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP L100S - Cast In collar - Stack	-/240/240	100mm	FAR3932

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP LP100R-b - Cast In collar - Floorwaste & Shower	-/240/180	100mm	FSP1713
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP H150S - Cast In collar - Floorwaste & Shower	-/240/240	150mm	FSP1700
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP H150S - Cast In collar - Stack	-/240/180	150mm	FR5670
uPVC pipe only (or with fitting)	FLOOR	150mm Concrete Slab	SNAP HP150R - Cast In collar - Stack	-/240/240	150mm	FSP1615
Wavin AS pipe	FLOOR	150mm Concrete Slab	SNAP H65S - Retrofit collar - Stack	-/240/240	56mm	FSP1771
Wavin AS pipe	FLOOR	150mm Concrete Slab	SNAP H100S - Cast In collar - Stack	-/240/240	70mm	FSP1771
Wavin AS pipe	FLOOR	150mm Concrete Slab	SNAP H100S - Cast In collar - Stack	-/240/240	110mm	FSP1771
HDPE pipe	FLOOR	150mm Concrete Slab + Condeck	SNAP H50FWS - Retrofit collar - Floorwaste & Shower	-/240/240	56mm	FSP1686
uPVC pipe	FLOOR	150mm Concrete Slab + Condeck	SNAP H50FWS - Retrofit collar - Floorwaste & Shower	-/240/240	50mm	FSP1686
Raupiano pipe	FLOOR	170mm Concrete Slab	SNAP L40/L50S - Retrofit collar - Stack	-/240/240	40mm	FAR4019
Raupiano pipe	FLOOR	170mm Concrete Slab	SNAP L40/L50S - Retrofit collar - Stack	-/240/240	40mm	FAR4019
Raupiano pipe	FLOOR	170mm Concrete Slab	SNAP H50S - Retrofit collar - Stack	-/240/240	50mm	FAR4019
Raupiano pipe	FLOOR	170mm Concrete Slab	SNAP L40/L50S - Retrofit collar - Stack	-/240/240	50mm	FAR4019
Raupiano pipe	FLOOR	170mm Concrete Slab	SNAP H100S - Cast In collar - Stack	-/240/240	75mm	FAR4019
Raupiano pipe	FLOOR	170mm Concrete Slab	SNAP L80S - Cast In collar - Stack	-/240/240	75mm	FAR4019
Raupiano pipe	FLOOR	170mm Concrete Slab	SNAP H100S - Cast In collar - Stack	-/240/240	90mm	FAR4019
Raupiano pipe	FLOOR	170mm Concrete Slab	SNAP L100S - Cast In collar - Stack	-/240/240	90mm	FAR4019
Raupiano pipe	FLOOR	170mm Concrete Slab	SNAP L100S - Cast In collar - Stack	-/240/240	100mm	FAR4019
uPVC pipe	FLOOR	170mm Concrete Slab	SNAP LP100R - Cast In collar - Floorwaste & Shower	-/240/240	100mm	FAR3722
uPVC pipe	FLOOR	170mm Concrete Slab	SNAP LP100R - Cast In collar - Floorwaste & Shower	-/240/240	100mm	FP4428
uPVC pipe only (or with fitting)	FLOOR	170mm Concrete Slab	SNAP H150S - Cast In collar - Stack	-/240/240	150mm	FAR3528
uPVC pipe only (or with fitting)	FLOOR	170mm Concrete Slab	SNAP H150S - Cast In collar - Stack	-/240/240	150mm	FP4428
PE 11 pipe	FLOOR	175mm Concrete Slab	SNAP 125C - Cast In collar - Stack	-/240/240	125mm	FSP1367a
PE 11 pipe	FLOOR	175mm Concrete Slab	SNAP H150S - Cast In collar - Stack	-/240/180	160mm	FSP1367a
HDPE pipe	FLOOR	180mm Concrete Slab	SNAP 50R - Retrofit collar - Stack	-/240/240	50mm	FAR3933
HDPE pipe	FLOOR	180mm Concrete Slab	SNAP 63R - Retrofit collar - Stack	-/240/240	50mm	FAR3933
HDPE pipe	FLOOR	180mm Concrete Slab	SNAP LP50R - Retrofit collar - Stack	-/240/240	50mm	FAR3933
HDPE pipe	FLOOR	180mm Concrete Slab	SNAP 50R - Retrofit collar - Stack	-/240/240	56mm	FAR3933
HDPE pipe	FLOOR	180mm Concrete Slab	SNAP 63R - Retrofit collar - Stack	-/240/240	56mm	FAR3933
HDPE pipe	FLOOR	180mm Concrete Slab	SNAP 63R - Retrofit collar - Stack	-/240/240	63mm	FAR3933
HDPE pipe	FLOOR	180mm Concrete Slab	SNAP 65-80R - Retrofit collar - Stack	-/240/240	63mm	FAR3933
HDPE pipe	FLOOR	180mm Concrete Slab	SNAP 65-80R - Cast In collar - Stack	-/240/240	75mm	FAR3933
HDPE pipe	FLOOR	180mm Concrete Slab	SNAP 84R - Cast In collar - Stack	-/240/240	75mm	FAR3933
HDPE pipe	FLOOR	180mm Concrete Slab	SNAP 110R - Cast In collar - Stack	-/240/240	90mm	FAR3933
HDPE pipe	FLOOR	180mm Concrete Slab	SNAP HP100R - Cast In collar - Stack	-/240/240	110mm	FAR3933

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
HDPE Silent pipe	FLOOR	180mm Concrete Slab	SNAP LP50R - Retrofit collar - Stack	-/240/240	50mm	FAR3933
uPVC pipe	FLOOR	180mm Concrete Slab	SNAP 63R - Cast In collar - Stack	-/240/240	65mm	FAR3933
uPVC pipe	FLOOR	180mm Concrete Slab	SNAP LP100R - Cast In collar - Stack	-/240/240	100mm	FAR3933
uPVC pipe only (or with fitting)	FLOOR	180mm Concrete Slab	SNAP LP50R - Retrofit collar - Stack	-/240/240	50mm	FAR3933
uPVC pipe only (or with fitting)	FLOOR	180mm Concrete Slab	SNAP 65-80R - Cast In collar - Stack	-/240/240	65mm	FAR3933
uPVC pipe only (or with fitting)	FLOOR	180mm Concrete Slab	SNAP 65-80R - Cast In collar - Stack	-/240/240	80mm	FAR3933
uPVC pipe only (or with fitting)	FLOOR	180mm Concrete Slab	SNAP 110R - Cast In collar - Stack	-/240/240	90mm	FAR3933
uPVC pipe only (or with fitting)	FLOOR	180mm Concrete Slab	SNAP HP150R - Cast In collar - Floorwaste & Shower	-/240/180	150mm	FSP1781
HDPE pipe	FLOOR	185mm Concrete Slab	SNAP H50FWS - Retrofit collar - Floorwaste & Shower	-/180/180	50mm	FAR3932
HDPE pipe	FLOOR	185mm Concrete Slab	SNAP H100FWS - Cast In collar - Floorwaste & Shower	-/240/240	63mm	FAR3932
HDPE pipe	FLOOR	185mm Concrete Slab	SNAP H100FWS - Cast In collar - Floorwaste & Shower	-/240/240	75mm	FAR3932
HDPE pipe	FLOOR	185mm Concrete Slab	SNAP H100FWS - Cast In collar - Floorwaste & Shower	-/240/240	90mm	FAR3932
HDPE Silent pipe	FLOOR	185mm Concrete Slab	SNAP H100FWS - Cast In collar - Floorwaste & Shower	-/240/240	110mm	FAR3932
HDPE Silent pipe	FLOOR	185mm Concrete Slab	SNAP L100FWS - Cast In collar - Floorwaste & Shower	-/240/240	110mm	FAR3932
uPVC pipe only (or with fitting)	FLOOR	185mm Concrete Slab	SNAP H100FWS - Retrofit collar - Floorwaste & Shower	-/240/240	50mm	FAR3932
uPVC pipe only (or with fitting)	FLOOR	185mm Concrete Slab	SNAP L100FWS - Retrofit collar - Floorwaste & Shower	-/240/240	50mm	FAR3932
uPVC pipe only (or with fitting)	FLOOR	185mm Concrete Slab	SNAP H100FWS - Cast In collar - Floorwaste & Shower	-/240/240	65mm	FAR3932
uPVC pipe only (or with fitting)	FLOOR	185mm Concrete Slab	SNAP L65FWS - Cast In collar - Floorwaste & Shower	-/240/240	65mm	FAR3932
uPVC pipe only (or with fitting)	FLOOR	185mm Concrete Slab	SNAP H100FWS - Cast In collar - Floorwaste & Shower	-/240/240	80mm	FAR3932
uPVC pipe only (or with fitting)	FLOOR	185mm Concrete Slab	SNAP L80FWS - Cast In collar - Floorwaste & Shower	-/240/240	80mm	FAR3932
uPVC pipe only (or with fitting)	FLOOR	185mm Concrete Slab	SNAP H100FWS - Cast In collar - Floorwaste & Shower	-/240/240	100mm	FAR3932
uPVC pipe only (or with fitting)	FLOOR	185mm Concrete Slab	SNAP H150S - Cast In collar - Floorwaste & Shower	-/240/240	100mm	FAR3932
uPVC pipe only (or with fitting)	FLOOR	185mm Concrete Slab	SNAP L100FWS - Cast In collar - Floorwaste & Shower	-/240/240	100mm	FAR3932
HDPE pipe	WALL	150mm Hebel block wall	SNAP HP100R - Cast In collar - Stack	-/240/240	110mm	FSP1659
HDPE pipe	WALL	150mm Hebel block wall	SNAP HP150R - Cast In collar	-/180/180	160mm	FSP1668
uPVC pipe	WALL	150mm Hebel block wall	SNAP LP50R - Retrofit collar - Stack	-/240/240	50mm	FSP1659
uPVC pipe	WALL	150mm Hebel block wall	SNAP HP100R - Cast In collar - Stack	-/240/240	100mm	FSP1659
uPVC pipe	WALL	150mm Hebel block wall	SNAP HP150R - Cast In collar - Stack	-/240/180	150mm	FSP1659
uPVC pipe	WALL	150mm Hebel block wall	SNAP HP250R-B - Cast In collar	-/180/180	250mm	FSP1668
CXL PX-AL-PX pipe	WALL	75mm Hebel Powerpanel	SNAP 32GAS - Retrofit collar	-/120/120	16mm	FSP1783
CXL PX-AL-PX pipe	WALL	75mm Hebel Powerpanel	SNAP 32GAS - Retrofit collar	-/120/120	20mm	FSP1822
CXL PX-AL-PX pipe	WALL	75mm Hebel Powerpanel	SNAP 32GAS - Retrofit collar	-/120/120	25mm	FSP1822
CXL PX-AL-PX pipe	WALL	75mm Hebel Powerpanel	SNAP 32GAS - Retrofit collar	-/120/120	32mm	FSP1822
CXL PX-AL-PX pipe only (or with fitting)	WALL	75mm Hebel Powerpanel	SNAP 50GAS - Retrofit collar	-/120/60	50mm	FSP1807

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
HDPE pipe	WALL	75mm Hebel Powerpanel	SNAP LP65R - Retrofit collar	-/120/90	40mm	FSP1783
HDPE pipe	WALL	75mm Hebel Powerpanel	SNAP LP65R - Cast In collar	-/120/90	63mm	FSP1807
HDPE pipe	WALL	75mm Hebel Powerpanel	SNAP LP100R-D - Cast In collar	-/120/120	75mm	FSP1807
HDPE pipe	WALL	75mm Hebel Powerpanel	SNAP LP100R-D - Cast In collar	-/120/120	110mm	FSP1783
HDPE pipe	WALL	75mm Hebel Powerpanel	SNAP HP150R - Cast In collar	-/120/120	160mm	FSP1822
PEX-B pipe	WALL	75mm Hebel Powerpanel	SNAP 32R - Retrofit collar	-/120/120	16mm	FSP1783
PEX-B pipe	WALL	75mm Hebel Powerpanel	SNAP 32R - Retrofit collar	-/120/120	20mm	FSP1807
PEX-B pipe	WALL	75mm Hebel Powerpanel	SNAP 32R - Retrofit collar	-/120/120	32mm	FSP1807
Raupiano pipe	WALL	75mm Hebel Powerpanel	SNAP LP65R - Retrofit collar	-/120/120	50mm	FSP1822
Raupiano pipe	WALL	75mm Hebel Powerpanel	SNAP LP100R-D - Cast In collar	-/120/120	110mm	FSP1822
uPVC pipe only (or with fitting)	WALL	75mm Hebel Powerpanel	SNAP LP65R - Retrofit collar	-/120/120	40mm	FSP1783
uPVC pipe only (or with fitting)	WALL	75mm Hebel Powerpanel	SNAP LP65R - Retrofit collar	-/120/120	50mm	FSP1783
uPVC pipe only (or with fitting)	WALL	75mm Hebel Powerpanel	SNAP LP65R - Cast In collar	-/120/90	65mm	FSP1783
uPVC pipe only (or with fitting)	WALL	75mm Hebel Powerpanel	SNAP LP100R-D - Cast In collar	-/120/90	80mm	FSP1807
uPVC pipe only (or with fitting)	WALL	75mm Hebel Powerpanel	SNAP LP100R-D - Cast In collar	-/120/90	100mm	FSP1783
uPVC pipe only (or with fitting)	WALL	75mm Hebel Powerpanel	SNAP HP150R - Cast In collar	-/120/120	150mm	FSP1807
HDPE pipe	WALL	78mm Speedpanel	SNAP LP50R - Retrofit collar	-/90/90	50mm	FSV1731
HDPE pipe	WALL	78mm Speedpanel	SNAP LP100R-C - Cast In collar	-/60/60	110mm	FSV1731
uPVC pipe	WALL	78mm Speedpanel	SNAP LP50R - Retrofit collar	-/120/120	40mm	FSV1731
uPVC pipe	WALL	78mm Speedpanel	SNAP LP50R - Retrofit collar	-/120/120	50mm	FSV1731
uPVC pipe	WALL	78mm Speedpanel	SNAP LP100R-C - Cast In collar	-/90/90	65mm	FSV1731
uPVC pipe	WALL	78mm Speedpanel	SNAP LP100R-C - Cast In collar	-/120/90	80mm	FSV1731
uPVC pipe	WALL	78mm Speedpanel	SNAP 110R - Cast In collar	-/120/90	100mm	FSV1731
uPVC pipe	WALL	78mm Speedpanel	SNAP LP100R-C - Cast In collar	-/60/60	100mm	FSV1731
uPVC pipe	WALL	78mm Speedpanel	SNAP HP150R - Cast In collar	-/120/90	150mm	FSV1731
HDPE pipe	WALL	Steel Frame, 1 x16mm Plasterboard	SNAP 50R - Retrofit collar	-/90/60	40mm	FP5663
HDPE pipe	WALL	Steel Frame, 1 x16mm Plasterboard	SNAP 110R - Cast In collar	-/90/60	110mm	FP5663
PEX-A pipe	WALL	Steel Frame, 1 x16mm Plasterboard	SNAP 32R - Retrofit collar	-/120/90	16mm	FSP1723
PEX-A pipe	WALL	Steel Frame, 1 x16mm Plasterboard	SNAP 32R - Retrofit collar	-/120/90	20mm	FSP1723
PEX-A pipe	WALL	Steel Frame, 1 x16mm Plasterboard	SNAP 32R - Retrofit collar	-/120/60	25mm	FSP1723
PEX-A pipe	WALL	Steel Frame, 1 x16mm Plasterboard	SNAP 32R - Retrofit collar	-/120/60	32mm	FSP1723
PEX-B pipe	WALL	Steel Frame, 1 x16mm Plasterboard	SNAP 32R - Retrofit collar	-/120/60	16mm	FSP1723
PEX-B pipe	WALL	Steel Frame, 1 x16mm Plasterboard	SNAP 32R - Retrofit collar	-/120/60	20mm	FSP1723
PEX-B pipe	WALL	Steel Frame, 1 x16mm Plasterboard	SNAP 32R - Retrofit collar	-/120/60	25mm	FSP1723
PEX-B pipe	WALL	Steel Frame, 1 x16mm Plasterboard	SNAP 32R - Retrofit collar	-/120/60	32mm	FSP1723

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
P-PVC pipe	WALL	Steel Frame, 1 x16mm Plasterboard	SNAP 32R - Retrofit collar	-/120/60	15mm	FSP1723
P-PVC pipe	WALL	Steel Frame, 1 x16mm Plasterboard	SNAP 32R - Retrofit collar	-/90/60	25mm	FP5663
Rifeng PX-AL-PX pipe	WALL	Steel Frame, 1 x16mm Plasterboard	SNAP 32GAS - Retrofit collar	-/90/60	20mm	FP5663
uPVC pipe	WALL	Steel Frame, 1 x16mm Plasterboard	SNAP 50R - Retrofit collar	-/90/60	40mm	FP5663
uPVC pipe	WALL	Steel Frame, 1 x16mm Plasterboard	SNAP 50R - Retrofit collar	-/90/60	50mm	FP5663
uPVC pipe	WALL	Steel Frame, 1 x16mm Plasterboard	SNAP 63R - Cast In collar	-/90/60	65mm	FP5663
uPVC pipe	WALL	Steel Frame, 1 x16mm Plasterboard	SNAP 65-80R - Cast In collar	-/90/60	80mm	FP5663
uPVC pipe	WALL	Steel Frame, 1 x16mm Plasterboard	SNAP 110R - Cast In collar	-/90/60	100mm	FP5663
C-PVC pipe	WALL	Steel Frame, 2x13mm Plasterboard	SNAP 50R - Retrofit collar	-/120/120	1.25 inch	FSP1748
PEX-AL pipe	WALL	Steel Frame, 2x13mm Plasterboard	SNAP 32GAS - Retrofit collar	-/180/180	15mm	FSP1759
PEX-AL pipe	WALL	Steel Frame, 2x13mm Plasterboard	SNAP 32R - Retrofit collar	-/180/120	15mm	FSP1759
PEX-AL pipe	WALL	Steel Frame, 2x13mm Plasterboard	SNAP 32GAS - Retrofit collar	-/180/120	20mm	FSP1759
PEX-AL pipe	WALL	Steel Frame, 2x13mm Plasterboard	SNAP 32R - Retrofit collar	-/180/90	20mm	FSP1759
PEX-AL pipe	WALL	Steel Frame, 2x13mm Plasterboard	SNAP 32GAS - Retrofit collar	-/180/120	26mm	FSP1759
PEX-AL pipe	WALL	Steel Frame, 2x13mm Plasterboard	SNAP 50GAS - Retrofit collar	-/180/120	32mm	FSP1759
PEX-AL pipe	WALL	Steel Frame, 2x13mm Plasterboard	SNAP 50GAS - Retrofit collar	-/180/120	40mm	FSP1759
PEX-AL pipe	WALL	Steel Frame, 2x13mm Plasterboard	SNAP 50GAS - Retrofit collar	-/180/90	50mm	FSP1759
PEX-AL pipe	WALL	Steel Frame, 2x13mm Plasterboard	SNAP 63GAS - Retrofit collar	-/180/60	63mm	FSP1759
P-PVC pipe	WALL	Steel Frame, 2x13mm Plasterboard	SNAP 32R - Retrofit collar	-/120/120	15mm	FSP1748
P-PVC pipe	WALL	Steel Frame, 2x13mm Plasterboard	SNAP 50R - Retrofit collar	-/120/120	32mm	FSP1748
PVC Flexi pipe	WALL	Steel Frame, 2x13mm Plasterboard	SNAP 32R - Retrofit collar	-/120/120	16mm	FSP1748
uPVC pipe	WALL	Steel Frame, 2x13mm Plasterboard	SNAP 110R - Cast In collar	-/120/120	100mm	FSP1748
HDPE pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 50R - Retrofit collar	-/180/180	40mm	FP4874
HDPE pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 50R - Retrofit collar	-/180/120	50mm	FAR3929
HDPE pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 63R - Retrofit collar	-/180/120	50mm	FAR3929
HDPE pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 50R - Retrofit collar	-/180/120	56mm	FAR3929
HDPE pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 63R - Retrofit collar	-/180/120	56mm	FAR3929
HDPE pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 63R - Retrofit collar	-/180/120	63mm	FAR3929
HDPE pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 65-80R - Cast In collar	-/180/120	75mm	FAR3929
HDPE pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 84R - Cast In collar	-/180/120	75mm	FAR3929
HDPE pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 65-80R - Cast In collar	-/180/120	90mm	FAR3929
HDPE pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 110R - Cast In collar	-/180/120	110mm	FP4874
HDPE pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP HP150R - Cast In collar	-/120/120	160mm	FSP1716
IPLEX PE-AL-PE pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32GAS - Retrofit collar	-/180/180	16mm	FSP1341
IPLEX PE-AL-PE pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32GAS - Retrofit collar	-/180/180	20mm	FCO2718

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
HDPE pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 110R - Cast In collar	-/180/120	110mm	FP4874
HDPE pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP HP150R - Cast In collar	-/120/120	160mm	FSP1716
IPELEX PE-AL-PE pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32GAS - Retrofit collar	-/180/180	16mm	FSP1341
IPELEX PE-AL-PE pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32GAS - Retrofit collar	-/180/180	20mm	FCO2718
IPELEX PE-AL-PE pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32GAS - Retrofit collar	-/180/180	25mm	FCO2718
IPELEX PE-AL-PE pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32GAS - Retrofit collar	-/180/120	32mm	FSP1341
IPELEX PE-AL-PE pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 50GAS - Retrofit collar	-/180/120	32mm	FCO2718
IPELEX PE-AL-PE pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 50GAS - Retrofit collar	-/180/120	40mm	FCO2718
IPELEX PE-AL-PE pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 50GAS - Retrofit collar	-/180/120	50mm	FSP1341
PE 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32R - Retrofit collar	-/180/180	20mm	FSP1366
PE 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 50R - Retrofit collar	-/180/180	20mm	FSP1366
PE 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 63R - Retrofit collar	-/180/180	20mm	FSP1366
PE 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32R - Retrofit collar	-/180/180	25mm	FAR3929
PE 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 50R - Retrofit collar	-/180/180	25mm	FAR3929
PE 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 63R - Retrofit collar	-/180/180	25mm	FAR3929
PE 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32R - Retrofit collar	-/180/180	32mm	FSP1366
PE 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 50R - Retrofit collar	-/180/180	32mm	FAR3929
PE 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 63R - Retrofit collar	-/180/180	32mm	FAR3929
PE 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 50R - Retrofit collar	-/180/180	40mm	FAR3929
PE 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 63R - Retrofit collar	-/180/180	40mm	FAR3929
PE 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 50R - Retrofit collar	-/180/180	50mm	FSP1366
PE 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 63R - Retrofit collar	-/180/180	50mm	FAR3929
PE 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 63R - Retrofit collar	-/180/180	63mm	FSP1366
PEX-A pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32R - Retrofit collar	-/180/120	16mm	FSP1634
PEX-A pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32R - Retrofit collar	-/180/180	20mm	FSP1634
PEX-A pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32R - Retrofit collar	-/180/180	25mm	FSP1634
PEX-A pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32R - Retrofit collar	-/180/90	25mm	FSP1634
PEX-A pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32R - Retrofit collar	-/180/180	32mm	FSP1716
PEX-A pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32R - Retrofit collar	-/180/90	32mm	FSP1634
PEX-B pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32R - Retrofit collar	-/180/180	16mm	FSP1634
PEX-B pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32R - Retrofit collar	-/180/180	20mm	FSP1634
PEX-B pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32R - Retrofit collar	-/180/120	25mm	FSP1634
PEX-B pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32R - Retrofit collar	-/180/120	32mm	FSP1634
PPR 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32R - Retrofit collar	-/180/180	20mm	FSP1360
PPR 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 50R - Retrofit collar	-/180/180	20mm	FSP1360

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
PPR 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 63R - Retrofit collar	-/180/180	20mm	FSP1360
PPR 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32R - Retrofit collar	-/180/180	25mm	FAR3929
PPR 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 50R - Retrofit collar	-/180/180	25mm	FAR3929
PPR 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 63R - Retrofit collar	-/180/180	25mm	FAR3929
PPR 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32R - Retrofit collar	-/180/180	32mm	FSP1360
PPR 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 50R - Retrofit collar	-/180/180	32mm	FAR3929
PPR 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 63R - Retrofit collar	-/180/180	32mm	FAR3929
PPR 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 50R - Retrofit collar	-/180/180	40mm	FAR3929
PPR 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 63R - Retrofit collar	-/180/180	40mm	FAR3929
PPR 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 50R - Retrofit collar	-/180/180	50mm	FSP1360
PPR 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 63R - Retrofit collar	-/180/180	50mm	FAR3929
PPR 7.4 pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 63R - Retrofit collar	-/180/180	63mm	FSP1360
Progef pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32R - Retrofit collar	-/180/180	20mm	FSP1658
Progef pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32R - Retrofit collar	-/180/180	25mm	FSP1658
Progef pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32R - Retrofit collar	-/180/180	32mm	FSP1658
Progef pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32R - Retrofit collar	-/180/180	40mm	FSP1658
Progef pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 50R - Retrofit collar	-/180/180	50mm	FSP1658
Progef pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 63R - Retrofit collar	-/180/180	63mm	FSP1658
Raupiano pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 50R - Retrofit collar	-/180/180	40mm	FSP1716
Raupiano pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 110R - Cast In collar	-/180/180	110mm	FSP1716
REHAU PX-AL-PE pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32GAS - Retrofit collar	-/180/180	16mm	FSP1341
REHAU PX-AL-PE pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 50GAS - Retrofit collar	-/180/180	40mm	FSP1341
Rifeng PX-AL-PX pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32GAS - Retrofit collar	-/180/180	16mm	FCO2719
Rifeng PX-AL-PX pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32GAS - Retrofit collar	-/180/180	20mm	FCO2719
Rifeng PX-AL-PX pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32GAS - Retrofit collar	-/180/180	25mm	FCO2719
Rifeng PX-AL-PX pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 32GAS - Retrofit collar	-/180/180	32mm	FCO2719
Rifeng PX-AL-PX pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 50GAS - Retrofit collar	-/180/180	32mm	FSP1341
Rifeng PX-AL-PX pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 50GAS - Retrofit collar	-/180/120	40mm	FCO2719
Rifeng PX-AL-PX pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 50GAS - Retrofit collar	-/180/120	50mm	FCO2719
uPVC pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 50R - Retrofit collar	-/180/120	40mm	FAR3929
uPVC pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 50R - Retrofit collar	-/180/120	40mm	FP4874
uPVC pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 50R - Retrofit collar	-/180/120	50mm	FAR3929
uPVC pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 63R - Retrofit collar	-/180/120	50mm	FAR3929
uPVC pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 63R - Retrofit collar	-/180/120	50mm	FP4874
uPVC pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 63R - Cast In collar	-/180/120	65mm	FAR3929

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
uPVC pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 84R - Cast In collar	-/180/120	65mm	FP4874
uPVC pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 65-80R - Cast In collar	-/180/120	80mm	FP4874
uPVC pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 84R - Cast In collar	-/180/120	80mm	FAR3929
uPVC pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 65-80R - Cast In collar	-/180/120	90mm	FAR3929
uPVC pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 110R - Cast In collar	-/180/180	100mm	FP4874
uPVC pipe	WALL	Steel Frame, 2x16mm Plasterboard	SNAP HP150R - Cast In collar	-/120/120	150mm	FSP1716
uPVC pipe only (or with fitting)	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 50R - Retrofit collar	-/180/180	40mm	FP4874
uPVC pipe only (or with fitting)	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 65-80R - Cast In collar	-/180/120	65mm	FAR3929
uPVC pipe only (or with fitting)	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 84R - Cast In collar	-/180/120	65mm	FAR3929
uPVC pipe only (or with fitting)	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 65-80R - Cast In collar	-/180/120	80mm	FAR3929
uPVC pipe only (or with fitting)	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 110R - Cast In collar	-/180/120	90mm	FAR3929
uPVC pipe only (or with fitting)	WALL	Steel Frame, 2x16mm Plasterboard	SNAP 110R - Cast In collar	-/180/120	100mm	FP4874
PVC Pipe	BEAM	Concrete Beam	SNAP L40-50S - Cast-in collar - Stack	-/240/240	50mm	FRT190069
PVC Pipe	BEAM	Concrete Beam	SNAP H150S-RR - Cast-in collar - Stack	-/240/240	150mm	FRT190069
PVC Pipe	FLOOR	190mm Wooden Stud, 2x16mm Plasterboard on exposed side, 1x15mm CFC Floor sheeting on top	SNAP LP50R - Retro-fit collar - Floorwaste & Shower	-/90/90	50mm	FSP2097
PVC Pipe	FLOOR	190mm Wooden Stud, 2x16mm Plasterboard on exposed side, 1x15mm CFC Floor sheeting on top	SNAP LP100R-D - Retro-fit collar - Floorwaste & Shower	-/90/90	100mm	FSP2097
PVC Pipe	FLOOR	190mm Wooden Stud, 2x16mm Plasterboard on exposed side, 1x15mm CFC Floor sheeting on top	SNAP LP100R-D - Retro-fit collar - Stack	-/90/90	100mm	FSP2097
Pex-a Pipe	FLOOR	190mm Wooden Stud, 2x16mm Plasterboard on exposed side, 1x15mm CFC Floor sheeting on top	SNAP 32R - Retro-fit collar - Stack	-/90/90	32mm	FSP2097
Raupiano Pipe	FLOOR	135mm Steel stud, 2x16mm Plasterboard on exposed side, 1x15mm CFC Floor sheeting on top	SNAP LP50R - Retro-fit collar - Floorwaste & Shower	-/90/90	50mm	FSP1906
Raupiano Pipe	FLOOR	135mm Steel stud, 2x16mm Plasterboard on exposed side, 1x15mm CFC Floor sheeting on top	SNAP LP100R-D - Retro-fit collar - Floorwaste & Shower	-/90/90	110mm	FSP1906
Raupiano Pipe	FLOOR	135mm Steel stud, 2x16mm Plasterboard on exposed side, 1x15mm CFC Floor sheeting on top	SNAP LP100R-D - Retro-fit collar - Stack	-/90/90	110mm	FSP1906
4xPex-b Pipes	FLOOR	120mm Concrete Slab	SNAP H50FWS-RR - Cast-in collar - Stack	-/180/120	4 x 20mm	FSP1872
3xPex-b Pipes	FLOOR	120mm Concrete Slab	SNAP H50FWS-RR - Cast-in collar - Stack	-/180/180	3 x 25mm	FSP1872
HDPE Pipe	FLOOR	120mm Concrete Slab	SNAP H50S-RR - Cast-in collar - Stack	-/120/120	40mm	FSP2028
HDPE Pipe	FLOOR	120mm Concrete Slab	SNAP H100S-RR - Cast-in collar - Stack	-/120/120	110mm	FSP2028
PVC Pipe	FLOOR	120mm Concrete Slab	SNAP H50S-RR - Cast-in collar - Stack	-/120/120	40mm	FSP2008
PVC Pipe	FLOOR	120mm Concrete Slab	SNAP H100S-RR - Cast-in collar - Stack	-/240/120	50mm	FSP2002
PVC Pipe	FLOOR	120mm Concrete Slab	SNAP H50S-RR - Cast-in collar - Stack	-/240/120	50mm	FSP2016
PVC Pipe	FLOOR	120mm Concrete Slab	SNAP H65S-RR - Cast-in collar - Stack	-/240/120	65mm	FSP2016

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
PVC Pipe	FLOOR	120mm Concrete Slab	SNAP H100FWS-RR - Cast-in collar - Floorwaste & Shower	-/120/120	100mm	FSP2008
PVC Pipe	FLOOR	120mm Concrete Slab	SNAP H100S-RR - Cast-in collar - Stack	-/240/120	100mm	FSP2016
PVC Pipe	FLOOR	120mm Concrete Slab	SNAP H100FWS-RR - Cast-in collar - Floorwaste & Shower	-/120/120	100mm	FSP2028
Raupiano Pipe	FLOOR	120mm Concrete Slab	SNAP 50R - Retro-fit collar - Stack	-/240/120	40mm	FSP2002
Raupiano Pipe	FLOOR	120mm Concrete Slab	SNAP LP50R - Retro-fit collar - Floorwaste & Shower	-/240/120	40mm	FSP2002
Raupiano Pipe	FLOOR	120mm Concrete Slab	SNAP LP100R-D - Retro-fit collar - Floorwaste & Shower	-/240/120	110mm	FSP2002
Raupiano Pipe	FLOOR	120mm Concrete Slab	SNAP 110R - Retro-fit collar - Stack	-/120/90	110mm	FSP2002
Triplus Pipe	FLOOR	120mm Concrete Slab	SNAP H50S-RR - Cast-in collar - Stack	-/240/120	40mm	FSP2016
Triplus Pipe	FLOOR	120mm Concrete Slab	SNAP H50S-RR - Cast-in collar - Stack	-/240/120	50mm	FSP2016
Triplus Pipe	FLOOR	120mm Concrete Slab	SNAP H100S-RR - Cast-in collar - Stack	-/120/120	75mm	FSP2008
Triplus Pipe	FLOOR	120mm Concrete Slab	SNAP H100S-RR - Cast-in collar - Stack	-/120/120	110mm	FSP2008
Triplus Pipe	FLOOR	120mm Concrete Slab	SNAP H150FWS-RR - Cast-in collar - Stack	-/120/120	110mm	FSP2049
HDPE Pipe	FLOOR	120mm Concrete Slab + Bondek	SNAP H50S-RR - Cast-in collar - Stack	-/240/180	32mm	FSP1883
HDPE Pipe	FLOOR	120mm Concrete Slab + Bondek	SNAP H50S-RR - Cast-in collar - Stack	-/240/180	40mm	FSP1883
HDPE Pipe	FLOOR	120mm Concrete Slab + Bondek	SNAP H50S-RR - Cast-in collar - Stack	-/240/180	50mm	FSP1883
HDPE Pipe	FLOOR	120mm Concrete Slab + Bondek	SNAP H50FWS-RR - Cast-in collar - Floorwaste & Shower	-/240/120	50mm	FSP1883
HDPE Pipe	FLOOR	120mm Concrete Slab + Bondek	SNAP H100S-RR - Cast-in collar - Stack	-/240/120	110mm	FSP1883
HDPE Pipe	FLOOR	120mm Concrete Slab + Bondek	SNAP LP100R-D - Retro-fit collar - Floorwaste & Shower	-/240/180	110mm	FSP1953
PE 100 Pipe	FLOOR	120mm Concrete Slab + Bondek	SNAP H100FWS-RR - Cast-in collar - Floorwaste & Shower	-/240/180	100mm	FSP1882
PVC Pipe	FLOOR	120mm Concrete Slab + Bondek	SNAP 50R - Retro-fit collar - Stack	-/240/240	50mm	FSP1953
PVC Pipe	FLOOR	120mm Concrete Slab + Bondek	SNAP LP100R - Retro-fit collar - Floorwaste & Shower	-/240/180	100mm	FSP1953
PVC Pipe	FLOOR	120mm Concrete Slab + Bondek	SNAP 110R - Retro-fit collar - Stack	-/240/240	100mm	FSP1953
PVC Pipe with Fitting	FLOOR	120mm Concrete Slab + Bondek	SNAP H50S-RR - Cast-in collar - Stack	-/240/120	40mm	FSP1882
PVC Pipe with Fitting	FLOOR	120mm Concrete Slab + Bondek	SNAP H50S-RR - Cast-in collar - Stack	-/240/120	50mm	FSP1882
PVC Pipe with Fitting	FLOOR	120mm Concrete Slab + Bondek	SNAP H50FWS-RR - Cast-in collar - Floorwaste & Shower	-/240/240	50mm	FSP1882
PVC Pipe with Fitting	FLOOR	120mm Concrete Slab + Bondek	SNAP H65S-RR - Cast-in collar - Stack	-/240/120	65mm	FSP1882
PVC Pipe with Fitting	FLOOR	120mm Concrete Slab + Bondek	SNAP H100S-RR - Cast-in collar - Stack	-/240/120	100mm	FSP1882
PVC Pipe with Fitting	FLOOR	120mm Concrete Slab + Bondek	SNAP H100FWS-RR - Cast-in collar - Floorwaste & Shower	-/240/180	100mm	FSP1882
Raupiano Pipe	FLOOR	120mm Concrete Slab + Bondek	SNAP 50R - Retro-fit collar - Stack	-/240/180	50mm	FSP1953
Raupiano Pipe	FLOOR	120mm Concrete Slab + Bondek	SNAP 110R - Retro-fit collar - Stack	-/240/180	110mm	FSP1953
Triplus Pipe	FLOOR	120mm Concrete Slab + Bondek	SNAP 50R - Retro-fit collar - Stack	-/240/180	50mm	FSP1905
Triplus Pipe	FLOOR	120mm Concrete Slab + Bondek	SNAP H50S-RR - Cast-in collar - Stack	-/240/120	50mm	FSP1905
Triplus Pipe	FLOOR	120mm Concrete Slab + Bondek	SNAP H100S-RR - Cast-in collar - Stack	-/240/120	75mm	FSP1905
Triplus Pipe	FLOOR	120mm Concrete Slab + Bondek	SNAP 110R - Retro-fit collar - Stack	-/240/180	75mm	FSP1905
Triplus Pipe	FLOOR	120mm Concrete Slab + Bondek	SNAP 110R - Retro-fit collar - Stack	-/240/180	110mm	FSP1905

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
Triplus Pipe	FLOOR	120mm Concrete Slab + Bondek	SNAP H100S-RR - Cast-in collar - Stack	-/240/120	110mm	FSP1905
Coolfit 2.0 Pipe	FLOOR	150mm Concrete Slab	SNAP H100FWS-RR - Cast-in collar - Stack	-/240/240	65/110mm	FSP1891
HDPE Pipe	FLOOR	150mm Concrete Slab	SNAP H50FWS-RR - Cast-in collar - Floorwaste & Shower	-/240/240	40mm	FSP1986
HDPE Pipe	FLOOR	150mm Concrete Slab	SNAP H65S-RR - Cast-in collar - Stack	-/240/240	50mm	FC12806
HDPE Pipe	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Straight	-/120/120	50mm	FCO3373
HDPE Pipe	FLOOR	150mm Concrete Slab	SNAP H65FWS-RR - Cast-in collar - Stack	-/240/240	56mm	FC12806
HDPE Pipe	FLOOR	150mm Concrete Slab	SNAP H65FWS-RR - Cast-in collar - Stack	-/240/240	63mm	FC12806
HDPE Pipe	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Straight	-/120/120	110mm	FCO3373
HDPE Pipe	FLOOR	150mm Concrete Slab	SNAP H150S-RR - Cast-in collar - Stack	-/180/180	110mm	FSP1904
HDPE Pipe	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Stack	-/180/180	110mm	FSP2050
HDPE Pipe with Fitting	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Straight	-/120/120	50mm	FCO3373
HDPE Pipe with Fitting	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Straight	-/120/120	110mm	FCO3373
PE Pipe	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Straight	-/120/120	50mm	FCO3373
PE Pipe	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Straight	-/120/120	100mm	FCO3373
PE Pipe with Fitting	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Straight	-/120/120	50mm	FCO3373
PE Pipe with Fitting	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Straight	-/120/120	100mm	FCO3373
Pex-a Pipe	FLOOR	150mm Concrete Slab	SNAP H50S-RR - Cast-in collar - Stack	-/240/240	32mm	FSP2072
Pressure PVC Pipe	FLOOR	150mm Concrete Slab	SNAP H50FWS-RR - Cast-in collar - Stack	-/240/240	20mm	FC12806
Pressure PVC Pipe	FLOOR	150mm Concrete Slab	SNAP H50FWS-RR - Cast-in collar - Stack	-/240/240	25mm	FC12806
Pressure PVC Pipe	FLOOR	150mm Concrete Slab	SNAP H50FWS-RR - Cast-in collar - Stack	-/240/240	40mm	FC12806
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP LP65R - Retro-fit collar - Stack	-/180/180	40mm	FC12804
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP LP65R - Retro-fit collar - Floorwaste & Shower	-/180/180	40mm	FC12804
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP LP50R - Retro-fit collar - Stack	-/240/120	40mm	FC12804
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP LP50R - Retro-fit collar - Floorwaste & Shower	-/240/120	40mm	FC12804
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP H65S-RR - Cast-in collar - Stack	-/240/240	40mm	FC12806
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Straight	-/120/120	40mm	FCO3373
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Stack	-/180/180	40mm	FSP2050
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP LP65R - Retro-fit collar - Stack	-/180/180	50mm	FC12804
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP LP65R - Retro-fit collar - Floorwaste & Shower	-/180/180	50mm	FC12804
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP H65FWS-RR - Cast-in collar - Stack	-/240/240	50mm	FC12806
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP H65FWS-RR - Cast-in collar - Stack	-/240/240	50mm	FC12806
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP H65FWS-RR - Cast-in collar - Floorwaste & Shower	-/240/240	50mm	FC12806
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP H65S-RR - Cast-in collar - Stack	-/240/240	50mm	FC12806
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Straight	-/120/120	50mm	FCO3373
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP H50S-RR w/ LP50R - Retro-fit & Cast-in collar - Floorwaste & Shower	-/240/240	56mm	FSP1673

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP LP65R - Retro-fit collar - Stack	-/240/240	65mm	FC12804
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP LP65R - Retro-fit collar - Floorwaste & Shower	-/240/240	65mm	FC12804
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP H65FWS-RR - Cast-in collar - Stack	-/240/240	65mm	FC12806
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP H65FWS-RR - Cast-in collar - Stack	-/240/240	65mm	FC12806
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP H65FWS-RR - Cast-in collar - Floorwaste & Shower	-/240/240	65mm	FC12806
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP H65S-RR - Cast-in collar - Stack	-/240/240	65mm	FC12806
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Straight	-/120/120	65mm	FCO3373
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Stack	-/180/180	65mm	FSP2050
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP LP100R-D - Retro-fit collar - Stack	-/240/240	80mm	FC12804
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP LP100R-D - Retro-fit collar - Stack	-/240/240	80mm	FC12804
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Straight	-/120/120	80mm	FCO3373
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Stack	-/180/180	80mm	FSP2050
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP LP100R-B - Retro-fit collar - Stack	-/240/180	100mm	FC12804
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP LP100R-B - Retro-fit collar - Floorwaste & Shower	-/240/180	100mm	FC12804
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP H150S-RR - Cast-in collar - Stack	-/240/240	100mm	FC12806
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Straight	-/120/120	100mm	FCO3373
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Straight	-/120/120	100mm	FCO3373
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP H100S-RR w/ LP100R - Retro-fit & Cast-in collars - Floorwaste & Shower	-/240/240	100mm	FSP1673
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP 110R - Retro-fit collar - Stack	-/240/240	100mm	FSP1673
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Stack	-/180/180	100mm	FSP2050
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP HP150R - Retro-fit collar - Floorwaste & Shower	-/240/180	150mm	FC12804
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP H150FWS-RR - Cast-in collar - Stack	-/240/240	150mm	FC12806
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP H150S-RR - Cast-in collar - Stack	-/240/240	150mm	FC12806
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP 200C - Cast-in collar - Straight	-/240/180	175mm	FSP1949
PVC Pipe	FLOOR	150mm Concrete Slab	SNAP HP315R - Retro-fit collar - Stack	-/180/180	315mm	FSP1872
PVC Pipe with Fitting	FLOOR	150mm Concrete Slab	SNAP LP65R - Retro-fit collar - Stack	-/180/180	40mm	FC12804
PVC Pipe with Fitting	FLOOR	150mm Concrete Slab	SNAP LP50R - Retro-fit collar - Stack	-/240/120	40mm	FC12804
PVC Pipe with Fitting	FLOOR	150mm Concrete Slab	SNAP LP65R - Retro-fit collar - Stack	-/180/180	50mm	FC12804
PVC Pipe with Fitting	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Straight	-/120/120	50mm	FCO3373
PVC Pipe with Fitting	FLOOR	150mm Concrete Slab	SNAP LP65R - Retro-fit collar - Stack	-/240/240	65mm	FC12804
PVC Pipe with Fitting	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Straight	-/120/120	65mm	FCO3373
PVC Pipe with Fitting	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Straight	-/120/120	80mm	FCO3373
PVC Pipe with Fitting	FLOOR	150mm Concrete Slab	SNAP LP100R-B - Retro-fit collar - Stack	-/240/180	100mm	FC12804
PVC Pipe with Fitting	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Straight	-/120/120	100mm	FCO3373
PVC Pipe with Fitting	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Straight	-/120/120	100mm	FCO3373

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
Raupiano Pipe	FLOOR	150mm Concrete Slab	SNAP LP50R - Retro-fit collar - Stack	-/240/240	40mm	FC12804
Raupiano Pipe	FLOOR	150mm Concrete Slab	SNAP LP50R - Retro-fit collar - Floorwaste & Shower	-/240/240	50mm	FC12804
Raupiano Pipe	FLOOR	150mm Concrete Slab	SNAP LP50R - Retro-fit collar - Stack	-/240/240	50mm	FC12804
Raupiano Pipe	FLOOR	150mm Concrete Slab	SNAP LP50R - Retro-fit collar - Stack	-/240/240	50mm	FC12804
Raupiano Pipe	FLOOR	150mm Concrete Slab	SNAP H65S-RR - Cast-in collar - Stack	-/240/240	50mm	FC12806
Raupiano Pipe	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Straight	-/120/120	50mm	FCO3373
Raupiano Pipe	FLOOR	150mm Concrete Slab	SNAP 50R - Retro-fit collar - Stack	-/240/240	50mm	FSP2072
Raupiano Pipe	FLOOR	150mm Concrete Slab	SNAP LP100R-B - Retro-fit collar - Stack	-/240/240	75mm	FC12804
Raupiano Pipe	FLOOR	150mm Concrete Slab	SNAP LP100R-B - Retro-fit collar - Stack	-/240/240	75mm	FC12804
Raupiano Pipe	FLOOR	150mm Concrete Slab	SNAP H100FWS-RR - Cast-in collar - Floorwaste & Shower	-/240/240	75mm	FC12806
Raupiano Pipe	FLOOR	150mm Concrete Slab	SNAP LP100R-B - Retro-fit collar - Stack	-/240/240	90mm	FC12804
Raupiano Pipe	FLOOR	150mm Concrete Slab	SNAP LP100R-B - Retro-fit collar - Stack	-/240/240	90mm	FC12804
Raupiano Pipe	FLOOR	150mm Concrete Slab	SNAP H100FWS-RR - Cast-in collar - Floorwaste & Shower	-/240/240	90mm	FC12806
Raupiano Pipe	FLOOR	150mm Concrete Slab	SNAP LP100R-B - Retro-fit collar - Stack	-/240/240	110mm	FC12804
Raupiano Pipe	FLOOR	150mm Concrete Slab	SNAP H150FWS-RR - Cast-in collar - Stack	-/240/240	110mm	FC12806
Raupiano Pipe	FLOOR	150mm Concrete Slab	SNAP H150S-RR - Cast-in collar - Stack	-/240/180	110mm	FC12806
Raupiano Pipe	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Straight	-/120/120	110mm	FCO3373
Raupiano Pipe	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Stack	-/240/240	110mm	FSP2072
Raupiano Pipe	FLOOR	150mm Concrete Slab	SNAP 110R - Retro-fit collar - Stack	-/240/240	110mm	FSP2072
Raupiano Pipe with Fitting	FLOOR	150mm Concrete Slab	SNAP H65S-RR - Cast-in collar - Stack	-/240/240	50mm	FC12806
Raupiano Pipe with Fitting	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Straight	-/120/120	50mm	FCO3373
Raupiano Pipe with Fitting	FLOOR	150mm Concrete Slab	SNAP H100S-RR - Cast-in collar - Stack	-/240/240	75mm	FC12806
Raupiano Pipe with Fitting	FLOOR	150mm Concrete Slab	SNAP H100S-RR - Cast-in collar - Stack	-/240/240	90mm	FC12806
Raupiano Pipe with Fitting	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Straight	-/120/120	110mm	FCO3373
Triplus Pipe	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Straight	-/120/120	50mm	FCO3373
Triplus Pipe	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Straight	-/120/120	110mm	FCO3373
Triplus Pipe with Fitting	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Straight	-/120/120	50mm	FCO3373
Triplus Pipe with Fitting	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Straight	-/120/120	110mm	FCO3373
Triplus Pipe with Fitting	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar - Stack	-/240/240	110mm	FSP2072
PVC Pipe	FLOOR	200mm Concrete Slab	SNAP HP400R - Retro-fit collar - Stack	-/120/120	375mm	FSP2074
HDPE Pipe	FLOOR	230mm Concrete Slab	SNAP 250C - Cast-in collar - Stack	-/240/240	250mm	FSP1986
HDPE Pipe	FLOOR	250mm Concrete Slab	SNAP 315C - Cast-in collar - Stack	-/240/180	315mm	FSP1924
HDPE Pipe	WALL	64mm Steel Stud, 13mm Plasterboard either side	SNAP 50R - Retro-fit collar - Straight	-/60/60	40mm	FSP1960
PEX-AL-PEX Pipe	WALL	64mm Steel Stud, 13mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/60/60	16mm	FSP1932
PEX-AL-PEX Pipe	WALL	64mm Steel Stud, 13mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/60/60	20mm	FSP1932

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
PEX-AL-PEX Pipe	WALL	64mm Steel Stud, 13mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/60/60	25mm	FSP1960
PEX-b Pipe	WALL	64mm Steel Stud, 13mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/60/60	16mm	FSP1932
PEX-b Pipe	WALL	64mm Steel Stud, 13mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/60/60	20mm	FSP1985
PEX-b Pipe	WALL	64mm Steel Stud, 13mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/60/60	25mm	FSP1932
Pressure PVC Pipe	WALL	64mm Steel Stud, 13mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/60/60	16mm	FSP1932
Pressure PVC Pipe	WALL	64mm Steel Stud, 13mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/60/60	20mm	FSP1960
Pressure PVC Pipe	WALL	64mm Steel Stud, 13mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/60/60	25mm	FSP1985
PVC Pipe	WALL	64mm Steel Stud, 13mm Plasterboard either side	SNAP 50R - Retro-fit collar - Straight	-/60/60	50mm	FSP1985
PVC Pipe	WALL	64mm Steel Stud, 13mm Plasterboard either side	SNAP 110R - Retro-fit collar - Straight	-/60/60	100mm	FSP1985
PVC Pipe with Fitting	WALL	64mm Steel Stud, 13mm Plasterboard either side	SNAP 50R - Retro-fit collar - Straight	-/60/60	50mm	FSP1932
PVC Pipe with Fitting	WALL	64mm Steel Stud, 13mm Plasterboard either side	SNAP 110R - Retro-fit collar - Straight	-/60/60	100mm	FSP1932
Raupiano Pipe	WALL	64mm Steel Stud, 13mm Plasterboard either side	SNAP 50R - Retro-fit collar - Straight	-/60/60	40mm	FSP2024
Raupiano Pipe	WALL	64mm Steel Stud, 13mm Plasterboard either side	SNAP 110R - Retro-fit collar - Straight	-/60/60	110mm	FSP2024
Triplus Pipe	WALL	64mm Steel Stud, 13mm Plasterboard either side	SNAP 50R - Retro-fit collar - Straight	-/60/60	40mm	FSP2024
Triplus Pipe	WALL	64mm Steel Stud, 13mm Plasterboard either side	SNAP 110R - Retro-fit collar - Straight	-/60/60	110mm	FSP2024
HDPE Pipe	WALL	64mm Steel Stud, 16mm Plasterboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/60	50mm	FC10395
HDPE Pipe	WALL	64mm Steel Stud, 16mm Plasterboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/60	50mm	FC10395
HDPE Pipe	WALL	64mm Steel Stud, 16mm Plasterboard either side	SNAP 63R - Retro-fit collar - Straight	-/90/60	56mm	FC10395
HDPE Pipe	WALL	64mm Steel Stud, 16mm Plasterboard either side	SNAP 63R - Retro-fit collar - Straight	-/90/60	63mm	FC10395
HDPE Pipe	WALL	64mm Steel Stud, 16mm Plasterboard either side	SNAP 63R - Retro-fit collar - Straight	-/90/60	75mm	FC10395
HDPE Pipe	WALL	64mm Steel Stud, 16mm Plasterboard either side	SNAP 65-80R - Retro-fit collar - Straight	-/90/60	90mm	FC10395
HDPE Pipe	WALL	64mm Steel Stud, 16mm Plasterboard either side	SNAP 110R - Retro-fit collar - Straight	-/90/60	110mm	FC10395
PEX-a Pipe	WALL	64mm Steel Stud, 16mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	16mm	FCO3379
PEX-a Pipe	WALL	64mm Steel Stud, 16mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	20mm	FCO3379
PEX-a Pipe	WALL	64mm Steel Stud, 16mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/60	25mm	FCO3379
PEX-a Pipe	WALL	64mm Steel Stud, 16mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/60	32mm	FCO3379
PEX-b Pipe	WALL	64mm Steel Stud, 16mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/60	16mm	FCO3379
PEX-b Pipe	WALL	64mm Steel Stud, 16mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/60	20mm	FCO3379
PEX-b Pipe	WALL	64mm Steel Stud, 16mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/60	25mm	FCO3379
PEX-b Pipe	WALL	64mm Steel Stud, 16mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/60	32mm	FCO3379
Pressure PVC Pipe	WALL	64mm Steel Stud, 16mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/60	15mm	FCO3379
Pressure PVC Pipe	WALL	64mm Steel Stud, 16mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/60	20mm	FC10395
PVC Pipe	WALL	64mm Steel Stud, 16mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/60	32mm	FC10395
PVC Pipe	WALL	64mm Steel Stud, 16mm Plasterboard either side	SNAP 65-80R - Retro-fit collar - Straight	-/90/60	80mm	FC10395
PVC Pipe	WALL	64mm Steel Stud, 16mm Plasterboard either side	SNAP 65-80R - Retro-fit collar - Straight	-/90/60	90mm	FC10395

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
PVC Pipe	WALL	64mm Steel Stud, 16mm Plasterboard either side	SNAP 110R - Retro-fit collar - Straight	-/90/60	100mm	FC10395
C-PVC Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP 50R - Retro-fit collar - Straight	-/120/120	1.25 inch	FCO3348
C-PVC Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP 50R - Retro-fit collar - Straight	-/120/120	1.5 Inch	FCO3348
C-PVC Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP 50R - Retro-fit collar - Straight	-/120/120	2 Inch	FCO3348
HDPE Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP HP315R - Retro-fit collar - Straight	-/120/120	315mm	FCO3348
Pexal Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP 32GAS - Retro-fit collar - Straight	-/120/120	15mm	FCO3348
Pexal Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP 32R - Retro-fit collar - Straight	-/120/120	15mm	FCO3348
Pexal Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP 32GAS - Retro-fit collar - Straight	-/120/120	20mm	FCO3348
Pexal Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP 32GAS - Retro-fit collar - Straight	-/120/120	26mm	FCO3348
Pexal Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP 50GAS - Retro-fit collar - Straight	-/120/120	32mm	FCO3348
Pexal Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP 50GAS - Retro-fit collar - Straight	-/120/120	40mm	FCO3348
Pex-b Pipes	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP 32R - Retro-fit collar - Straight	-/120/120	2 x 20mm	FCO3348
Pressure PVC Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP 32R - Retro-fit collar - Straight	-/120/120	15mm	FCO3348
Pressure PVC Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP 50R - Retro-fit collar - Straight	-/120/120	32mm	FCO3348
PVC (Flexi) Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP 32R - Retro-fit collar - Straight	-/120/120	16mm	FCO3348
PVC Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP 50R - Retro-fit collar - Straight	-/120/120	50mm	FCO3348
PVC Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP 65-80R - Retro-fit collar - Straight	-/120/120	65mm	FCO3348
PVC Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP 110R - Retro-fit collar - Straight	-/120/120	100mm	FCO3348
PVC Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP HP250R-B - Retro-fit collar - Straight	-/120/120	225mm	FCO3348
PVC Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP HP315R - Retro-fit collar - Straight	-/120/120	315mm	FCO3348
PVC Pipe with Fitting	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP 110R - Retro-fit collar - Straight	-/120/120	100mm	FCO3348
Px/Al/Px & Pex-b Pipes	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP 32R - Retro-fit collar - Straight	-/120/120	20mm + 20mm	FCO3348
Px/Al/Px & Pex-b Pipes	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP 50R - Retro-fit collar - Straight	-/120/120	25mm + 20mm	FCO3348
Raupiano Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP 110R - Retro-fit collar - Straight	-/120/120	110mm	FCO3348
Raupiano Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP 50R - Retro-fit collar - Straight	-/120/120	40mm	FCO3348
Triplus Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP 50R - Retro-fit collar - Straight	-/120/120	40mm	FCO3348
2xPex-b Pipes	WALL	64mm Steel Stud, 2x13mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/120/120	2 x 20mm	FSP1902
C-PVC Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard either side	SNAP 50R - Retro-fit collar - Straight	-/120/120	1.5 Inch	FSP1902
C-PVC Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard either side	SNAP 50R - Retro-fit collar - Straight	-/120/120	2 Inch	FSP1978
HDPE Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard either side	SNAP 50R - Retro-fit collar - Straight	-/120/120	40mm	FSP2090
HDPE Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard either side	SNAP 110R - Retro-fit collar - Straight	-/120/120	110mm	FSP2090
HDPE Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard either side	SNAP HP250R-B - Retro-fit collar - Straight	-/120/120	250mm	FSP2040
HDPE Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard either side	SNAP HP315R - Retro-fit collar - Straight	-/120/120	315mm	FSP1946
PVC Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard either side	SNAP 50R - Retro-fit collar - Straight	-/120/120	40mm	FSP2090
PVC Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard either side	SNAP HP250R-B - Retro-fit collar - Straight	-/120/120	225mm	FSP1978

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
PVC Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard either side	SNAP HP315R - Retro-fit collar - Straight	-/120/120	315mm	FSP1931
PVC Pipe with Fitting	WALL	64mm Steel Stud, 2x13mm Plasterboard either side	SNAP 50R - Retro-fit collar - Straight	-/120/120	40mm	FSP2090
PVC Pipe with Fitting	WALL	64mm Steel Stud, 2x13mm Plasterboard either side	SNAP 50R - Retro-fit collar - Straight	-/120/120	50mm	FSP1902
PVC Pipe with Fitting	WALL	64mm Steel Stud, 2x13mm Plasterboard either side	SNAP 65-80R - Retro-fit collar - Straight	-/120/120	65mm	FSP1902
PVC Pipe with Fitting	WALL	64mm Steel Stud, 2x13mm Plasterboard either side	SNAP 65-80R - Retro-fit collar - Straight	-/120/120	80mm	FSP2090
PVC Pipe with Fitting	WALL	64mm Steel Stud, 2x13mm Plasterboard either side	SNAP 110R - Retro-fit collar - Straight	-/120/120	100mm	FSP1996
PVC Pipe with Fitting	WALL	64mm Steel Stud, 2x13mm Plasterboard either side	SNAP HP150R - Retro-fit collar - Straight	-/120/120	150mm	FSP2090
PX-AL-PX + PEX-b Pipes	WALL	64mm Steel Stud, 2x13mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/120/120	20mm + 20mm	FSP1902
PX-AL-PX + PEX-b Pipes	WALL	64mm Steel Stud, 2x13mm Plasterboard either side	SNAP 50R - Retro-fit collar - Straight	-/120/120	25mm + 20mm	FSP1902
Raupiano Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard either side	SNAP 50R - Retro-fit collar - Straight	-/120/120	40mm	FSP1996
Raupiano Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard either side	SNAP 110R - Retro-fit collar - Straight	-/120/120	110mm	FSP1996
Triplus Pipe	WALL	64mm Steel Stud, 2x13mm Plasterboard either side	SNAP 50R - Retro-fit collar - Straight	-/120/120	40mm	FSP1996
GASPEX PX-AL-PX Pipe	WALL	64mm Steel Stud, 2x16mm Plasterboard either side	SNAP 50GAS - Mounted collar - Straight	-/180/180	32mm	FCO3379
HDPE Pipe	WALL	64mm Steel Stud, 2x16mm Plasterboard either side	SNAP HP150R - Retro-fit collar - Straight	-/120/120	160mm	FCO3379
IPLEX PE-AL-PE Pipe	WALL	64mm Steel Stud, 2x16mm Plasterboard either side	SNAP 32GAS - Mounted collar - Straight	-/180/180	16mm	FCO3379
IPLEX PE-AL-PE Pipe	WALL	64mm Steel Stud, 2x16mm Plasterboard either side	SNAP 32GAS - Mounted collar - Straight	-/180/120	32mm	FCO3379
IPLEX PE-AL-PE Pipe	WALL	64mm Steel Stud, 2x16mm Plasterboard either side	SNAP 50GAS - Mounted collar - Straight	-/180/120	50mm	FCO3379
PE 7.4 Pipe	WALL	64mm Steel Stud, 2x16mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/180/180	20mm	FCO3379
PE 7.4 Pipe	WALL	64mm Steel Stud, 2x16mm Plasterboard either side	SNAP 63R - Retro-fit collar - Straight	-/180/180	20mm	FCO3379
PE 7.4 Pipe	WALL	64mm Steel Stud, 2x16mm Plasterboard either side	SNAP 50R - Retro-fit collar - Straight	-/180/180	20mm	FCO3379
PE 7.4 Pipe	WALL	64mm Steel Stud, 2x16mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/180/180	32mm	FCO3379
PE 7.4 Pipe	WALL	64mm Steel Stud, 2x16mm Plasterboard either side	SNAP 50R - Retro-fit collar - Straight	-/180/180	50mm	FCO3379
PE 7.4 Pipe	WALL	64mm Steel Stud, 2x16mm Plasterboard either side	SNAP 63R - Retro-fit collar - Straight	-/180/180	63mm	FCO3379
PEX-a Pipe	WALL	64mm Steel Stud, 2x16mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/180/180	32mm	FCO3379
PPR 7.4 Pipe	WALL	64mm Steel Stud, 2x16mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/180/180	20mm	FCO3379
PPR 7.4 Pipe	WALL	64mm Steel Stud, 2x16mm Plasterboard either side	SNAP 63R - Retro-fit collar - Straight	-/180/180	20mm	FCO3379
PPR 7.4 Pipe	WALL	64mm Steel Stud, 2x16mm Plasterboard either side	SNAP 50R - Retro-fit collar - Straight	-/180/180	20mm	FCO3379
PPR 7.4 Pipe	WALL	64mm Steel Stud, 2x16mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/180/180	32mm	FCO3379
PPR 7.4 Pipe	WALL	64mm Steel Stud, 2x16mm Plasterboard either side	SNAP 50R - Retro-fit collar - Straight	-/180/180	50mm	FCO3379
PPR 7.4 Pipe	WALL	64mm Steel Stud, 2x16mm Plasterboard either side	SNAP 63R - Retro-fit collar - Straight	-/180/180	63mm	FCO3379
PVC Pipe	WALL	64mm Steel Stud, 2x16mm Plasterboard either side	SNAP HP150R - Retro-fit collar - Straight	-/120/120	150mm	FCO3379
Raupiano Pipe	WALL	64mm Steel Stud, 2x16mm Plasterboard either side	SNAP 50R - Retro-fit collar - Straight	-/180/180	40mm	FCO3379
Raupiano Pipe	WALL	64mm Steel Stud, 2x16mm Plasterboard either side	SNAP 50R - Retro-fit collar - Straight	-/180/120	50mm	FC10394
Raupiano Pipe	WALL	64mm Steel Stud, 2x16mm Plasterboard either side	SNAP 65-80R - Retro-fit collar - Straight	-/180/120	75mm	FC10394
Raupiano Pipe	WALL	64mm Steel Stud, 2x16mm Plasterboard either side	SNAP 110R - Retro-fit collar - Straight	-/180/120	90mm	FC10394

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
Raupiano Pipe	WALL	64mm Steel Stud, 2x16mm Plasterboard either side	SNAP 110R - Retro-fit collar - Straight	-/180/180	110mm	FCO3379
REHAU PX-AL-PE Pipe	WALL	64mm Steel Stud, 2x16mm Plasterboard either side	SNAP 32GAS - Mounted collar - Straight	-/180/180	16mm	FCO3379
REHAU PX-AL-PE Pipe	WALL	64mm Steel Stud, 2x16mm Plasterboard either side	SNAP 50GAS - Mounted collar - Straight	-/180/180	40mm	FCO3379
CXL Px-AI-Px Pipe	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP 32GAS - Mounted collar - Straight	-/120/120	16mm	FCO3331
CXL Px-AI-Px Pipe	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP 32GAS - Mounted collar - Straight	-/120/120	20mm	FCO3331
CXL Px-AI-Px Pipe	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP 32GAS - Mounted collar - Straight	-/120/120	25mm	FCO3331
CXL Px-AI-Px Pipe	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP 32GAS - Mounted collar - Straight	-/120/120	32mm	FCO3331
CXL Px-AI-Px Pipe	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP 50GAS - Mounted collar - Straight	-/120/60	50mm	FCO3331
HDPE Pipe	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP LP65R - Retro-fit collar - Straight	-/120/120	40mm	FCO3331
HDPE Pipe	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP LP65R - Retro-fit collar - Straight	-/120/120	63mm	FCO3331
HDPE Pipe	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP LP100R-D - Retro-fit collar - Straight	-/120/120	75mm	FCO3331
HDPE Pipe	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP LP100R-D - Retro-fit collar - Straight	-/120/120	110mm	FCO3331
HDPE Pipe	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP HP150R - Retro-fit collar - Straight	-/120/120	160mm	FCO3331
PEX-AI-PEX Pipe	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP 32GAS - Mounted collar - Straight	-/120/120	16mm	FC11840
PEX-AI-PEX Pipe	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP 32GAS - Mounted collar - Straight	-/120/120	20mm	FC11840
PEX-AI-PEX Pipe	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP 32GAS - Mounted collar - Straight	-/120/120	25mm	FC11840
PEX-AI-PEX Pipe	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP 32GAS - Mounted collar - Straight	-/120/120	32mm	FC11840
PEX-AI-PEX Pipe	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP 50GAS - Mounted collar - Straight	-/120/60	40mm	FC11840
PEX-AI-PEX Pipe	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP 50GAS - Mounted collar - Straight	-/120/60	50mm	FC11840
PEX-b Pipe	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP 32R - Retro-fit collar - Straight	-/120/120	16mm	FCO3331
PEX-b Pipe	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP 32R - Retro-fit collar - Straight	-/120/120	20mm	FCO3331
PEX-b Pipe	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP 32R - Retro-fit collar - Straight	-/120/120	25mm	FC10389
PEX-b Pipe	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP 32R - Retro-fit collar - Straight	-/120/120	32mm	FCO3331
PVC Pipe with Fitting	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP LP65R - Retro-fit collar - Straight	-/120/120	40mm	FCO3331
PVC Pipe with Fitting	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP LP65R - Retro-fit collar - Straight	-/120/120	50mm	FCO3331
PVC Pipe with Fitting	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP LP65R - Retro-fit collar - Straight	-/120/120	65mm	FCO3331
PVC Pipe with Fitting	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP LP100R-D - Retro-fit collar - Straight	-/120/120	80mm	FCO3331
PVC Pipe with Fitting	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP LP100R-D - Retro-fit collar - Straight	-/120/120	100mm	FCO3331
PVC Pipe with Fitting	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP HP150R - Retro-fit collar - Straight	-/120/120	150mm	FCO3331
Raupiano Pipe	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP LP65R - Retro-fit collar - Straight	-/120/120	40mm	FC11838
Raupiano Pipe	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP LP65R - Retro-fit collar - Straight	-/120/120	50mm	FCO3331
Raupiano Pipe	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP LP100R-D - Retro-fit collar - Straight	-/120/120	75mm	FC11838
Raupiano Pipe	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP LP100R-D - Retro-fit collar - Straight	-/120/120	90mm	FC11838
Raupiano Pipe	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP LP100R-D - Retro-fit collar - Straight	-/120/120	110mm	FCO3331
HDPE Pipe	WALL	75mm Hebel Powerpanel Wall (90 min)	SNAP LP65R - Retro-fit collar - Straight	-/120/90	50mm	FC10129

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
HDPE Pipe	WALL	75mm Hebel Powerpanel Wall (90 min)	SNAP LP65R - Retro-fit collar - Straight	-/120/90	56mm	FC10129
HDPE Pipe	WALL	75mm Hebel Powerpanel Wall (90 min)	SNAP LP100R-D - Retro-fit collar - Straight	-/120/120	90mm	FC10129
HDPE Pipe	WALL	75mm Hebel Powerpanel Wall (90 min)	SNAP HP150R - Retro-fit collar - Straight	-/120/120	125mm	FC10129
PEX-a Pipe	WALL	75mm Hebel Powerpanel Wall (90 min)	SNAP 32R - Retro-fit collar - Straight	-/120/120	16mm	FC10389
PEX-a Pipe	WALL	75mm Hebel Powerpanel Wall (90 min)	SNAP 32R - Retro-fit collar - Straight	-/120/120	20mm	FC10389
PEX-a Pipe	WALL	75mm Hebel Powerpanel Wall (90 min)	SNAP 32R - Retro-fit collar - Straight	-/120/120	25mm	FC10389
PEX-a Pipe	WALL	75mm Hebel Powerpanel Wall (90 min)	SNAP 32R - Retro-fit collar - Straight	-/120/120	32mm	FC10389
PVC Pipe	WALL	75mm Hebel Powerpanel Wall (90 min)	SNAP LP65R - Retro-fit collar - Straight	-/120/120	40mm	FC10124
PVC Pipe	WALL	75mm Hebel Powerpanel Wall (90 min)	SNAP LP65R - Retro-fit collar - Straight	-/120/120	50mm	FC10124
PVC Pipe	WALL	75mm Hebel Powerpanel Wall (90 min)	SNAP LP65R - Retro-fit collar - Straight	-/120/90	65mm	FC10124
PVC Pipe	WALL	75mm Hebel Powerpanel Wall (90 min)	SNAP LP100R-D - Retro-fit collar - Straight	-/120/90	80mm	FC10124
PVC Pipe	WALL	75mm Hebel Powerpanel Wall (90 min)	SNAP LP100R-D - Retro-fit collar - Straight	-/120/90	90mm	FC10124
PVC Pipe	WALL	75mm Hebel Powerpanel Wall (90 min)	SNAP LP100R-D - Retro-fit collar - Straight	-/120/90	100mm	FC10124
PVC Pipe	WALL	75mm Hebel Powerpanel Wall (90 min)	SNAP LP100R-D - Retro-fit collar - Straight	-/120/90	100mm	FC10124
PVC Pipe	WALL	75mm Hebel Powerpanel Wall (90 min)	SNAP HP150R - Retro-fit collar - Straight	-/120/120	150mm	FC10124
PVC Pipe with Fitting	WALL	75mm Hebel Powerpanel Wall (90 min)	SNAP LP100R-D - Retro-fit collar - Straight	-/120/90	90mm	FC10124
PVC Pipe with Fitting	WALL	75mm Hebel Powerpanel Wall (90 min)	SNAP LP100R-D - Retro-fit collar - Straight	-/120/90	100mm	FC10124
PX/Al/Px Pipe	WALL	75mm Hebel Powerpanel Wall (90 min)	SNAP 32R - Retro-fit collar - Straight	-/90/90	16mm	FSP2058
PX/Al/Px Pipe	WALL	75mm Hebel Powerpanel Wall (90 min)	SNAP 32R - Retro-fit collar - Straight	-/90/90	20mm	FSP2058
Raupiano Pipe	WALL	75mm Hebel Powerpanel Wall (90 min)	SNAP LP65R - Retro-fit collar - Straight	-/120/120	40mm	FC11838
Raupiano Pipe	WALL	75mm Hebel Powerpanel Wall (90 min)	SNAP LP100R-D - Retro-fit collar - Straight	-/120/120	75mm	FC11838
Raupiano Pipe	WALL	75mm Hebel Powerpanel Wall (90 min)	SNAP LP100R-D - Retro-fit collar - Straight	-/120/120	90mm	FC11838
Triplus Pipe	WALL	75mm Hebel Powerpanel Wall (90 min)	SNAP LP50R - Retro-fit collar - Straight	-/90/90	50mm	FSP2058
Triplus Pipe	WALL	75mm Hebel Powerpanel Wall (90 min)	SNAP LP100R-D - Retro-fit collar - Straight	-/90/90	100mm	FSP2058
2xPex-b Pipes	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	2x20mm	FCO3268
C-PVC Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	32mm	FCO3268
C-PVC Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	38mm	FCO3268
C-PVC Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	50mm	FCO3268
GASPEX PX-AL-PX Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32GAS - Mounted collar - Straight	-/90/90	16mm	FCO3268
GASPEX PX-AL-PX Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32GAS - Mounted collar - Straight	-/90/90	20mm	FCO3268
GASPEX PX-AL-PX Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32GAS - Mounted collar - Straight	-/90/90	25mm	FCO3268
GASPEX PX-AL-PX Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50GAS - Mounted collar - Straight	-/90/90	32mm	FCO3268
GASPEX PX-AL-PX Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32GAS - Mounted collar - Straight	-/90/90	32mm	FCO3268
GASPEX PX-AL-PX Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50GAS - Mounted collar - Straight	-/90/90	40mm	FCO3268
GASPEX PX-AL-PX Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50GAS - Mounted collar - Straight	-/90/90	50mm	FCO3268

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
HDPE Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	40mm	FCO3268
HDPE Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	50mm	FCO3268
HDPE Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	50mm	FCO3268
HDPE Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	56mm	FCO3268
HDPE Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	56mm	FCO3268
HDPE Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	63mm	FCO3268
HDPE Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 65-80R - Retro-fit collar - Straight	-/90/90	75mm	FCO3268
HDPE Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 65-80R - Retro-fit collar - Straight	-/90/90	90mm	FCO3268
HDPE Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 110R - Retro-fit collar - Straight	-/90/90	110mm	FCO3268
HDPE Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP HP150R - Retro-fit collar - Straight	-/90/90	160mm	FCO3268
HDPE Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP HP250R-B - Retro-fit collar - Straight	-/90/90	250mm	FCO3268
HDPE Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP HP315R - Retro-fit collar - Straight	-/90/90	315mm	FCO3268
IPEX PE-AL-PE Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32GAS - Mounted collar - Straight	-/90/90	16mm	FCO3268
IPEX PE-AL-PE Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32GAS - Mounted collar - Straight	-/90/90	20mm	FCO3268
IPEX PE-AL-PE Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32GAS - Mounted collar - Straight	-/90/90	25mm	FCO3268
IPEX PE-AL-PE Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50GAS - Mounted collar - Straight	-/90/90	32mm	FCO3268
IPEX PE-AL-PE Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32GAS - Mounted collar - Straight	-/90/90	32mm	FCO3268
IPEX PE-AL-PE Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50GAS - Mounted collar - Straight	-/90/90	40mm	FCO3268
IPEX PE-AL-PE Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50GAS - Mounted collar - Straight	-/90/90	50mm	FCO3268
PE 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	20mm	FCO3268
PE 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	20mm	FCO3268
PE 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	20mm	FCO3268
PE 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	25mm	FCO3268
PE 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	25mm	FCO3268
PE 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	25mm	FCO3268
PE 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	32mm	FCO3268
PE 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	32mm	FCO3268
PE 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	32mm	FCO3268
PE 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	40mm	FCO3268
PE 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	40mm	FCO3268
PE 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	50mm	FCO3268
PE 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	50mm	FCO3268
PE 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	63mm	FCO3268
PEX-a Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	16mm	FCO3268
PEX-a Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	20mm	FCO3268

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
PEX-a Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	25mm	FCO3268
PEX-a Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	32mm	FCO3268
PEX-a Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	32mm	FCO3268
PEXAL Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32GAS - Mounted collar - Straight	-/90/90	15mm	FCO3268
PEXAL Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	15mm	FCO3268
PEXAL Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32GAS - Mounted collar - Straight	-/90/90	20mm	FCO3268
PEXAL Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	20mm	FCO3268
PEXAL Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32GAS - Mounted collar - Straight	-/90/90	26mm	FCO3268
PEXAL Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50GAS - Mounted collar - Straight	-/90/90	32mm	FCO3268
PEXAL Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50GAS - Mounted collar - Straight	-/90/90	40mm	FCO3268
PEXAL Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50GAS - Mounted collar - Straight	-/90/90	50mm	FCO3268
PEX-b Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	16mm	FCO3268
PEX-b Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	20mm	FCO3268
PEX-b Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	25mm	FCO3268
PEX-b Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	32mm	FCO3268
PPR 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	20mm	FCO3268
PPR 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	20mm	FCO3268
PPR 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	20mm	FCO3268
PPR 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	25mm	FCO3268
PPR 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	25mm	FCO3268
PPR 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	25mm	FCO3268
PPR 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	32mm	FCO3268
PPR 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	32mm	FCO3268
PPR 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	32mm	FCO3268
PPR 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	40mm	FCO3268
PPR 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	40mm	FCO3268
PPR 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	50mm	FCO3268
PPR 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	50mm	FCO3268
PPR 7.4 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	63mm	FCO3268
Pressure PVC Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	15mm	FCO3268
Pressure PVC Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	32mm	FCO3268
Progef SDR11 PN10 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	20mm	FCO3268
Progef SDR11 PN10 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	25mm	FCO3268
Progef SDR11 PN10 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	32mm	FCO3268
Progef SDR11 PN10 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	40mm	FCO3268

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
Progef SDR11 PN10 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	50mm	FCO3268
Progef SDR11 PN10 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	63mm	FCO3268
Progef SDR7.4 PN16 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	20mm	FCO3268
Progef SDR7.4 PN16 Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	25mm	FCO3268
PVC (Flexi) Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	16mm	FCO3268
PVC Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	40mm	FCO3268
PVC Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	40mm	FCO3268
PVC Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	50mm	FCO3268
PVC Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	50mm	FCO3268
PVC Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	50mm	FCO3268
PVC Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	50mm	FCO3268
PVC Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	65mm	FCO3268
PVC Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 65-80R - Retro-fit collar - Straight	-/90/90	65mm	FCO3268
PVC Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 65-80R - Retro-fit collar - Straight	-/90/90	65mm	FCO3268
PVC Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 65-80R - Retro-fit collar - Straight	-/90/90	80mm	FCO3268
PVC Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 65-80R - Retro-fit collar - Straight	-/90/90	80mm	FCO3268
PVC Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 65-80R - Retro-fit collar - Straight	-/90/90	90mm	FCO3268
PVC Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 110R - Retro-fit collar - Straight	-/90/90	90mm	FCO3268
PVC Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 110R - Retro-fit collar - Straight	-/90/90	100mm	FCO3268
PVC Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 110R - Retro-fit collar - Straight	-/90/90	100mm	FCO3268
PVC Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 110R - Retro-fit collar - Straight	-/90/90	100mm	FCO3268
PVC Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP HP150R - Retro-fit collar - Straight	-/90/90	150mm	FCO3268
PVC Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP HP250R-B - Retro-fit collar - Straight	-/90/90	225mm	FCO3268
PVC Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP HP315R - Retro-fit collar - Straight	-/90/90	315mm	FCO3268
PVC Pipe with Fitting	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	40mm	FCO3268
PVC Pipe with Fitting	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	40mm	FCO3268
PVC Pipe with Fitting	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	50mm	FCO3268
PVC Pipe with Fitting	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 65-80R - Retro-fit collar - Straight	-/90/90	65mm	FCO3268
PVC Pipe with Fitting	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 65-80R - Retro-fit collar - Straight	-/90/90	80mm	FCO3268
PVC Pipe with Fitting	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 110R - Retro-fit collar - Straight	-/90/90	90mm	FCO3268
PVC Pipe with Fitting	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 110R - Retro-fit collar - Straight	-/90/90	100mm	FCO3268
Px/Al/Px + Pex-b Pipes	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	20mm + 20mm	FCO3268
Px/Al/Px + Pex-b Pipes	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	25mm + 20mm	FCO3268
Raupiano Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	40mm	FCO3268
Raupiano Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	40mm	FCO3268

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
Raupiano Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	40mm	FCO3268
Raupiano Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	50mm	FCO3268
Raupiano Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 65-80R - Retro-fit collar - Straight	-/90/90	75mm	FCO3268
Raupiano Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 65-80R - Retro-fit collar - Straight	-/90/90	90mm	FCO3268
Raupiano Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 110R - Retro-fit collar - Straight	-/90/90	110mm	FCO3268
Raupiano Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 110R - Retro-fit collar - Straight	-/90/90	110mm	FCO3268
Raupiano Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 110R - Retro-fit collar - Straight	-/90/90	110mm	FCO3268
REHAU PX-AL-PE Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32GAS - Mounted collar - Straight	-/90/90	16mm	FCO3268
REHAU PX-AL-PE Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50GAS - Mounted collar - Straight	-/90/90	40mm	FCO3268
Triplus Pipe	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	40mm	FCO3268
2xPex-b Pipes	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	2x20mm	FCO3369
C-PVC Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	32mm	FCO3369
C-PVC Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	38mm	FCO3369
C-PVC Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	50mm	FCO3369
GASPEX PX-AL-PX Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32GAS - Mounted collar - Straight	-/90/90	16mm	FCO3369
GASPEX PX-AL-PX Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32GAS - Mounted collar - Straight	-/90/90	20mm	FCO3369
GASPEX PX-AL-PX Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32GAS - Mounted collar - Straight	-/90/90	25mm	FCO3369
GASPEX PX-AL-PX Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50GAS - Mounted collar - Straight	-/90/90	32mm	FCO3369
GASPEX PX-AL-PX Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32GAS - Mounted collar - Straight	-/90/90	32mm	FCO3369
GASPEX PX-AL-PX Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50GAS - Mounted collar - Straight	-/90/90	40mm	FCO3369
GASPEX PX-AL-PX Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50GAS - Mounted collar - Straight	-/90/90	50mm	FCO3369
HDPE Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	40mm	FCO3369
HDPE Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	50mm	FCO3369
HDPE Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	50mm	FCO3369
HDPE Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	56mm	FCO3369
HDPE Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	56mm	FCO3369
HDPE Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	63mm	FCO3369
HDPE Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 65-80R - Retro-fit collar - Straight	-/90/90	75mm	FCO3369
HDPE Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 65-80R - Retro-fit collar - Straight	-/90/90	90mm	FCO3369
HDPE Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 110R - Retro-fit collar - Straight	-/90/90	110mm	FCO3369
HDPE Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP HP150R - Retro-fit collar - Straight	-/90/90	160mm	FCO3369
HDPE Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP HP250R-B - Retro-fit collar - Straight	-/90/90	250mm	FCO3369
HDPE Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP HP315R - Retro-fit collar - Straight	-/90/90	315mm	FCO3369
IPLEX PE-AL-PE Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32GAS - Mounted collar - Straight	-/90/90	16mm	FCO3369
IPLEX PE-AL-PE Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32GAS - Mounted collar - Straight	-/90/90	20mm	FCO3369

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
IPEX PE-AL-PE Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32GAS - Mounted collar - Straight	-/90/90	25mm	FCO3369
IPEX PE-AL-PE Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50GAS - Mounted collar - Straight	-/90/90	32mm	FCO3369
IPEX PE-AL-PE Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32GAS - Mounted collar - Straight	-/90/90	32mm	FCO3369
IPEX PE-AL-PE Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50GAS - Mounted collar - Straight	-/90/90	40mm	FCO3369
IPEX PE-AL-PE Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50GAS - Mounted collar - Straight	-/90/90	50mm	FCO3369
PE 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	20mm	FCO3369
PE 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	20mm	FCO3369
PE 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	20mm	FCO3369
PE 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	25mm	FCO3369
PE 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	25mm	FCO3369
PE 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	25mm	FCO3369
PE 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	32mm	FCO3369
PE 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	32mm	FCO3369
PE 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	32mm	FCO3369
PE 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	40mm	FCO3369
PE 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	40mm	FCO3369
PE 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	50mm	FCO3369
PE 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	50mm	FCO3369
PE 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	63mm	FCO3369
PEX-a Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	16mm	FCO3369
PEX-a Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	20mm	FCO3369
PEX-a Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	25mm	FCO3369
PEX-a Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	32mm	FCO3369
PEX-a Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	32mm	FCO3369
PEXAL Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32GAS - Mounted collar - Straight	-/90/90	15mm	FCO3369
PEXAL Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	15mm	FCO3369
PEXAL Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32GAS - Mounted collar - Straight	-/90/90	20mm	FCO3369
PEXAL Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	20mm	FCO3369
PEXAL Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32GAS - Mounted collar - Straight	-/90/90	26mm	FCO3369
PEXAL Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50GAS - Mounted collar - Straight	-/90/90	32mm	FCO3369
PEXAL Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50GAS - Mounted collar - Straight	-/90/90	40mm	FCO3369
PEXAL Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50GAS - Mounted collar - Straight	-/90/90	50mm	FCO3369
PEX-b Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	16mm	FCO3369
PEX-b Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	20mm	FCO3369
PEX-b Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	25mm	FCO3369

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
PEX-b Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	32mm	FCO3369
PPR 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	20mm	FCO3369
PPR 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	20mm	FCO3369
PPR 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	20mm	FCO3369
PPR 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	25mm	FCO3369
PPR 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	25mm	FCO3369
PPR 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	25mm	FCO3369
PPR 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	32mm	FCO3369
PPR 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	32mm	FCO3369
PPR 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	32mm	FCO3369
PPR 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	40mm	FCO3369
PPR 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	40mm	FCO3369
PPR 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	50mm	FCO3369
PPR 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	50mm	FCO3369
PPR 7.4 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	63mm	FCO3369
Pressure PVC Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	15mm	FCO3369
Pressure PVC Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	32mm	FCO3369
Progef SDR11 PN10 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	20mm	FCO3369
Progef SDR11 PN10 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	25mm	FCO3369
Progef SDR11 PN10 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	32mm	FCO3369
Progef SDR11 PN10 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	40mm	FCO3369
Progef SDR11 PN10 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	50mm	FCO3369
Progef SDR11 PN10 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	63mm	FCO3369
Progef SDR7.4 PN16 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	20mm	FCO3369
Progef SDR7.4 PN16 Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	25mm	FCO3369
PVC (Flexi) Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	16mm	FCO3369
PVC Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	40mm	FCO3369
PVC Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	40mm	FCO3369
PVC Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	50mm	FCO3369
PVC Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	50mm	FCO3369
PVC Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	50mm	FCO3369
PVC Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	50mm	FCO3369
PVC Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	65mm	FCO3369
PVC Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 65-80R - Retro-fit collar - Straight	-/90/90	65mm	FCO3369
PVC Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 65-80R - Retro-fit collar - Straight	-/90/90	65mm	FCO3369

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
NON-INSULATED COMBUSTIBLE PIPES						
PVC Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 65-80R - Retro-fit collar - Straight	-/90/90	80mm	FCO3369
PVC Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 65-80R - Retro-fit collar - Straight	-/90/90	80mm	FCO3369
PVC Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 65-80R - Retro-fit collar - Straight	-/90/90	90mm	FCO3369
PVC Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 110R - Retro-fit collar - Straight	-/90/90	90mm	FCO3369
PVC Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 110R - Retro-fit collar - Straight	-/90/90	100mm	FCO3369
PVC Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 110R - Retro-fit collar - Straight	-/90/90	100mm	FCO3369
PVC Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 110R - Retro-fit collar - Straight	-/90/90	100mm	FCO3369
PVC Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP HP150R - Retro-fit collar - Straight	-/90/90	150mm	FCO3369
PVC Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP HP250R-B - Retro-fit collar - Straight	-/90/90	225mm	FCO3369
PVC Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP HP315R - Retro-fit collar - Straight	-/90/90	315mm	FCO3369
PVC Pipe with Fitting	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	40mm	FCO3369
PVC Pipe with Fitting	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	40mm	FCO3369
PVC Pipe with Fitting	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 63R - Retro-fit collar - Straight	-/90/90	50mm	FCO3369
PVC Pipe with Fitting	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 65-80R - Retro-fit collar - Straight	-/90/90	65mm	FCO3369
PVC Pipe with Fitting	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 65-80R - Retro-fit collar - Straight	-/90/90	80mm	FCO3369
PVC Pipe with Fitting	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 110R - Retro-fit collar - Straight	-/90/90	90mm	FCO3369
PVC Pipe with Fitting	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 110R - Retro-fit collar - Straight	-/90/90	100mm	FCO3369
Px/Al/Px + Pex-b Pipes	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	20mm + 20mm	FCO3369
Px/Al/Px + Pex-b Pipes	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	25mm + 20mm	FCO3369
Raupiano Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	40mm	FCO3369
Raupiano Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	40mm	FCO3369
Raupiano Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	40mm	FCO3369
Raupiano Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	50mm	FCO3369
Raupiano Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 65-80R - Retro-fit collar - Straight	-/90/90	75mm	FCO3369
Raupiano Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 65-80R - Retro-fit collar - Straight	-/90/90	90mm	FCO3369
Raupiano Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 110R - Retro-fit collar - Straight	-/90/90	110mm	FCO3369
Raupiano Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 110R - Retro-fit collar - Straight	-/90/90	110mm	FCO3369
Raupiano Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 110R - Retro-fit collar - Straight	-/90/90	110mm	FCO3369
REHAU PX-AL-PE Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32GAS - Mounted collar - Straight	-/90/90	16mm	FCO3369
REHAU PX-AL-PE Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50GAS - Mounted collar - Straight	-/90/90	40mm	FCO3369
Triplus Pipe	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 50R - Retro-fit collar - Straight	-/90/90	40mm	FCO3369

Service Penetration	Orientation	Substrate	System Description	FRR	Specimen Size	Report Ref.
ELECTRICAL PENETRATION SERVICES						
PVC Conduit	FLOOR	150mm Concrete Slab	SNAP 32R - Retrofit collar - Stack	-/240/240	20mm	FSP1781
PVC Conduit	FLOOR	150mm Concrete Slab	SNAP 32R - Retrofit collar - Stack	-/240/240	20mm	FSP1781
PVC Conduit	FLOOR	150mm Concrete Slab	SNAP 32R - Retrofit collar - Stack	-/240/240	25mm	FSP1781
PVC Conduit	FLOOR	150mm Concrete Slab	SNAP 32R - Retrofit collar - Stack	-/240/240	25mm	FSP1781
PVC Conduit	WALL	75mm Hebel Powerpanel	SNAP 32R - Retrofit collar	-/120/120	20mm	FSP1783
PVC Conduit	WALL	75mm Hebel Powerpanel	SNAP 32R - Retrofit collar	-/120/120	25mm	FSP1807
PVC Conduit	WALL	Steel Frame, 1 x16mm Plasterboard	SNAP 32R - Retrofit collar	-/90/60	25mm	FP5663
PVC Conduit	WALL	Steel Frame, 2x13mm Plasterboard	SNAP 32R - Retrofit collar	-/120/120	20mm	FSP1748
PVC Conduit	WALL	Steel Frame, 2x13mm Plasterboard	SNAP 32R - Retrofit collar	-/120/120	20mm	FSP1748
PVC Conduit	WALL	Steel Frame, 2x13mm Plasterboard	SNAP 32R - Retrofit collar	-/120/120	25mm	FSP1748
PVC Conduit	WALL	Steel Frame, 2x13mm Plasterboard	SNAP 32R - Retrofit collar	-/120/120	25mm	FSP1748
PVC Conduit	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP 32R - Retro-fit collar - Straight	-/120/120	20mm	FCO3348
PVC Conduit	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP 32R - Retro-fit collar - Straight	-/120/120	20mm	FCO3348
PVC Conduit	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP 32R - Retro-fit collar - Straight	-/120/120	20mm	FCO3348
PVC Conduit	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP 32R - Retro-fit collar - Straight	-/120/120	25mm	FCO3348
PVC Conduit	WALL	64mm Steel Stud, 2x13mm Plasterboard and 25mm Shaft Liner	SNAP 32R - Retro-fit collar - Straight	-/120/120	25mm	FCO3348
PVC Conduit	WALL	64mm Steel Stud, 2x13mm Plasterboard either side	SNAP 32R - Retro-fit collar - Straight	-/120/120	20mm	FSP1902
PVC Conduit	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP 32R - Retro-fit collar - Straight	-/120/120	20mm	FCO3331
PVC Conduit (+3-Core Cable)	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP 32R - Retro-fit collar - Straight	-/120/120	20mm	FCO3331
PVC Conduit (+3-Core Cable)	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP 32R - Retro-fit collar - Straight	-/120/120	25mm	FCO3331
PVC Conduit	WALL	75mm Hebel Powerpanel Wall (120 min)	SNAP 32R - Retro-fit collar - Straight	-/120/120	27mm	FCO3331
PVC Conduit	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	20mm	FCO3268
PVC Conduit	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	20mm	FCO3268
PVC Conduit (+3-Core Cable)	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	20mm	FCO3268
PVC Conduit	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	25mm	FCO3268
PVC Conduit (+3-Core Cable)	WALL	90mm Steel Stud, 10mm Firecrunch either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	25mm	FCO3268
PVC Conduit	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	20mm	FCO3369
PVC Conduit	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	20mm	FCO3369
PVC Conduit (+3-Core Cable)	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	20mm	FCO3369
PVC Conduit	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	25mm	FCO3369
PVC Conduit (+3-Core Cable)	WALL	90mm Steel Stud, 2x7.5mm Multiboard either side	SNAP 32R - Retro-fit collar - Straight	-/90/90	25mm	FCO3369
MIXED SERVICE PENETRATION DEVICES						
Pair Coil w/ FR Lagging & 4C+E Cable	FLOOR	120mm Concrete Slab	SNAP H50FWS-RR - Cast-in collar - Stack	-/180/90	3/8 & 3/4 inch	FSP1872
Collar may be filled with Rockwool in lieu of a pipe	FLOOR	150mm Concrete Slab	SNAP H110S - Cast-in collar	-/120/120		FCO3373