

04/04/2016

Hardware required to be listed:-

Watermist (at present we expect this will be a case by case process)

All sprinkler heads

Flexible droppers

Alarm valves

Deluge valve and preaction valves. (this is effectively done as part of the project review process)

Supervisory devices on isolation valves

Automatic pressure and flow regulating valves. (pressure relief, pressure sustaining valves, pressure reducing, tank infill float valve.

Backflow preventors

Pipes not on table 4.3

PVC-C pipe

Strainers

Sprinkler gong

Pressure switches & sensors

Kitchen fire suppression systems

Pump (the one on the fire pump; not jockey pumps.)

Diesel engines (this is effectively done as part of the project review process)

Electric motor controller

FSI inlet (this means the coupler itself)